



Next Generation Hydrogen Station Composite Data Products: All Stations (Retail and Non-Retail Combined)

Data through Quarter 4 of 2016

Sam Sprik, Jennifer Kurtz, Chris Ainscough,
Genevieve Saur, and Michael Peters

May 10, 2017

NREL/PR-5400-68554


Hydrogen Station Project Partners




- Air Liquide
- Air Products
- California Air Resources Board
- California Energy Commission
- California State University Los Angeles
- First Element
- Gas Technology Institute
- Linde
- H2 Frontier
- Proton OnSite
- Shell
- IPHE and HySUT



Analysis Categories




Deployment



NREL cdp_infr_10


Created: May-08-17 4:46 PM | Data Range: 2009Q3-2016Q4

Hydrogen Stations by Type



NREL cdp_infr_11

Created: May-08-17 4:46 PM | Data Range: 2008Q3-2016Q4



NREL edp_infr_27


Created: Dec-19-16 4:38 PM | Data Range: 2009Q1-2016Q3

Safety

Safety (and Maintenance) Learnings

From Safety Reports Template

- Alarms not communicated
- Breakaway leak
- Check compressor oil filter
- Check integrity of delivered equipment
- Compressor leaking at startup normal?
- Does isolated leak need to shut down station?
- Electrical glitch
- Estop activated after hearing escaping gas-nitrogen
- Estop activated when nozzle stuck on car
- Estop activated without cause
- Estop flooded prevented restart
- False alarm - No Fire
- Fill and leak check together caused shutdown - false leak alarm
- Filter to catch scrap from material processing
- Forgot to turn back on after maintenance
- Freezing and thawing caused moisture in communication connector
- Frozen cooling block - defrost
- HTO sensor fault
- Heat trace short caused false fire alarm
- Heavy rain triggered fire alarm
- Hose vent failure - nozzle stuck on car
- Loose wire intermittent problems
- Loud popping could be relief valve
- Mass balance alarm bug
- Mass balance alarm caused by high ambient temperature
- Power Issue - 3 Phase
- Predict service life better
- Proper installation prevents leaks
- Rain on sensor causing alarm
- Regular inspection of compressor valves
- Regular leak checks
- Regular station inspection
- Reset
- Spider web obscuring sensor
- Thermocouple failure shutdown station
- Vibration from normal activity shutdown dispenser
- Vibration isolation



An Incident is an event that results in:

- a lost time accident and/or injury to personnel
- damage/unplanned downtime for project equipment, facilities or property
- impact to the public or environment
- any hydrogen release that unintentionally ignites
- release of any volatile, hydrogen containing compound (including the hydrocarbons used as common fuels)

A Near Miss is:

- an event that under slightly different circumstances could have become an incident
- any hydrogen release sufficient to sustain a flame if ignited


A Minor H2 Leak is:

- an unplanned hydrogen release insufficient to sustain a flame, and does not accumulate in sufficient quantity to ignite



NREL cdp_infr_31

Created: Apr-20-17 11:47 AM | Data Range: 2008Q3-2016Q4



An Incident is an event that results in:

- a lost time accident and/or injury to personnel
- damage/unplanned downtime for project equipment, facilities or property
- impact to the public or environment
- any hydrogen release that unintentionally ignites
- release of any volatile, hydrogen containing compound (including the hydrocarbons used as common fuels)

A Near Miss is:

- an event that under slightly different circumstances could have become an incident
- any hydrogen release sufficient to sustain a flame if ignited


A Minor H2 Leak is:

- an unplanned hydrogen release insufficient to sustain a flame, and does not accumulate in sufficient quantity to ignite



NREL cdp_infr_32

Created: Apr-20-17 11:48 AM | Data Range: 2008Q3-2016Q4



An Incident is an event that results in:


- a lost time accident and/or injury to personnel
- damage/unplanned downtime for project equipment, facilities or property
- impact to the public or environment
- any hydrogen release that unintentionally ignites
- release of any volatile, hydrogen containing compound (including the hydrocarbons used as common fuels)

A Near Miss is:

- an event that under slightly different circumstances could have become an incident
- any hydrogen release sufficient to sustain a flame if ignited

A Minor H2 Leak is:





An Incident is an event that results in:

- a lost time accident and/or injury to personnel
- damage/unplanned downtime for project equipment, facilities or property
- impact to the public or environment
- any hydrogen release that unintentionally ignites
- release of any volatile, hydrogen containing compound (including the hydrocarbons used as common fuels)

A Near Miss is:

- an event that under slightly different circumstances could have become an incident
- any hydrogen release sufficient to sustain a flame if ignited

A Minor H2 Leak is:


- an unplanned hydrogen release insufficient to sustain a flame, and does not accumulate in sufficient quantity to ignite




NREL cdp_infr_34

Created: Apr-20-17 11:37 AM | Data Range: 2008Q3-2016Q4

Mean Fills per Hydrogen Leak




Mean Hydrogen Dispensed per Hydrogen Leak





Maintenance and Reliability

Maintenance by Equipment Type






1. Total includes classified events (plotted) and unclassified events.







Failure Modes for Top Equipment Categories



MISC includes the following failure modes: animal damage, collision, communication error, contamination, corrective maintenance, debris, design flaw, electrical breaker, end of life, environmental factors, fluid temp, freezing, installation error, inspect trouble alarm or report, level low, loose electrical, loose mechanical, maintenance error, manufacturing defect, material deform/degrade/fatigue, moisture, na, operator error, out of calibration, overtemperature, power outage/quality, pressure loss, software bug, stress outside design limit, tight, vandalism, vibration, other

* Percentage of total events or hours.





NREL edp_infr_26

Created: Apr-20-17 11:45 AM | Data Range: 2011Q1-2016Q4

* Trendlines connect continuous months of operation for a single station. Gaps in trendlines represent quarters in which a station was offline or missing data. Each station is represented by a unique color.

Maintenance Labor Hours by Month






NREL cdp_infr_30


Created: Apr-24-17 11:01 AM | Data Range: 2011Q1-2016Q4

*Each color represents a unique station.




NREL cdp_infr_49

Created: Apr-24-17 2:11 PM | Data Range: 2011Q1-2016Q4




1. IEC 61164:2004(E), Reliability Growth - Statistical Test and Evaluation Methods, IEC. 2004.
2. % change in instantaneous mean Fills between failures

Mean Amount Dispensed Between Failures




NREL cdp_infr_51


Created: Apr-24-17 2:11 PM | Data Range: 2011Q1-2016Q4




1. IEC 61164:2004(E), Reliability Growth - Statistical Test and Evaluation Methods, IEC. 2004.
2. % change in instantaneous mean H₂ Dispensed (kg) between failures




Historical Failure Rate (bathtub curve) by kg H₂ Dispensed




 NREL cdp_infr_60
 Created: Apr-24-17 2:53 PM | Data Range: 2011Q1-2016Q4






Maintenance Causes and Effects

Subsystem: SAFETY

Component: ENTIRE

Preventative Maintenance accounted for 93% of all events.
Suppressed in the plot to show detail for other causes.



Causes

Effects



NREL cdp_infr_64


Created: Apr-20-17 11:48 AM | Data Range: 2011Q1-2016Q4

Maintenance Causes and Effects

Subsystem: SAFETY

Component: SENSOR

Preventative Maintenance accounted for 52% of all events.
Suppressed in the plot to show detail for other causes.



Causes

Effects




NREL cdp_infr_65

Created: Apr-20-17 11:47 AM | Data Range: 2011Q1-2016Q4

Maintenance Causes and Effects

Subsystem: SAFETY

Component: SOFTWARE



Causes

Effects



NREL cdp_infr_66


Created: Apr-20-17 11:40 AM | Data Range: 2011Q1-2016Q4

Maintenance Causes and Effects

Subsystem: DISPENSER

Component: ENTIRE

Preventative Maintenance accounted for 41% of all events.
Suppressed in the plot to show detail for other causes.



Causes

Effects



NREL cdp_infr_67


Created: Apr-20-17 11:30 AM | Data Range: 2011Q1-2016Q4

Maintenance Causes and Effects: Dispenser (Valve)

Maintenance Causes and Effects

Subsystem: DISPENSER

Component: VALVE



Causes


Effects



NREL cdp_infr_68

Created: Apr-20-17 11:30 AM | Data Range: 2011Q1-2016Q4

Maintenance Causes and Effects
Subsystem: DISPENSER
Component: FITTING



Causes

Effects



NREL cdp_infr_69


Created: Apr-20-17 11:44 AM | Data Range: 2011Q1-2016Q4

Maintenance Causes and Effects

Subsystem: COMPRESSOR

Component: ENTIRE

Preventative Maintenance accounted for 66% of all events.
Suppressed in the plot to show detail for other causes.




NREL cdp_infr_70

Created: Apr-20-17 11:41 AM | Data Range: 2011Q1-2016Q4

Maintenance Causes and Effects

Subsystem: COMPRESSOR

Component: VALVE



Causes

Effects



NREL cdp_infr_71


Created: Apr-20-17 11:30 AM | Data Range: 2011Q1-2016Q4

Maintenance Causes and Effects: Compressor (Seal)

Maintenance Causes and Effects

Subsystem: COMPRESSOR

Component: SEAL



Causes




NREL cdp_infr_72

Created: Apr-20-17 11:30 AM | Data Range: 2011Q1-2016Q4

Performance


Hydrogen Dispensed by Quarter



NREL cdp_infr_01

Created: May-08-17 4:27 PM | Data Range: 2009Q3-2016Q4

Note: Colors represent individual stations




NREL cdp_infr_58

Created: May-08-17 5:15 PM | Data Range: 2009Q3-2016Q4


Note: Colors represent individual stations

Hydrogen Dispensed by Region




NREL cdp_infr_81


Created: May-05-17 3:30 PM | Data Range: 2009Q3-2016Q4





Histogram of Fueling Times



Histogram of Fueling Amounts






NREL cdp_infr_08

Created: May-08-17 4:42 PM | Data Range: 2008Q3-2016Q4


*Time is from end of fill to start of next fill.




NREL cdp_infr_09

Created: May-08-17 4:44 PM | Data Range: 2008Q3-2016Q4


*The line at 450 bar separates 350 bar fills from 700 bar fills. It is slightly over the allowable 125% of nominal pressure (437.5 bar) from SAE J2601.







NREL cdp_infr_13


Created: May-08-17 4:49 PM | Data Range: 2008Q3-2016Q4






1. Friday Chevron profile "Hydrogen Delivery Infrastructure Options Analysis", T. Chen, 2008.







Histogram of Fueling Amount Vs Time



 NREL cdp_infr_18
Created: May-06-17 4:57 PM | Data Range: 2008Q3-2016Q4

Histogram of Fueling Rates
By Year






NREL cdp_infr_29


Created: Apr-20-17 11:39 AM | Data Range: 2011Q1-2016Q4


Monthly Averages: All Fills



NREL cdp_infr_55

Created: May-08-17 5:10 PM | Data Range: 2009Q3-2016Q4







1. SAE J2601 (2014) defines fuel delivery temperature as measured near the dispenser breakaway. See paragraph 4.21. Temperature data here are from HyStEP tests measuring fuel temperature just downstream of the receptacle. SAE J2601 requires that fuel delivery temperature reach the limits shown in blue above within 30 seconds of the start of fueling.



Cost



Station Costs by Daily Capacity




NREL cdp_infr_40

Created: Dec-16-16 12:34 PM | Data Range: 2009Q1-2016Q3

Average Station Cost by Category

Budget Amounts* (Avg Total = \$2.2M), 46 Stations




*Based on budgeted data from station awards (includes cost share)

**Station includes: Hydrogen Equipment and Station Engineering, Design, Fabrication, Procurement, Site Preparation, Installation, and Construction


***Data Reporting includes quarterly reporting on performance, operation and maintenance


CDP-INFR-42

Station Cost




Station Cost by Type





Maintenance Cost per kg of Hydrogen Dispensed




NREL cdp_infr_53

Created: Apr-20-17 11:37 AM | Data Range: 2011Q1-2016Q4

*Each color represents a unique station. 3 data points excluded that were over \$1000/kg


Utilization

Dispensed Hydrogen per Day of Week



NREL cdp_infr_05
 Created: May-08-17 4:36 PM | Data Range: 2009Q3-2016Q4

1. Chevron weekly demand profile "Hydrogen Delivery Infrastructure Options Analysis", T. Chen.




NREL cdp_infr_06
 Created: May-08-17 4:38 PM | Data Range: 2008Q3-2016Q4

¹ Station nameplate capacity reflects a variety of system design considerations including system capacity, throughput, system reliability and durability, and maintenance. Actual daily usage may exceed nameplate capacity.
² Maximum quarterly utilization considers all days; average daily utilization considers only days when at least one filling occurred

CDP-INFR-07


Station Usage



NREL cdp_infr_07
 Created: May-08-17 4:40 PM | Data Range: 2009Q3-2016Q4


¹Excludes hydrogen fills of < 0.5 kg


²Average daily fills considers only days when at least one fill occurred




NREL cdp_infr_19
Created: May-08-17 4:58 PM | Data Range: 2008Q3-2016Q4

Number of Fills by Month



 NREL cdp_infr_20
Created: May-08-17 4:59 PM | Data Range: 2008Q3-2016Q4


Hydrogen Dispensed by Station Type



NREL cdp_infr_74

Created: May-08-17 5:18 PM | Data Range: 2008Q3-2016Q4

Station Capacity Utilization Trends by Quarter




¹ Trendlines connect continuous quarters of operation for a single station. Gaps in trendlines represent quarters in which a station was offline or missing data. Each station is represented by a unique color.

² Average quarterly utilization only considers quarters when at least one fill occurred.


³ Station nameplate capacity is as reported to NREL and reflects a variety of system design considerations including: system capacity, throughput, system reliability, and maintenance. Actual daily usage may exceed nameplate capacity.

Station Amount Dispensed by Quarter



¹ Trendlines connect continuous quarters of operation for a single station. Gaps in trendlines represent quarters in which a station was offline or missing data. Each station is represented by a unique color.


² Average quarterly amount only considers quarters when at least one fill occurred.



¹ Trendlines connect continuous quarters of operation for a single station. Gaps in trendlines represent quarters in which a station had no fills or was missing data. Each station is represented by a unique color.

² The average percent of days with fills only considers quarters in which at least one fill occurred. Stations with no filling days in a quarter are excluded from the average for that quarter. All stations with at least one fill in a quarter are given equal weight when calculating the average for the quarter.

Summary of Station Usage Statistics⁴




¹ Station nameplate capacity is as reported to NREL and reflects a variety of system design considerations including: system capacity, throughput, system reliability, and maintenance. Actual daily usage may exceed nameplate capacity.

² Average quarterly utilization only considers days when at least one fill occurred.


³ Utilization is calculated by dividing the quarterly amount dispensed by the stations nameplate capacity.

⁴ Only quarters with fills are included.






Daily Fueling Amounts by Month




Hydrogen Quality

CDP-INFR-25

Hydrogen Quality




* Values are in micromole/mole, except for particulate size (Psize) in micrometer. Only values that exceed SAE J2719 guideline are shown in text. Left edge of text box aligns with date



NREL cdp_infr_79
 Created: May-08-17 5:23 PM | Data Range: 2011Q1-2016Q4


CDP-INFR-79

Impurities—Argon




NREL cdp_infr_79

Created: May-08-17 5:21 PM | Data Range: 2011Q1-2016Q4




NREL cdp_infr_79

Created: May-08-17 5:21 PM | Data Range: 2011Q1-2016Q4




NREL cdp_infr_79

Created: May-08-17 5:22 PM | Data Range: 2011Q1-2016Q4




NREL cdp_infr_79

Created: May-08-17 5:22 PM | Data Range: 2011Q1-2016Q4




NREL cdp_infr_79

Created: May-08-17 5:23 PM | Data Range: 2011Q1-2016Q4




NREL cdp_infr_79

Created: May-08-17 5:20 PM | Data Range: 2011Q1-2016Q4




NREL cdp_infr_79

Created: May-08-17 5:21 PM | Data Range: 2011Q1-2016Q4




NREL cdp_infr_79

Created: May-08-17 5:20 PM | Data Range: 2011Q1-2016Q4




NREL cdp_infr_79

Created: May-08-17 5:24 PM | Data Range: 2011Q1-2016Q4




NREL cdp_infr_79

Created: May-08-17 5:23 PM | Data Range: 2011Q1-2016Q4




NREL cdp_infr_79
Created: May-08-17 5:20 PM | Data Range: 2011Q1-2016Q4

Notes for exceeding SAE J2719 Limits:
Ok for Total HC = 3.2 (Methane = 3.2 ok per SAE J2719)



NREL cdp_infr_79



Created: May-08-17 5:22 PM | Data Range: 2011Q1-2016Q4




NREL cdp_infr_79

Created: May-08-17 5:19 PM | Data Range: 2011Q1-2016Q4

Component Energy





NREL cdp_infr_36

Created: May-01-17 11:29 AM | Data Range: 2013Q4-2016Q4

Station Energy per kg Dispensed

