



# WESTERN WIND AND SOLAR INTEGRATION STUDY: EXECUTIVE SUMMARY

*PREPARED FOR:*

**The National Renewable Energy Laboratory**

A national laboratory of the U.S. Department of Energy

*PREPARED BY:*

**GE Energy**

*MAY 2010*

## NOTICE

This report was prepared as an account of work sponsored by an agency of the United States government. Neither the United States government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States government or any agency thereof.

Available electronically at <http://www.osti.gov/bridge>

Available for a processing fee to U.S. Department of Energy and its contractors, in paper, from:

U.S. Department of Energy  
Office of Scientific and Technical Information  
P.O. Box 62  
Oak Ridge, TN 37831-0062  
phone: 865.576.8401  
fax: 865.576.5728  
email: <mailto:reports@adonis.osti.gov>

Available for sale to the public, in paper, from:

U.S. Department of Commerce  
National Technical Information Service  
5285 Port Royal Road  
Springfield, VA 22161  
phone: 800.553.6847  
fax: 703.605.6900  
email: [orders@ntis.fedworld.gov](mailto:orders@ntis.fedworld.gov)  
online ordering: <http://www.ntis.gov/ordering.htm>

Printed on paper containing at least 50% wastepaper, including 20% postconsumer waste

# WESTERN WIND AND SOLAR INTEGRATION STUDY: EXECUTIVE SUMMARY

May 2010

Prepared for NREL by GE Energy

1 River Road

Schenectady, New York 12345

Technical Monitor: Debra Lew

Prepared under Subcontract No. AAM-8-77557-01

Subcontract Report

NREL/SR-550-47781

National Renewable Energy Laboratory

1617 Cole Boulevard, Golden, Colorado 80401

303-275-3000 • [www.nrel.gov](http://www.nrel.gov)

NREL is a national laboratory of the U.S. Department of Energy

Office of Energy Efficiency and Renewable Energy

Operated by the Alliance for Sustainable Energy, LLC

Contract No. DE-AC36-08GO28308

Cover photos (from left to right): PIX # 15996, 08604, 10927 and 14898

---

# ACKNOWLEDGMENTS

The National Renewable Energy Laboratory (NREL) thanks the U.S. Department of Energy (DOE) for sponsoring the Western Wind and Solar Integration Study. Contributors include:

## PROJECT MANAGERS

Debra Lew	NREL
Richard Piwko	GE Energy

## STUDY TEAM

<b>GE</b>	Nicholas Miller, Kara Clark, Gary Jordan, Lavelle Freeman, Zhi Gao, Shakeer Meeran, Ekrem Gursoy, Miaolei Shao, Ryan Konopinski, Amanvir Chahal, Glenn Haringa, David Burnham, Kristen Bleyman
<b>NREL</b>	Michael Milligan, Brian Parsons, Yih-Huei Wan, Erik Ela, Donna Heimiller, George Scott, Kirsten Orwig, Ray George, Nate Blair, Mark Mehos, Craig Turchi, Paul Denholm, Marc Schwartz, Dennis Elliott, Steve Haymes, Dave Corbus, Tony Markel
<b>3TIER Group</b>	Cameron Potter, Bart Nijssen
<b>Exeter Associates</b>	Kevin Porter, Sari Fink
<b>Northern Arizona University</b>	Tom Acker, Karin Wadsack, Carson Pete, Jason Kemper and Mark Bielecki
<b>State University of New York at Albany and Clean Power Research</b>	Richard Perez, Tom Hoff

## WESTCONNECT

Charlie Reinhold

## TECHNICAL REVIEW COMMITTEE

<b>Arizona Public Service</b>	Ron Flood
<b>El Paso Electric</b>	Dennis Malone
<b>NV Energy</b>	Vladimir Chadliev
<b>Public Service of New Mexico</b>	Jeff Mechenbier, Tom Duane
<b>Salt River Project</b>	Rob Kondziolka, Maria Denton
<b>Tri-State Generation and Transmission</b>	Mark Graham, Eric Williams
<b>Tucson Electric Power</b>	Gary Trent, Tom Hansen
<b>Western Area Power Administration</b>	Bob Easton, Joe Liberatore
<b>Xcel Energy</b>	Steve Beuning, Keith Parks, Tom Ferguson, Brett Oakleaf
<b>American Wind Energy Association</b>	Ron Lehr
<b>Consultant</b>	Brendan Kirby
<b>Enernex Corporation</b>	Bob Zavadil
<b>Lawrence Berkeley National Laboratory</b>	Andrew Mills
<b>Renewable Energy Consulting</b>	Ed DeMeo
<b>Sandia National Laboratory</b>	Abraham Ellis
<b>University College Dublin</b>	Mark O'Malley
<b>U.S. Department of Energy</b>	Charlton Clark and Larry Mansueti
<b>Utility Wind Integration Group</b>	Charlie Smith
<b>Western Electricity Coordinating Council</b>	Bradley Nickell
<b>Western Interstate Energy Board</b>	Doug Larson, Tom Carr
<b>WindLogics</b>	Mark Ahlstrom

Finally, we thank Bruce Green (NREL) and Mark Schroder (Purple Sage Design) for designing this Executive Summary and the full report.


---

# INTRODUCTION

The focus of the Western Wind and Solar Integration Study (WWSIS) is to investigate the operational impact of up to 35% energy penetration of wind, photovoltaics (PVs), and concentrating solar power (CSP) on the power system operated by the WestConnect group of utilities in Arizona, Colorado, Nevada, New Mexico, and Wyoming<sup>1</sup>. WWSIS was conducted over two and a half years by a team of researchers in wind power, solar power, and utility operations, with oversight from technical experts in these fields. This report discusses the development of data inputs, the design of scenarios to address key issues, and the analysis and sensitivity studies that were conducted to answer questions about the integration of wind and solar power on the grid.

## WESTCONNECT

WestConnect is a group of transmission providers that are working collaboratively on initiatives to improve wholesale electricity markets in the West. Participants include Arizona Public Service, El Paso Electric Co., NV Energy, Public Service of New Mexico, Salt River Project, Tri-State Generation and Transmission Cooperative, Tucson Electric Power, Western Area Power Administration, and Xcel Energy.



The technical analysis performed in this study shows that it is operationally feasible for WestConnect to accommodate 30% wind and 5% solar energy penetration, assuming the following changes to current practice could be made over time:

- Substantially increase balancing area cooperation or consolidation, real or virtual;
  - Increase the use of sub-hourly scheduling for generation and interchanges;
  - Increase utilization of transmission;
  - Enable coordinated commitment and economic dispatch of generation over wider regions;
  - Incorporate state-of-the-art wind and solar forecasts in unit commitment and grid operations;
- Increase the flexibility of dispatchable generation where appropriate (e.g., reduce minimum generation levels, increase ramp rates, reduce start/stop costs or minimum down time);
  - Commit additional operating reserves as appropriate;
  - Build transmission as appropriate to accommodate renewable energy expansion;
  - Target new or existing demand response programs (load participation) to accommodate increased variability and uncertainty;
  - Require wind plants to provide down reserves.

In addition, suggestions for follow-on work to further explore these and additional mitigation options are listed in the Conclusions and Next Steps section.

<sup>1</sup> WestConnect also includes utilities in California, but these were not included in WWSIS because California had already completed a renewable energy integration study for the state.

## BACKGROUND

WWSIS and its sister study, the Eastern Wind Integration and Transmission Study (EWITS), follow the U.S. Department of Energy's (DOE) 20% Wind Energy by 2030 Study that considered the benefits, costs, and challenges associated with sourcing 20% of the nation's energy from wind power by 2030 [1, 2]. The study found that while proactive measures were required, no insurmountable barriers to reaching 20% wind were identified. Thus, DOE and the National Renewable Energy Laboratory (NREL) embarked upon WWSIS and EWITS to examine, in much greater depth, whether there were technical or physical barriers in operating the grid with 20% wind. Solar power was included in WWSIS due to the significant solar resources and solar development in the West.

### BALANCING AREAS

Balancing areas are responsible for balancing load and generation within a defined area and maintaining scheduled interchanges with other balancing areas.

Four of the five states in WestConnect have Renewables Portfolio Standards (RPS) that require 15-30% of annual electricity sales to come from renewable sources by 2020-2025. Additionally, WWSIS models the entire western interconnection, examining the operating impact of up to 23% penetration of wind and solar in the rest of the Western Electricity Coordinating Council (WECC). Most of the states in WECC have similar RPS requirements and renewable energy growth in the region has been significant.

The study was designed to answer questions that utilities, Public Utility Commissions, developers, and regional planning organizations had about renewable energy use in the West:

- What is the operating impact of up to 35% renewable energy penetration and how can this be accommodated?
- How does geographic diversity help to mitigate variability?
- How do local resources compare to remote, higher quality resources delivered by long distance transmission?
- Can balancing area cooperation mitigate variability?
- How should reserve requirements be modified to account for the variability in wind and solar?
- What is the benefit of integrating wind and solar forecasting into grid operations?
- How can hydro generation help with integration of renewables?

WWSIS and its sister study EWITS build upon a large body of work on wind integration [3-9]. Previous studies examined specific utilities or states, looking at the impact of wind on operations in the regulation (seconds to minutes), load following (minutes to hours), and unit commitment (hours to days) time frames. In these studies, hypothetical wind and transmission build-outs were typically added to the existing system, which was simulated or statistically analyzed over these time



frames. These studies generally consider the impact of the variability of wind (due to varying weather) and the uncertainty of wind (due to our inability to perfectly forecast the weather). Even if the weather and the wind could be perfectly forecast,

## **STUDY ASSUMPTIONS**

### **SCENARIO DEVELOPMENT:**

- Specific energy targets for each of three technologies: wind, PV, and CSP were fixed. For example, wind sites could not be traded out for CSP sites.
- A number of capital cost assumptions in 2008 dollars were used in determining the different geographic scenarios: wind at \$2000/kW, PV at \$4000/kW, CSP with thermal storage at \$4000/kW, transmission at \$1600/MW-mile, and transmission losses at 1% per 100 miles. No tax credits are assumed or included.
- The geographic scenarios considered different interstate transmission build-outs and included these costs in the scenarios. Incremental intra-state transmission build-outs were not specified in this analysis. Existing transmission capacity is assumed to be unavailable for new renewable energy generation only for the scenario development process.
- New transmission was undersized: 0.7 MW of new transmission was added for each 1.0 MW of remote generation.

### **PRODUCTION SIMULATION ANALYSIS:**

- All study results are in 2017 nominal dollars with 2% escalation per year.
- \$2/MBTU coal; \$9.50/MBTU natural gas.
- Carbon dioxide costs were assumed to be \$30/metric ton of CO<sub>2</sub>.
- Except in cases where specified, extensive balancing area cooperation is assumed (see box on page 19).
- The production simulation analysis assumes that all units are economically committed and dispatched while respecting existing and new transmission limits and generator cycling capabilities and minimum turndowns.
- Existing available transmission capacity is accessible to renewable generation.
- Generation equivalent to 6% of load is held as contingency reserves – half is spinning and half is non-spinning.
- The balance of generation was not optimized for renewables. Rather, a business-as-usual capacity expansion met projected load growth in 2017. Renewable energy capacity was added to this mix, so the system analyzed is overbuilt by the amount of capacity value of the renewable plants.
- Increased O&M of conventional generators due to increased ramping and cycling was not included due to lack of data.
- Renewable energy plant O&M costs are not included. Wind and solar are considered price-takers.
- The hydro modeling did not reflect the specific climatic patterns of 2004, 2005, and 2006, but rather a 10-year long term average flow per month.
- The sub-hourly modeling assumes a 5-minute economic dispatch.

grid operators would still have to accommodate wind's variability. It is important to note that operators already manage variability and uncertainty in the load; wind and solar add to that variability and uncertainty.

WWSIS was funded by DOE and was managed by NREL. The main partner in this study was WestConnect. The project team included 3TIER Group (wind power dataset, and wind and solar forecasts), State University of New York at Albany/Clean Power Research (solar radiation dataset), Exeter Associates (data collection), Northern Arizona University (wind validation and hydro), NREL (wind validation, and PV and CSP power datasets), and GE (scenarios, and main technical/economic analysis). A Technical Review Committee (TRC), composed of members of WestConnect utilities, western utility organizations, and industry and technical experts, met eight times to review technical results and progress. A broader stakeholder group, open to the public, met five times to ensure study direction and results were relevant to western grid issues. Interim and final results of this study have been vetted in approximately 30 public forums.

The study examined grid operation for the year 2017. That is, system loads and generation expansion were projected to represent year 2017. While 35% renewable energy penetration was not expected by 2017, this year was selected in order to start with a realistic model of the transmission grid. The study examined inter-annual operability by modeling operations for year 2017 three times, using historical load and weather patterns from years 2004, 2005, and 2006.

## WHAT THIS STUDY DOES AND DOES NOT COVER

While this study undertakes detailed analysis and modeling of the power system, it was meant to be a complement to other in-depth studies:

- WWSIS is an operations study, not a transmission planning study, although different scenarios model different interstate transmission expansion options.
- WWSIS is not a cost-benefit analysis, even though wind and solar capital costs were incorporated in scenario development. Rather WWSIS focuses on the variable operational costs and savings due to fuel and emissions.
- WWSIS is not a reliability study, although analysis of the capacity value of wind and solar was conducted to assess their contributions to resource adequacy. A full complement of planning and operational electrical studies would be required to more accurately understand and identify system impacts.
- WWSIS does not address dynamic stability issues.
- WWSIS does not attempt to optimize the balance between wind and solar resources. Wind and solar levels were fixed independently.

In 2017, it is anticipated that WestConnect and WECC will operate differently from current practice. WWSIS assumed the following changes from current operational practice:



- Production simulations of WECC grid operations assume least-cost economic dispatch in which all generation resources are shared equally and not committed to specific loads. Except for California and Alberta, WECC currently utilizes a bilateral contract market with long and short-term contracts in which resources are contracted out to meet specific loads.
- Other than California and Alberta, WECC currently operates as 37 separate balancing areas that utilize these bilateral contracts to balance their areas. Except where specified, this study assumes five regional balancing areas in WECC (Arizona-New Mexico, Rocky Mountain, Pacific Northwest, Canada and California). WWSIS does not consider any power purchase agreements, including those for renewables<sup>2</sup>.
- Except for California and Alberta, transmission in WECC is primarily contractually obligated and utilized. Existing available transmission capacity may be contractually obligated and not accessible to other generation. This study assumes that existing available transmission capacity is accessible to other generation on a short-term, non-firm basis.
- Pricing developed by production cost modeling can vary widely from bilateral contract prices, and was not aligned or calibrated with current bilateral contract prices. The incremental operations and maintenance (O&M) costs in the report do not necessarily replicate escalated current costs in the Western Interconnection.

In addition to these caveats, there are reasons that the study results tend toward the conservative:

- WWSIS did not model a more flexible non-renewable balance of generation than what exists and is planned in WECC today. If 20-35% variable generation were to be planned in WECC, more flexible generation would be likely planned as well, reducing the challenge that wind and solar place on operation in this study.
- This study modeled the grid for the year 2017. If WWSIS were conducted for a later year when 35% renewables would be more plausible, the power system would likely have a larger load, more flexible balance of generation, and more transmission, all of which would help to accommodate the renewables.
- The wind dataset used was conservative in terms of overestimating the actual variability found in measured wind plant output.
- The base assumption of \$9.50/MBTU for gas means that gas is displaced, which leaves coal (which in the West, is less flexible than gas) to accommodate the variability of the renewables.

---

<sup>2</sup> Thus, throughout this work, *costs* specifically and solely refer only to variable costs, i.e., fuel plus O&M plus carbon tax, that are incurred during operation. Prices paid to individual generators are not reported.

# SCENARIOS

## WIND, SOLAR, AND LOAD DATA

About 75 GW of wind generation sites were required for the study scenarios. Because there are not adequate measurements of wind speed or wind power to model this amount of wind generation, 3TIER Group employed a mesoscale Numerical Weather Prediction (NWP) Model to essentially recreate the weather in a 3-dimensional physical representation of the atmosphere in the western U.S. for the years 2004-2006. They then sampled this model at a 2-km, 10-minute resolution and modeled wind plants throughout this region, based on a Vestas V90 3-MW turbine. 3TIER Group also developed day-ahead wind forecasts for each hour. Over 960 GW of wind sites were modeled. The wind dataset is publicly available [10, 11].

Similarly, a lack of solar irradiance or power measurements led to the use of a satellite cloud cover model to simulate the United States at a 10-km, hourly resolution [12]. Day-ahead hourly solar forecasts were also developed [10]. PV was modeled in 100-MW blocks as distributed generation on rooftops because modeling information for large, central station PV plants was not available at the time of the study. Over 15 GW of PV plants were included in the dataset. Ten-minute variability was subsequently added to the aggregate hourly outputs to create the 10-minute PV data.

CSP was modeled as 100-MW blocks of parabolic trough plants with six hours of thermal storage. Over 200 GW of CSP plants were modeled in the dataset. Because the CSP with thermal storage produces a very stable output, the 10-minute dataset was created simply by interpolating the hourly dataset.

Hourly load-profile data for all operating areas in WECC were obtained from a Ventyx database, and 10-minute load data were derived by interpolating the hourly data.

## SCENARIO DESCRIPTION

The WWSIS used a multidimensional scenario-based study approach to evaluate:

- Different levels of energy penetration for wind and solar generation, ranging from 11% to 35%;
- Different geographic locations for the wind and solar resources;
- A wide array of sensitivities to assess issues such as fuel costs, operating reserve levels, unit commitment strategies, storage alternatives, balancing area size, etc.

Table 1 shows the four levels of wind and solar energy penetration assumed for the study scenarios. The **Preselected case** includes that wind and solar capacity which was installed by the end of 2008. The **10% case** includes 10% wind energy (relative to total annual load energy) and 1% solar energy (solar consisted of 70% CSP and 30% PV) in the study footprint, as well as the rest of WECC. The **20% case** includes 20% wind energy and 3% solar energy in the study footprint, with 10% wind energy and 1% solar energy in the rest of WECC. The **20/20% case** includes 20% wind energy and 3% solar energy in the study footprint, as well as the rest of WECC. The **30% case** included 30% wind energy and 5% solar energy in the study footprint, with 20% wind energy and 3% solar energy in the rest of WECC.

TABLE 1 – WIND AND SOLAR ENERGY PENETRATIONS FOR WWSIS CASES WITH NAMING CONVENTION IN BLUE.					
CASE NAME	IN FOOTPRINT			REST OF WECC	
NAME	WIND + SOLAR	WIND	SOLAR	WIND	SOLAR
<b>PRE-SELECTED CASE</b>	3%*	3%	*	2%	*
<b>10% CASE</b>	11%	10%	1%	10%	1%
<b>20% CASE</b>	23%	20%	3%	10%	1%
<b>20/20% CASE</b>	23%	20%	3%	20%	3%
<b>30% CASE</b>	35%	30%	5%	20%	3%

\* *Existing solar embedded in load*

Three geographic scenarios were developed to examine the tradeoff between: 1) local resources that are closer to load, but have lower capacity factors and 2) remote resources that have higher capacity factors, but require long distance transmission to access loads. An algorithm was developed to select sites based on energy value, capacity value, and geographic diversity according to criteria developed for each scenario. Figure 1 shows maps of the study scenarios for the 30% case. Total nameplate ratings of wind generation for each state are shown in blue; solar MW ratings are shown in red. New transmission lines to increase interstate transfer capability are shown in black. Significant intra-state transmission also needs to be built to bring the renewable resources to the existing bulk transmission grid, but WWSIS did not examine intra-state transmission.




Figure 1 – Three geographic scenarios developed for siting of wind and solar plants in the 30% case, with appropriate interstate transmission included to bring resources to load.

**In Area Scenario:** Each state in the study footprint met its wind and solar energy targets using the best available wind and solar generation resources within its state boundary. No additional interstate transmission was added.

**Local Priority Scenario:** This scenario used the best wind and solar sites within the entire footprint, but included a 10% capital cost advantage to resources within each state. The result was a scenario that was about halfway between the In Area and Mega Project Scenarios. This scenario includes new interstate transmission, but not as much as the Mega Project Scenario.

**Mega Project Scenario:** The study footprint met its wind and solar energy targets by using the best available wind and solar resources within the study footprint. Given that many of the best wind resources are in Wyoming, this scenario includes a large penetration of wind generation in Wyoming (and other wind-rich areas), with new transmission lines to deliver the energy to load centers.

For all three of these scenarios, the rest-of-WECC scenario remains constant: each state in the rest of WECC meets its renewable energy target using the best available resources within the state boundary.

Table 2 shows a summary of the total wind and solar MW ratings by state for the three study scenarios. Table 3 summarizes the capital costs for the three study scenarios.

**TABLE 2 – SUMMARY OF AGGREGATED WIND AND SOLAR MW RATINGS BY STATE FOR WWSIS SCENARIOS**

IN AREA								
			10%	1%	20%	3%	30%	5%
AREA	LOAD MIN. (MW)	LOAD MAX. (MW)	WIND (MW)	SOLAR (MW)	WIND (MW)	SOLAR (MW)	WIND (MW)	SOLAR (MW)
ARIZONA	6,995	23,051	3,600	400	7,350	1,200	11,220	2,000
COLORADO EAST	4,493	11,589	2,040	300	3,780	800	5,640	1,400
COLORADO WEST	712	1,526	300	0	600	200	900	300
NEW MEXICO	2,571	5,320	1,080	200	1,920	400	2,790	700
NEVADA	3,863	12,584	2,340	200	4,680	700	7,050	1,100
WYOMING	2,369	4,016	930	100	1,620	100	2,340	300
<b>IN FOOTPRINT</b>	<b>21,249</b>	<b>58,087</b>	<b>10,290</b>	<b>1,200</b>	<b>19,950</b>	<b>3,400</b>	<b>29,940</b>	<b>5,800</b>

LOCAL PRIORITY								
			10%	1%	20%	3%	30%	5%
AREA	LOAD MIN. (MW)	LOAD MAX. (MW)	WIND (MW)	SOLAR (MW)	WIND (MW)	SOLAR (MW)	WIND (MW)	SOLAR (MW)
ARIZONA	6,995	23,051	2,850	400	5,2550	1,200	7,710	2,000
COLORADO EAST	4,493	11,589	2,190	300	3,870	800	4,650	1,400
COLORADO WEST	712	1,526	210	0	450	200	570	300
NEW MEXICO	2,571	5,320	1,350	200	2,100	400	2,970	700
NEVADA	3,863	12,584	1,350	200	2,490	700	3,450	1,100
WYOMING	2,369	4,016	1,650	100	4,020	100	7,410	300
<b>IN FOOTPRINT</b>	<b>21,249</b>	<b>58,087</b>	<b>9,600</b>	<b>1,200</b>	<b>18,180</b>	<b>3,400</b>	<b>26,760</b>	<b>5,800</b>

MEGA PROJECT								
			10%	1%	20%	3%	30%	5%
AREA	LOAD MIN. (MW)	LOAD MAX. (MW)	WIND (MW)	SOLAR (MW)	WIND (MW)	SOLAR (MW)	WIND (MW)	SOLAR (MW)
ARIZONA	6,995	23,051	810	400	1,260	1,200	1,890	2,600
COLORADO EAST	4,493	11,589	2,010	300	2,400	800	2,490	1,200
COLORADO WEST	712	1,526	60	0	90	200	90	200
NEW MEXICO	2,571	5,320	1,860	200	2,700	400	4,350	1,000
NEVADA	3,863	12,584	570	200	1,020	700	1,440	600
WYOMING	2,369	4,016	3,390	100	8,790	100	13,770	100
<b>IN FOOTPRINT</b>	<b>21,249</b>	<b>58,087</b>	<b>8,700</b>	<b>1,200</b>	<b>16,260</b>	<b>3,400</b>	<b>24,030</b>	<b>5,700</b>

			10%	1%	20%	3%	30%	5%
<b>OUT OF FOOT-PRINT</b>	<b>46,328</b>	<b>119,696</b>	<b>22,950</b>	<b>2,500</b>	<b>22,950</b>	<b>2,500</b>	<b>45,450</b>	<b>7,500</b>

**TABLE 3 – CAPITAL COSTS (IN US2008\$) FOR STUDY SCENARIOS WITH 30% WIND ENERGY AND 5% SOLAR ENERGY IN THE STUDY FOOTPRINT.**

SCENARIO	WIND (MW)	SOLAR (MW)	TRANSMISSION (GW-MI)	WIND (\$B)	SOLAR (\$B)	INTERSTATE TRANSMISSION (\$B)	TOTAL (\$B)
<b>IN-AREA</b>	29,940	5,800	0	59.9	23.2	0	83.1
<b>LOCAL PRIORITY</b>	26,760	5,800	2,100	53.5	23.2	3.4	80.1
<b>MEGA PROJECT</b>	24,030	5,700	6,900	48.1	22.8	11.0	81.9

*The rest of WECC includes 45,450 MW of wind (\$91 billion), 4000 MW of PV (\$16 billion), and 3500 MW of CSP (\$14 billion). Intrastate transmission is not included in any of these scenario costs.*

## **ANALYTICAL METHODS**

Four primary analytical methods were used to evaluate the performance of the system with high penetrations of wind and solar generation: statistical analysis, hourly production simulation analysis, sub-hourly analysis using minute-to-minute simulations, and resource adequacy analysis.

Statistical analysis was used to quantify variability due to system load, as well as wind and solar generation over multiple time frames (annual, seasonal, daily, hourly, and 10-minute). The statistical analysis quantified the grid variability due to load alone over several time scales, using the interpolated hourly load data. The changes in grid variability due to wind and solar generation were also quantified for each scenario at various levels of aggregation. The statistical analysis also examined the forecast accuracy for wind generation.

Production simulation analysis with GE's MAPS (Multi-Area Production Simulation) program was used to evaluate hour-by-hour grid operation of each scenario for 3 years with different wind, solar, and load profiles. WECC was represented as a set of 106 zones, each with its own load profile, portfolio of generating plants, and transmission capacity with neighboring areas. The zones were grouped into 20 transmission areas. The production simulation results quantified numerous impacts of additional renewable generation on grid operation including:

- Amount of flexible generation on-line during a given hour, including its available ramp-up and ramp-down capability;
- Effects of day-ahead wind forecast alternatives in unit commitment;
- Changes in conventional generation dispatch;
- Changes in emissions ( $\text{NO}_x$ ,  $\text{SO}_x$ , and  $\text{CO}_2$ ) due to renewable generation;
- Changes in grid operation costs, revenues, and net cost of energy;
- Changes in transmission path loadings;
- Changes in use of hydro resources;
- Changes in use and economic value of energy storage.

Minute-to-minute simulation analysis was used to quantify grid performance trends and to investigate potential mitigation measures during challenging situations, such as large 1-hour, 3-hour and 6-hour changes in net load, high levels of wind and solar penetration, low load levels with minimal maneuverable generation on-line, and/or high wind forecast errors. Minute-to-minute analysis simulated the operation of dispatchable generation resources as well as variable wind and solar generation in the study footprint using one-minute time steps, while enforcing constraints related to unit maximum, minimum, ramp rate, inertia flow schedule, and regional Automatic Generator Control (AGC) functions.



Resource adequacy analysis involved loss-of-load-expectation (LOLE) calculations for the study footprint using the Multi-Area Reliability Simulation program, MARS. The analysis quantified the impact of wind and solar generation on overall reliability measures, as well as the capacity values of the wind and solar generation resources.

Impacts on system-level operating reserves were also analyzed using a variety of techniques including statistics, production simulation, and minute-to-minute simulation. This analysis quantified the effects of variability and uncertainty, and related that information to the system's increased need for operating reserves to maintain reliability and security.

The results from these analytical methods complemented each other, and provided a basis for developing observations, conclusions, and recommendations with respect to the successful integration of wind and solar generation into the WestConnect grid.

## OPERATIONS WITH 35% RENEWABLES

The power system is designed to handle variability in load. With wind and solar, the power system is called on to handle variability in the net load (load minus wind minus solar), which can be considerable during certain periods of the year. Figure 2 shows the load, wind, solar, and net load profiles for the 30% case during two



selected weeks in July and April.

In the July week, (top plot), the net load (blue line at bottom edge) is not significantly impacted by wind and solar variation. However, in the April week (bottom plot), the high, variable wind output dominates the net load, especially during low load

**WWSIS finds that 35% renewable energy penetration is operationally feasible provided significant changes to current operating practice are made, including balancing area cooperation and sub-hourly generation and interchange schedule.**

hours, leading to several hours of negative net load during the week. This week in April was the worst week in terms of operational challenges of the three years.

As an example of how the system would operate under less severe operating conditions, Figure 3 shows the generation dispatch for the same July week shown in Figure 2 for the In-Area Scenario. The left figure is without renewable generation and the right is the 30% case. Although the wind and solar generation are definitely noticeable, they primarily displace combined cycle and gas turbine generation, and have minimal impact on the steam coal units.




**Figure 2 – With 35% renewables, system operators must now balance generation against the net load (blue line). This may be straightforward (top, July) or challenging (bottom, April).**

Figure 4 shows similar information for the April week shown in Figure 2. Here, operating the system with renewable generation is much more challenging. The combined cycle generation has been almost completely displaced, as have significant levels of coal generation. Nonetheless, the system can operate with balancing area cooperation. Without balancing area cooperation, operations during this week would be extremely difficult, if not impossible, for individual balancing areas.


How much renewable generation can the system handle? All three geographic scenarios show significant benefits with no negative effects in the 10% case. No significant adverse impacts were observed up to the 20% case in WestConnect, given balancing area cooperation. Increased renewable generation in the rest of WECC

<sup>3</sup> WECC requires 6% of load to be held as contingency reserves, half of which is required to be spinning (i.e., synchronized to the grid) reserves.

(20/20% case) led to increased stress on system operations within WestConnect, with some instances of insufficient reserves<sup>3</sup> due to wind and solar forecast error. These can be addressed, but the system has to work harder to absorb the renewables. Operations become more challenging for the 30% case in which load and contingency reserves are met only if the wind/solar forecasts are perfect. With imperfect forecasts, load is served but there are contingency reserve shortfalls. Extra spinning reserves can be held every hour of the year to meet those contingency reserve requirements, but the cost to hold enough to eliminate all contingency reserve shortfalls is very high. A more cost-effective alternative is to establish a demand response program or develop strategies to more accurately predict when these shortfalls occur and schedule more reserves during those hours or add additional quick start generation where needed. In the 20% and 30% cases, decreased flexibility of either the coal or hydro facilities made operation more difficult and increased the costs of integrating renewable generation.



*Figure 3 – 35% renewables have a minor impact on other generators during an easy week in July, 2006. WestConnect dispatch - no renewables (left) and 30% case (right)*




*Figure 4 – 35% renewables have a significant impact on other generation during the hardest week of the three years (mid-April 2006). WestConnect dispatch - no renewables (left) and 30% case (right)*

## BENEFITS OF 35% RENEWABLES


Wind and solar generation primarily displace gas resources nearly all hours of the year, given the fuel prices and carbon tax assumed for this study (\$2/MBTU coal, \$9.50/MBTU gas, \$30/ton CO<sub>2</sub>). Since gas-fired generation is typically more flexible than coal generation, the natural economic displacement of gas generation by wind and solar generation makes the balance of dispatchable generation on-line less flexible (fewer gas units, more coal units). Across WECC, operating costs drop by \$20 billion/yr (\$17 billion/yr in 2009\$) from approx \$50 billion/yr (\$43 billion/yr in 2009\$), resulting in a 40% savings due to offset fuel and emissions. This savings does not account for the capital or operating costs associated with the wind, solar, or transmission facilities, nor does it include any of the costs that would be required to implement the operational reforms needed to accommodate the renewables including balancing area cooperation or sub-hourly scheduling, although presumably some of this savings would be used to recover the capital costs of building this scenario, including payments to wind and solar generators. Figure 5 (left plot) shows the overall impact on the operating costs of WECC for the various penetration levels under the In-Area Scenario with a state-of-the-art (SOA) forecast. The 30% case shows WECC operating cost savings of \$20 billion/yr (\$17 billion/yr in 2009\$) due to the wind and solar generation resources. Figure 5 (right plot) divides these values by the corresponding amount of renewable energy provided. In the 30% case, this equates to \$80/MWh (\$60/MWh in 2009\$) of wind and solar energy produced. Lower penetrations of renewables showed values up to \$88/MWh (\$75/MWh in 2009\$) of renewable energy produced (see Section 6.2). These operating cost savings would be applied toward the costs of the wind and solar energy, and depending on the magnitude of these costs, may or may not be sufficient to cover them.

**The 30% case reduced fuel and emissions costs by 40% and CO<sub>2</sub> emissions by 25-45% across WECC.**



**Figure 5 – WECC saves \$20 billion (\$17 billion in 2009\$), or 40%, in annual operating costs in the 30% case, which is equivalent to \$80 (\$60 in 2009\$) per MWh of wind and solar energy produced. Note: Chart on right starts at \$70/MWh.**

At a \$3.50/MBTU gas price, wind and solar primarily displace coal generation, leaving the more flexible gas generation resources to operate together with the wind and solar generation. With lower gas price assumptions, operating costs are reduced by about 40%, to \$46/MWh (\$39/MWh in 2009\$), but emissions reductions are higher.



*Figure 6 – Assuming \$9.50/MBTU gas, renewable energy displaces gas (orange). At lower gas prices (\$3.50/MBTU), coal is displaced instead, resulting in greater emissions reductions (blue).*

Figure 6 shows the total WECC reductions in emissions for the 30% case. CO<sub>2</sub> emissions would be reduced by nearly 120 million tons/year, or approximately 25%, for the 30% case. SO<sub>x</sub> emissions would be reduced by approximately 45,000 tons/year (~5%) and NO<sub>x</sub> would be reduced nearly 100,000 tons/year (~15%) (see Section 6.2.1). At a \$3.50/MBTU gas price, CO<sub>2</sub> emissions are reduced by nearly 200 million tons/year (45%), and NO<sub>x</sub> and SO<sub>x</sub> by 300,000 tons/year (50%) and 220,000 tons/year (30%), respectively.

## BALANCING AREA COOPERATION IS ESSENTIAL


There are three key benefits of balancing area cooperation: 1) aggregating diverse renewable resources over larger geographic areas reduces the overall variability of the renewables, 2) aggregating the load reduces the overall variability of the load, and

**The technical analysis performed in this study shows that it is feasible for the WestConnect region to accommodate 30% wind and 5% solar energy penetration, but it would require extensive balancing area cooperation or consolidation, real or virtual.**


3) aggregating the non-renewable balance of generation provides access to more balancing (and more flexible) resources. Figure 7 shows the reduced-variability benefit arising from aggregating smaller transmission areas into the WestConnect footprint. Variability for

small areas such as Colorado-West (CO-W) or Wyoming (WY) increases significantly as renewable penetrations increase from the 10% to the 30% case. This effect becomes even more extreme at a more granular level, e.g., for specific balancing areas within

a state (see Section 7.1). However, when the balancing areas across WestConnect are aggregated, there is only a slight increase in variability with increased renewables penetrations, and even a slight decrease in variability WECC-wide.



*Figure 7 – The variability of the net load increases with increasing renewable energy penetration. Aggregating several transmission areas over the WestConnect footprint results in reduced variability. Percent increase in the standard deviation of the hourly changes of the net load in all areas for In-Area Scenario.*



*Figure 8 – WECC can save \$2 billion (\$1.7 billion in 2009\$) by holding spinning reserves as 5 large regions (right) rather than many smaller zones (left).*

From an operational perspective, balancing area cooperation can lead to cost savings because reserves can be pooled. A sensitivity analysis was performed, running WECC as 106 zones (which are roughly equivalent to balancing areas in the southwest, but there are multiple zones per balancing area in the northwest) versus 5 large regions.



**Balancing area (BA)** cooperation can take many forms and means different things to different people. In WWSIS, cooperation is modeled by assuming:

- All generation resources, across all BAs, are committed from a common regional generation stack on a least-cost basis
- Generation commitments assume physical transmission capability is available for import or export of power transfers between BAs
- All generation dispatches are made on a least-marginal-cost basis
- All regional reserves are shared across BAs; i.e., the most economic resources for reserves are used
- Day-ahead generation dispatch and inter-area transmission schedules can be modified during operation to enable sharing of load-following, regulation, and reserves

Mechanisms to enable these aspects of cooperation are numerous, and include facets currently used or proposed in WECC such as the ACE diversity interchange (ADI), dynamic scheduling, an energy imbalance service, and other means of consolidating BA services. Many technical and institutional barriers will need to be addressed to achieve the level of cooperation of the work presented here.

hourly scheduling has a greater impact on the regulation requirements than does the wind and solar variability.

Sub-hourly scheduling can substantially reduce the maneuvering duty imposed on the units providing load following. In the 30% case, the fast maneuvering of combined

**Sub-hourly scheduling will be required to successfully operate the system at high penetration levels without significantly increased regulating reserves.**

cycle plants with sub-hourly scheduling is about half of that with hourly scheduling, as shown in Figure 9. Sub-hourly scheduling in the 30% case is roughly equivalent to the 20/20% case with hourly scheduling. Improvements in plant efficiency and reductions in O&M costs, while difficult to quantify, are expected from this smoother operation.

Figure 8 shows the \$2 billion (\$1.7 billion in 2009\$) savings in WECC operating costs in the 10% case. There are significant savings from sharing reserves over larger regions, irrespective of the renewables on the system.

## **SUB-HOURLY SCHEDULING IS CRITICAL**

The current practice of scheduling both the generation and interstate exchange only once each hour has a significant impact on the regulation duty. At high penetration levels, such hourly schedule changes can use most, if not all, of the available regulation capability to compensate for Area Control Error (ACE) excursions during large scheduled ramps. This can leave no regulation capability for the sub-hourly variability.

The minute-to-minute simulations showed that the current practice of





Figure 9 – Fast maneuvering duty of combined cycle units can be cut in half by moving from hourly to sub-hourly scheduling.

## UNCERTAINTY (FORECAST ERROR) RESULTS IN THE BIGGEST IMPACT ON THE SYSTEM

Integrating day-ahead wind and solar forecasts into the unit commitment process is essential to help mitigate the uncertainty of wind and solar generation. Even though SOA wind and solar forecasts are imperfect and sometimes result in reserve shortfalls due to missed forecasts, it is still beneficial to incorporate them into the day-ahead scheduling process, because this will reduce the amount of shortfalls. Over the course of the year, use of these forecasts reduces WECC operating costs by up to 14%, or \$5 billion/yr (\$4 billion/yr in 2009\$), which is \$12-20/MWh (\$10-17/MWh in 2009\$) of wind and solar generation. The left side of Figure 10 shows the WECC-wide operating cost savings for using SOA forecasts compared to ignoring wind in the day-ahead commitment. The right side shows the incremental cost savings for perfect wind and solar day-ahead forecasts, which would reduce WECC operating costs by another \$500 million/yr (\$425 million/yr in 2009\$) in the 30% case (see Section 6.2.1), or \$1-2/MWh (\$0.9-1.7/MWh in 2009\$) of wind and solar generation.

**Using state-of-the-art wind and solar forecasts in day-ahead unit commitment is essential and would reduce annual WECC operating costs by up to \$5 billion (\$4 billion in 2009\$) or \$12-20/MWh (\$10-17/MWh in 2009\$) of renewable energy, compared to ignoring renewables in the unit commitment process. Perfect forecasts would reduce annual costs by another \$500 million (\$425 million in 2009\$) or \$1-2/MWh (\$0.9-1.7/MWh in 2009\$) of renewable energy.**




*Figure 10 – WECC saves \$1-5 billion (\$1-4 billion in 2009\$) in annual operating costs just by using a SOA day-ahead forecast in the unit commitment process (left). Incremental savings for perfect forecasts are an order of magnitude less (right).*

### THE IMPACTS OF EXTREME FORECAST ERRORS ON CONTINGENCY RESERVE SHORTFALLS

While on average, wind forecast error is not very large (8% mean absolute error across WestConnect), there are hours when wind forecast errors can be extreme, ranging up to over 11,000 MW of over- or under-forecast in WestConnect. Severe over-forecasts can result in contingency reserve shortfalls; severe under-forecasts can result in curtailment of wind.

Operating rules dictate that systems must carry contingency reserves to cover system events, such as tripping of a large generator. In WECC, the spinning portion of these contingency reserves is equivalent to 3% of the system load. Applying these WECC rules, severe over-forecasts can lead to under-commitment of generation units, which can result in contingency reserve shortfalls if insufficient quick-start capacity is available.

If the forecast is perfect, there are no contingency reserve shortfalls, even in the 30% case. With a SOA forecast, Figure 11 shows that these contingency reserve shortfalls become an issue in the 30% case. It should be noted, however, that even these shortfalls represent only a tiny percentage (~0.005%) of the total load energy.



**Figure 11 – Contingency reserve shortfalls start to become an issue in the 30% case. Increasing spinning reserve can reduce the shortfalls but even increasing spinning reserves by 25% of the day-ahead wind forecast does not completely eliminate reserve shortfalls. Hourly production simulation analysis shows spilled energy, or curtailment, on the left axis and contingency reserve shortfalls on the right axis for the In-Area Scenario with no wind/solar, the 10, 20, and 30% case for a SOA forecast. The five bars on the right show the effect of increasing spinning reserve by 5, 10, 15, 20, and 25% of the day-ahead wind forecast.**

Spinning reserves can be increased to cover these contingency reserve shortfalls, but at a cost. Figure 11 shows the impact of increasing spinning reserves by 5, 10, 15, 20 and 25% of the day-ahead wind forecast. However, each additional 5% increment of committed spinning reserve is increasingly expensive, as shown in Figure 12, and even with a 25% increase in committed spinning reserves, not all contingency reserve shortfalls are eliminated.

The average cost of increasing reserves is shown in Figure 12. Increasing the committed spinning reserve by 5% of the wind forecast increases WECC operating costs by over \$3,000 per MWh (\$2,550/MWh in 2009\$) of reduced reserve shortfall.

Expressed another way, it would be comparable to pay some of the load \$3,000/MWh (\$2,550/MWh in 2009\$) to drop off rather than increasing the spinning reserve by 5% of the forecast.

At the other extreme, if spinning reserve is increased by 25%, it would cost an average of roughly \$13,600/MWh (\$11,600/MWh in 2009\$) of reserve shortfall. The incremental reduction achieved by increasing the spinning reserve from 20% to 25% of the forecast would cost over \$100,000/MWh (\$85,000/MWh in 2009\$). It should

**It is more cost-effective to have demand response address the 89 hours of contingency reserve shortfalls rather than increase spin for 8760 hours of the year. Demand response can save up to \$600M/yr (\$510M/yr in 2009\$) in operating costs versus committing additional spinning reserves.**

be more economic to use load participation (i.e., demand response) than to increase the spinning reserves to achieve the same objectives. Using load participation instead of committing additional generation for operating reserves would save up to \$600 million (\$510 million in 2009\$) in operating costs per year (see Sections 5.4, 7.2, and 6.2.2).




Figure 12 – The cost of increasing spinning reserves increases with higher percentages of spin. The incremental cost increases sharply at higher percentages of spin, indicating that the cost of reducing those final reserve shortfalls is prohibitively high. The five bars show the effect of increasing spinning reserve by 5, 10, 15, 20, and 25% of the day-ahead wind forecast.




Figure 13 – A demand response program which requires load to participate in the 89 hours of the year that there are contingency reserve shortfalls is more cost-effective than increasing spin for each of the 8760 hours of the year. Hourly contingency reserve-shortfall duration curves for the In-Area 30% case with a SOA forecast with no additional spinning reserves, and then with spinning reserves increased by 5, 10, 15, 20, and 25% of the day-ahead wind forecast.

Instead of holding additional spinning reserve for each of the 8760 hours of the year, Figure 13 shows that a demand response program could address those 89 hours of the year when there is a contingency reserve shortfall and have a total participation of approximately 1300 MW of load. The contingency reserve shortfalls could also be met by a combination of increased spinning reserves and a smaller demand response program. An alternative to demand response or increased spinning reserve for every hour of the year could be dynamic allocation of spinning reserves based on better forecasting, improved reserve policies, and more accurate prediction of when shortfalls are likely to occur.

## HOW OFTEN IS WIND CURTAILED?

Uncertainty drives both curtailment and reserve shortfalls. With a perfect forecast, no wind or solar curtailment was necessary in any of the scenarios. Even in the few hours when the renewable generation exceeded the load in WestConnect, there was sufficient flexibility within WECC to absorb all of the generation. With a SOA forecast, no curtailment occurred up through the 20% case (see Figure 11). The hourly production simulations showed about 800 GWh of wind curtailment in the 30% case, representing less than 0.5% of the total wind energy production. In addition, the minute-to-minute analysis indicated that more wind curtailment may be required under some combinations of low load and high wind. Altogether, wind curtailment in the 30% case is estimated to be on the order of 1% or less of the total wind energy. Curtailment is also affected by flexibility of the balance of generation, e.g., raising the minimum operating point of the coal units to 70% increased the wind curtailment slightly (see Sections 6.2 and 6.4.4).


## THE EFFECT OF VARIABILITY – ARE ADDITIONAL RESERVES NECESSARY?

In addition to contingency reserves, utilities are required to hold variability or load following reserves to cover 10-minute load variability 95% of the time. Typically, utilities do not commit additional variability reserves because the existing dispatchable generating fleet can adequately cover this variability reserve requirement. With wind and solar, the net load variability increases and in the 30% case, the average variability reserve requirement doubles. However, when wind and solar are added to the system, thermal units are backed down because it is sometimes more economical to back down a unit rather than to decommit it.

This results in more up-reserves available than in the case when there is no wind and solar, as shown in Figure 14. Therefore, commitment of additional reserves is not needed to cover variability in the study footprint. Figure 14 shows a duration curve of the total amount of up-reserves in the committed generation after the contingency reserve requirement is subtracted out, showing that 95% of the time, there are adequate up-reserves in the 30% Local Priority case.

**While the need for variability reserves doubles in the 30% wind case, the backing down of conventional units results in more available up-reserves. Therefore, commitment of additional reserves is not needed to cover the increased variability.**





*Figure 14 – There are more up-reserves available in the 30% case than in the no wind/solar case because the additional renewable energy generation causes many conventional units to be backed down. Variability Up-Reserve Margin – Local Priority 30% vs. No Wind or Solar Case.*

Regulating reserves are a subset of the fast variability requirement, but are held separately from the 10-minute variability reserves. Regulating reserves are required to be automatically controlled through AGC. While WWSIS did not evaluate which units were on AGC, the minute-to-minute analysis showed that sufficient regulating reserve capability was available in WestConnect.

Down reserves can be handled through wind curtailment when other resources are depleted. A wind plant can reduce its output very quickly in response to a command

**Wind plants can be curtailed to provide down regulating reserves instead of moving regulating units. Even so, curtailment is estimated to be on the order of 1% or less of total wind energy in the 30% case.**

signal. Simulations in this study show that down reserves can be implemented through command signals (ACE signals) from system operators. With extensive balancing area cooperation, WestConnect can accommodate large amounts of

renewables, and curtailment of wind is expected to be on the order of 1% or less in the 30% case.

## WHAT IS THE EFFECT OF DIFFERENT TRANSMISSION AND GEOGRAPHIC SCENARIOS?

The In-Area, Local Priority, and Mega Project Scenarios showed similar overall performance and economics for a given penetration level. This indicates that the specific locations of the wind and solar resources within WestConnect are not critical, provided there is adequate transmission infrastructure and access, and balancing area cooperation (see Sections 4.2.3, 5.5, 6.4.1, 6.4.6, 7.3.1). The assumption that existing transmission capacity can be fully utilized is an important change from present practice underpinning these results.

Figure 15 shows the study footprint’s monthly wind and solar energy as a percentage of load energy for all three scenarios in the 30% case in 2006.




Figure 15 – The month-to-month variation of wind and solar penetration is greater than the scenario-to-scenario variation.

The plots clearly illustrate that 1) despite the month-to-month variation, there is relatively little difference among scenarios at the footprint resolution and 2) there is significant month-to-month variation in energy across the year. In fact, there is more interannual variation in each month’s penetration levels than there is inter-scenario variation (see Section 4.1.1-4.1.2)

The total WECC operating cost savings per MWh of renewable energy for the different scenarios was also very similar across the three geographic scenarios, with only a slight increase in value as the wind plant locations were shifted to the higher capacity factor sites in the Local Priority and Mega Project Scenarios (see Section 6.4.1)


## IS NEW LONG DISTANCE TRANSMISSION NEEDED?

Sufficient intra-area transmission within each state or transmission area for renewable energy generation to access load or bulk transmission is needed. However, the In-Area Scenario, which included no additional long distance, interstate transmission, worked just as well operationally as the other scenarios. A sensitivity case examined the impact of the interstate transmission build-outs in the Local Priority and Mega Project Scenarios (which required \$3.4 and \$11 billion dollars, in 2008\$, of interstate transmission respectively). Figure 16 shows the increased annual operating

**Up to 20% renewable penetration could be achieved with little or no new long distance, interstate transmission additions, assuming full utilization of existing transmission capacity.**

costs for the cases in which the new interstate transmission build-outs associated with the Local Priority and Mega Project Scenarios were eliminated. These increased costs are modest because renewables have displaced other generation and freed up transmission capacity. Assuming renewables have full access to this newly opened up capacity, there is less need for new transmission.

Assuming a 15% fixed charge rate, the 30% Local Priority Scenario would justify about \$2 billion (\$1.7 billion in 2009\$) in transmission investments and the Mega Project Scenario would justify a little over \$10 billion (\$8.5 billion in 2009\$). This rough estimate suggests that the full-scale transmission build-out might be justified in the 30% Mega Project Scenario, but not at lower penetrations in the Mega Project or for any of the other scenarios. A more limited transmission build-out may be justified for the Local Priority Scenario. Of course, these estimates do not include any reliability benefits that would be realized from adding more transmission. All scenarios could be built out to the 10% case without any new interstate transmission (see Section 6.4.6).




**Figure 16 – Building the Local Priority and Mega Project Scenarios without the accompanying interstate transmission, increases costs at high penetrations in the Mega Project Scenario.**

### IS ADDITIONAL STORAGE NEEDED?

Storage can provide many benefits to the system, including price arbitrage (charging when spot prices are low and discharging when prices are high), reliability, and ancillary services. Pumped storage hydro (PSH), solar thermal storage, and plug-in hybrid electric vehicles (PHEVs) were examined in WWSIS, with the largest focus on PSH (see Chapter 8). WWSIS evaluated only the price arbitrage part of the value proposition for PSH and found it much less than sufficient to economically justify additional storage facilities.

In the 10% and 20% wind penetration scenarios, gas generation is always on the margin (meaning that there are only small spot price variations during most days). As a result, there is no apparent opportunity to economically justify energy storage based on price arbitrage. Spot price variations increase in the 30% wind penetration scenarios, primarily due to errors in day-ahead wind energy forecasts. Occasionally, the price swings are very large. However, because this is driven by forecast uncertainty, it is not possible to strategically schedule the use of storage resources to take advantage of the price variations (and subsequently help eliminate the operational problems due to wind forecast errors).



**Figure 17 – A new 100-MW PSH plant with perfect pricing foresight would earn approximately \$4 million/yr (\$3.4million/yr in 2009\$) from price arbitrage in the 30% case.**


To examine a best-case scenario for storage, a new 100-MW PSH plant was added to the system and given perfect foresight of spot prices so that it could be dispatched to optimize revenue. The results in Figure 17 show the resulting number of operating hours and value. With no renewables, the PSH unit would run about 2200 hours (total pumping and generating time) and have an operating value of about \$2.6 million (\$2.2 million in 2009\$) for the year. With a perfect forecast, the value of the PSH unit decreased as the renewable penetration increased, due to decreased spot prices. With 30% penetration and a perfect forecast the 100-MW PSH plant only had an annual operating value of \$0.5 million (\$0.4 million in 2009\$) which would only yield a capitalized value of about \$35/kW (\$30/kW in 2009\$). With an SOA forecast, spot prices are higher due to forecast error, and the 30% case increased the PSH annual operating value to \$3.8 M (\$3.2M in 2009\$). However, this is several times less than would be required to recover costs for a new PSH plant<sup>4</sup> (see Section 8).

## WHAT IS THE BENEFIT OF FLEXIBILITY IN THE REST OF THE GENERATION FLEET?

System flexibility is the key to accommodating increased renewable generation. WWSIS finds that at higher (30% case) penetration levels, decreased flexibility of either the coal or hydro facilities made operation more difficult and increased the costs of integrating the renewable generation.

## ALLOWING HYDRO TO PROVIDE LOAD FOLLOWING FOR WIND/SOLAR VARIABILITY IS HELPFUL

Hydro generation is capable of quick start/stop cycling and fast ramping, which makes it a good partner for variable wind and solar generation. Sensitivity analyses were conducted to examine the effects of hydro constraints on operating costs (see Section 6.4.2).



**Figure 18 – Decreasing the flexibility of the hydro system increases costs.** Operating cost savings for hydro dispatch to net load (left), and operating cost increase for constant output hydro operation (right), WECC.

This study assumed that hydro generation is normally committed and dispatched to serve daily peak net-load periods, while respecting the minimum operating points on the hydro units. The left side of Figure 18 shows the impact of adjusting the hydro schedules to account for the day-ahead renewable forecasts. Although the impact is relatively small at low levels of penetration, the WECC operating costs would be reduced by \$200 million/yr (\$170 million/yr in 2009\$) at the 30% case, increasing the value of wind and solar energy by about \$1/MWh (\$0.9/MWh in 2009\$).


The right side of Figure 18 examines the impact if hydro operation were severely constrained, such as a requirement to maintain constant river flow. In this case, the WECC operating costs would increase by up to \$1 billion/yr (\$0.9 billion/yr in 2009\$). Clearly it is important to maintain as much operational flexibility as possible with the hydro generation (see Section 6.4.2).

<sup>4</sup> Assuming \$1200-2000/kW capital cost and a fixed charge rate of 15% for a new PSH, \$18-30 million annually would be needed to recover capital costs.

## CONSTRAINTS ON COAL PLANTS RESULT IN HIGHER OPERATING COSTS

In WWSIS, coal plants were assumed to be able to operate down to minimum generation levels of 40% of nameplate capacity. WWSIS finds that higher minimum generation levels result in increased operating costs.

A sensitivity case explored the impact of varying coal plant minimum loading on system operating costs. Increasing the minimum loading had minimal impact with wind penetrations less than 20%. At the 30% scenario, the impact becomes more noticeable, as shown in Figure 19. If coal plants are allowed to only operate above 70% load, then WECC operating costs would increase by nearly \$160 million/yr (\$136 million/yr in 2009\$). See Section 6.4.4.



*Figure 19 – Decreasing the flexibility of the coal fleet by increasing minimum generation levels on coal plants increases costs. Increased WECC operating costs over 40% minimum ratings on coal plants, 30% case.*

## WHAT IS THE CONTRIBUTION OF RENEWABLES TO RESOURCE ADEQUACY?

Variable resources such as wind and solar PV are primarily energy resources rather than capacity resources. However, they provide some contribution to reliability (resource adequacy). A range of capacity valuation techniques based on traditional loss-of-load-expectation (LOLE) data were evaluated to consider the variability inherent with the renewable generation. This was conducted for WestConnect assuming no transmission constraints within the study footprint and no interconnections with the rest of WECC, so that the capacity value characteristics of the renewable generation could be isolated.



Table 4 shows capacity values of wind based on daily LOLE which were typical of the overall analysis. Wind generation resources selected for this study were found to have capacity values in the range of 10% to 15%. Wind plant energy output tends to

**Wind was found to have capacity values of 10-15%; PV was 25-30%; and CSP with 6 hours of thermal energy storage was 90-95%.**

be higher during winter and spring seasons, and during nighttime hours, which is contrary to system peak load periods. Hence, the capacity value is low relative to the plant rating. PV solar plants have

capacity values in the range of 25% to 30%. Although PV solar produces its energy during the daytime, output tends to decline in the late afternoon and early evening when peak load hours often occur. The PV output was based on the DC rating of the system; it would be 23% higher if based on the AC rating and included inverter and other losses from the outset. Concentrating solar plants with thermal energy storage have capacity values in the range of 90% to 95%, similar to thermal generating plants. Their maximum energy production tends to be during the long summer days, and the storage capability extends the energy output through the late afternoon and early evening hours, when peak loads occur (see Sections 4.2, 4.3, and 9.2 through 9.7).

TABLE 4 – CAPACITY VALUES FOR 2004-2006.				
CASE	WIND ONLY	PV ONLY	CSP ONLY	WIND+PV+CSP
10%	13.5%	35.0%	94.5%	18.2%
20%	12.8%	29.3%	94.8%	19.7%
30%	12.3%	27.7%	95.3%	19.8%

# CONCLUSIONS AND NEXT STEPS

The technical analysis performed in this study shows that it is feasible for the WestConnect region to accommodate 30% wind and 5% solar energy penetration. This requires key changes to current practice, including substantial balancing area cooperation, sub-hourly scheduling, and access to underutilized transmission capacity.

WWSIS finds that both variability and uncertainty of wind and solar generation impacts grid operations. However, the uncertainty (due to imperfect forecasts) leads to a greater impact on operations and results in some contingency reserve shortfalls and some curtailment, both of which are relatively small. The variability leads to a greater sub-hourly variability reserve requirement, but because conventional units are backed down, the system naturally has extra reserve margins.

This study has established both the potential and the challenges of large scale integration of wind and solar generation in WestConnect and, more broadly, in WECC. However, changes of this magnitude warrant further investigation. The project team regards the following as valuable topics for exploration:

- Characterization of the capabilities of the non-renewable generation portfolio in greater detail (e.g., minimum turndown, ramp rates, cost of additional wear and tear);
- Changes in non-renewable generation portfolio (e.g., impact of retirements, characteristics, and value of possible fleet additions or upgrades);
- Reserve requirements and strategies (e.g., off-line reserves, reserves from non-generation resources);
- Load participation or demand response (e.g., functionality, market structures, PHEV);
- Fuel sensitivities (e.g., price, carbon taxes, gas contracts and storage, hydro constraints and strategies);
- Forecasting (e.g., calibration of forecasting using field experience, strategies for use of short-term forecasting);
- Rolling unit commitment (e.g., scheduling units more frequently than once on a day-ahead basis);
- Transmission planning and reliability analyses (e.g., transient stability, voltage stability, protection and control, intra-area constraints and challenges);
- Hydro flexibility (e.g., calibration of hydro models with plant performance).

# REFERENCES

- [1] EERE (U.S. DOE Office of Energy Efficiency and Renewable Energy). July 2008. 20% Wind Energy by 2030: Increasing Wind Energy's Contribution to U.S. Electric Supply. DOE/GO-102008-2567. Washington: EERE. [www1.eere.energy.gov/windandhydro/pdfs/41869.pdf](http://www1.eere.energy.gov/windandhydro/pdfs/41869.pdf).
- [2] Enernex Corporation. January 2010. "Eastern Wind Integration and Transmission Study", NREL Report No. SR-550-47078, [www.nrel.gov/wind/systemsintegration/pdfs/2010/ewits\\_final\\_report.pdf](http://www.nrel.gov/wind/systemsintegration/pdfs/2010/ewits_final_report.pdf).
- [3] New York State Energy Research and Development Authority. March 2005. "The Effects of Integrating Wind Power on Transmission System Planning, Reliability, and Operations," [www.nyserda.org/publications/wind\\_integration\\_report.pdf](http://www.nyserda.org/publications/wind_integration_report.pdf).
- [4] California Energy Commission. July 2007. Intermittency Analysis Project Study. "Appendix B - Impact of Intermittent Generation on Operation of California Power Grid," [www.energy.ca.gov/2007publications/CEC-500-2007-081/CEC-500-2007-081-APB.PDF](http://www.energy.ca.gov/2007publications/CEC-500-2007-081/CEC-500-2007-081-APB.PDF).
- [5] Ontario Power Authority. October 2006. Independent Electricity System Operator, Canadian Wind Energy Association's "Ontario Wind Integration Study," [www.powerauthority.on.ca/Storage/28/2321\\_OPA\\_Report\\_final.pdf](http://www.powerauthority.on.ca/Storage/28/2321_OPA_Report_final.pdf).
- [6] GE Energy. March 2008. Attachment A: Analysis of Wind Generation Impact on ERCOT Ancillary Services Requirements. Prepared for Electric Reliability Council of Texas. Schenectady, NY: GE Energy. [http://www.ercot.com/content/news/presentations/2008/Wind\\_Generation\\_Impact\\_on\\_Ancillary\\_Services\\_-\\_GE\\_Study.zip](http://www.ercot.com/content/news/presentations/2008/Wind_Generation_Impact_on_Ancillary_Services_-_GE_Study.zip).
- [7] Smith, C., et al. August 2007. "Utility Wind Integration and Operating Impact State of the Art", IEEE Power and Energy, Vol 22, No. 3, pp 900-908, [www.nrel.gov/wind/systemsintegration/pdfs/2007/milligan\\_wind\\_integration.pdf](http://www.nrel.gov/wind/systemsintegration/pdfs/2007/milligan_wind_integration.pdf).
- [8] DeMeo, E., et al. Nov/Dec 2007. "Accommodating Wind's Natural Behavior", IEEE Power & Energy Magazine, pp 59-67 <http://ieeexplore.ieee.org/iel5/8014/4382976/04383124.pdf>.
- [9] Corbus, D., D. Lew, G. Jordan, W. Winters, F. Van Hull, J. Manobianco, and R. Zavadil. November/December 2009. "Up with Wind: Studying the Integration and Transmission of Higher Levels of Wind Power." IEEE Power and Energy, 7(6): 36-46.
- [10] 3TIER. March 2010. Development of Regional Wind Resource and Wind Plant Output Datasets, NREL SR-550-47676, <http://www.nrel.gov/docs/fy10osti/47676.pdf>.
- [11] NREL. Wind Integration Datasets. [www.nrel.gov/wind/integrationdatasets](http://www.nrel.gov/wind/integrationdatasets).
- [12] Wilcox, S., April 2007. "National Solar Radiation Database, 1999 - 2005: User's Manual," NREL Report TP-581-41364, <http://www.nrel.gov/docs/fy07osti/41364.pdf>.











