

WindPACT Rotor Design Study: Hybrid Tower Design

**Period of Performance:
June 29, 2000 – February 28, 2004**

D.J. Malcolm
*Global Energy Concepts LLC
Kirkland, Washington*



NREL

National Renewable Energy Laboratory
1617 Cole Boulevard, Golden, Colorado 80401-3393
303-275-3000 • www.nrel.gov

Operated for the U.S. Department of Energy
Office of Energy Efficiency and Renewable Energy
by Midwest Research Institute • Battelle

Contract No. DE-AC36-99-GO10337

WindPACT Rotor Design Study: Hybrid Tower Design

**Period of Performance:
June 29, 2000 – February 28, 2004**

D.J. Malcolm
*Global Energy Concepts LLC
Kirkland, Washington*

NREL Technical Monitor: J. Cotrell

Prepared under Subcontract No. YAT-0-30213-01



NREL

National Renewable Energy Laboratory
1617 Cole Boulevard, Golden, Colorado 80401-3393
303-275-3000 • www.nrel.gov

Operated for the U.S. Department of Energy
Office of Energy Efficiency and Renewable Energy
by Midwest Research Institute • Battelle

Contract No. DE-AC36-99-GO10337

NOTICE

This report was prepared as an account of work sponsored by an agency of the United States government. Neither the United States government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States government or any agency thereof.

Available electronically at <http://www.osti.gov/bridge>

Available for a processing fee to U.S. Department of Energy and its contractors, in paper, from:

U.S. Department of Energy
Office of Scientific and Technical Information
P.O. Box 62
Oak Ridge, TN 37831-0062
phone: 865.576.8401
fax: 865.576.5728
email: <mailto:reports@adonis.osti.gov>

Available for sale to the public, in paper, from:

U.S. Department of Commerce
National Technical Information Service
5285 Port Royal Road
Springfield, VA 22161
phone: 800.553.6847
fax: 703.605.6900
email: orders@ntis.fedworld.gov
online ordering: <http://www.ntis.gov/ordering.htm>



Table of Contents

1	INTRODUCTION	1
1.1	Background	1
1.2	Current and Past Practice	1
1.3	Scope.....	2
1.4	Objectives	2
2	APPROACH	4
2.1	Selected Configuration.....	4
2.2	Initial Design Spreadsheet	5
2.3	Final Spreadsheet Design.....	5
2.3.1	Spreadsheet Calculations	6
2.4	Component Design Process	8
2.5	Cable Dynamics	8
3	ANALYSIS AND DESIGN.....	10
3.1	Outline Geometries	10
3.2	Selection of Configuration	12
3.3	Natural Frequency of Wind Turbine.....	14
3.4	Selection of Configuration for Costing.....	14
4	COST ESTIMATES	16
5	DISCUSSION AND CONCLUSIONS.....	18
5.1	Discussion	18
5.2	Conclusions.....	19
6	REFERENCES	20

Appendix A Drawings of Proposed Hybrid Tower

List of Figures

Figure 1-1. Representative stayed tower configuration.....	3
Figure 2-1. Two-dimensional layout of hybrid tower	4
Figure 2-2. Displacements of tube due to tube flexing and due to cable extension	6
Figure 2-3. Natural frequency and axial stiffness vs. tension for the upper guy cables.....	8
Figure 3-1. Outlines of Group #1: variation of spreader beam length.....	10
Figure 3-2. Outlines of Group #2: variation of truss base width.....	11
Figure 3-3. Outlines of Group #3: variation of truss height	11
Figure 3-4. Variation of key properties with length of spreader beam (Group #1).....	12
Figure 3-5. Variation of key properties with truss base width	13
Figure 3-6. Variation of key properties with truss height.....	13

List of Tables

Table 3-1. Outline Geometries Considered	10
Table 3-2. Configuration Dimensions Selected for Final Costing	14
Table 3-3. Masses of Subassemblies of the Selected Configuration	15
Table 4-1. Summary of Vendors Approached for Cost Estimates	16
Table 4-2. Comparison of Costs with WindPACT Baseline	17
Table 5-1. Technical Challenges Associated with Hybrid Tower.....	18

1 INTRODUCTION

1.1 Background

Wind energy has the lowest overall cost of all renewable energy sources and is now almost competitive with conventional energy sources, even without environmental credits. The dramatic decrease in the cost of energy (COE) from wind over the past two decades is due to improvements in aerodynamics, materials, controls, electronics, and in the balance-of-station costs, such as interconnection and maintenance.

In 2000, the National Renewable Energy Laboratory (NREL) launched the Wind Partnerships for Advanced Component Technologies (WindPACT) program to examine ways in which the cost of wind energy could be reduced a further 30% to approximately \$0.03/kWh. The purpose of this program is to explore advanced technologies for improving machine reliability and decreasing the overall COE.

The cost of a wind turbine tower can represent as much as 20% of the cost of an entire megawatt-scale horizontal axis wind turbine (HAWT) and as much as 10% of the total COE. The tower is a major cost component, and its design is important: Its structural properties are key to the response of the rotor; its height determines the wind regime that the rotor experiences; it allows access to the turbine nacelle and rotor; and it houses components of the electrical connection and the control and protection systems.

Most large wind turbines currently installed in the United States use self-supporting steel tubular towers. The diameter of these tubes is limited by the maximum size that can be transported by road, which is approximately 4.3 m. The base dimensions of a truss tower are not restrained by this limit, but trusses may require more maintenance and may not be aesthetically acceptable. Guyed tube towers have been used, but they represent additional foundation costs and inconvenience. Addressing these limitations may lead to an alternative that avoids the problems. For this reason, the WindPACT Rotor Design Study [1] was modified to include a study of a hybrid tower to determine the technical and economic feasibility of such a design.

1.2 Current and Past Practice

In the past, many methods have been used to support horizontal and vertical axis wind turbines. The most common approach for vertical axis wind turbines (VAWTs) has been to use guy cables for the upper bearing while the lower connection remains close to the ground. Rigid truss frames have also been used for VAWTs but with limited success.

Small HAWTs usually required a ratio of height to diameter (H/D) greater than that for larger HAWTs in order to gain the same benefit of higher wind speeds. This meant that small HAWTs more often employed supporting guy cables, which are likely to be more cost-effective than a freestanding tube or truss when the H/D ratio exceeds about 2.0.

In the 1980s, when many 50- to 100-kW machines were installed in California, truss towers were common. Although a stiff support can be offered to the nacelle in this way, truss towers were considered an attraction to birds, leading to a possible increase in avian mortality. In addition, truss towers were considered less aesthetic than single-tube towers. As a result of these and other factors, self-supporting tube towers have become the standard for utility-scale wind turbines. Although the tubes are generally made of steel or concrete, steel tubes have become the standard, especially in developed countries with high labor costs.

The towers for large HAWTs are sometimes categorized according to the fundamental natural frequency of the combined system [2]. Systems with a natural frequency below the rotor speed (1P) are classed as “soft-soft”; those with natural frequencies between 1P and nP (where n is the number of blades) are “soft”; and a frequency above nP identifies the tower as “stiff.” Some think that soft-soft towers will

more successfully attenuate the fatigue loads throughout the system. However, this relationship has not been firmly proven, and most large wind turbines use soft towers.

This study focuses on large HAWTs, which can be considered to have rated powers above 1.0 MW, although even this is well below the higher ratings that most manufacturers now sell. Such machines have hub heights greater than 50 m; the highest reach about 80 m. A major limitation of the use of steel tubes for heights above about 80 m is that the base diameter must fit within the maximum dimension that can be transported by road. This limit is about 4.3 m in the United States. Any larger diameter may require sectioning and field assembly by bolting or welding. The former may be unsightly and expensive; the latter may increase the costs of obtaining adequate quality assurance.

To circumvent the problem of transporting large steel sections, one recent study [3] examined the concept of combining an upper steel tube with a concrete lower tube. That study concludes that at some scales, the use of cast-in-place or precast concrete for the lower tube will be cost-effective.

1.3 Scope

The current study examines an alternative type of hybrid design, one that considers a combination of steel tube, steel truss, and guy cables (Figure 1-1). It may be called a “stayed” design due to the analogy with the support of sailing ship masts.

This study is limited to an examination of configurations suited to supporting a 1.5-MW rotor and nacelle at a hub height of 84 m. These values make the tower comparable with the 1.5-MW WindPACT baseline tower [1]. However, the width of the spreader beams, the height of the truss, and the shape of the tube are varied to optimize the configuration.

1.4 Objectives

The objectives of this study are to:

- Construct a simple mathematical model of the stayed tower to allow trade-offs between the dimensions to optimize the configuration
- Carry out preliminary design of the major components and to prepare drawings
- Obtain cost estimates for all components
- Draw conclusions regarding the cost-effectiveness of this type of configuration
- Identify the strengths and weaknesses of the design concept.

2 APPROACH

2.1 Selected Configuration

The basic configuration model and nomenclature used to model the concept are shown in Figure 2-1.




Figure 2-1. Two-dimensional layout of hybrid tower.

The location at which the guy cables are connected to the tube is fixed such that distance h_3 is equal to the rotor radius below the hub height to ensure blade-cable clearance.

The following key design variables were identified:

- The length of the spreader beams
- The base dimension of the truss
- The height of the connection between truss and tube (i.e., the height of the truss)
- The stiffness of the guy cables.

Early in the project, the connection between the truss, the spreader beams, and the tube was identified as a key component. This component must be a casting to accept the multiple connections, and the moment transferred to the tube will affect not only the tube but also the design of the casting. The value of this moment should be as low as possible.

2.2 Initial Design Spreadsheet

The hybrid tower sketched in Figures 1-1 and 2-1 is a highly redundant structure because there are multiple load paths, except in the upper part of the tube. An exact analysis of the internal forces due to a given external load is, therefore, a complex calculation best done by a computer code such as a finite element analysis. However, to avoid the added cost of this process and to facilitate analysis of many configurations, as much of the analysis as possible was completed by hand and by spreadsheet calculations. This was justified by the objective to arrive at a cost estimate to determine whether the concept merits further pursuit.

We made the following assumptions to perform this simplified analysis:

1. The upper cables are distinct from the lower cables and have their own set of end attachments.
2. The spreader beams are infinitely stiff members pinned at each end.
3. The truss is also very stiff, and the top of the truss does not translate.
4. The bending stiffness of the tower can be represented by a torsional spring at the base of the tube.
5. The tube is of constant cross section and stiffness (this was later modified).
6. The loading on the tower is a single lateral load at the hub height.

These assumptions make the hybrid tower a once-indeterminate structure, and it is possible to solve for all the member forces using the Solver feature in an Excel spreadsheet. The input to the spreadsheet consisted of:

- Lateral force at hub height
- Truss height
- Width of the truss base
- Span of the spreader beams
- Axial stiffness of the cables
- Bending stiffness of the tube
- Cross section area of main truss members.

The spreadsheet output included the forces in all the components. We used this information to calculate the lateral motion at the hub and to compare it with the stiffness of a conventional tower. In addition, the spreadsheet performed some preliminary design, such as the mass of the cables, the tube, the truss, and the spreader beams (by making assumptions about the governing criteria).

In practice, a preload will be applied to the cable system to ensure that no cables become slack under the influence of normal operating loads. For extreme loads, such as from the 50-year return wind loading, it is permissible to allow the downwind cables to become slack. The preload was chosen so that under the 50-year predicted characteristic thrust at the yaw bearing, the downwind guy cables were reduced to zero tension (assuming that the response of the system, including the cable tension, remained linear).

2.3 Final Spreadsheet Design

It is usually possible to arrive at a set of guy cable stiffness and tube flexibility that results in zero bending at the base of the tube under the influence of a lateral load at hub height. Figure 2-2 shows how the bending effects at the tube base due to cable extension only are of opposite nature to that of the lateral load only. The spreadsheet was, therefore, set up to solve for the cable size that would result in zero total rotation at the tower base and, hence, zero base-bending moment. In this solution, the distribution of

bending stiffness in the tube is important, and it is no longer acceptable to approximate the tube as having constant stiffness. The formulas in the spreadsheet were corrected to reflect the tapered nature of the tube. This, in turn, meant that tube diameter and wall thicknesses at the top, at the cable restraint, and at the base were required as input.




Figure 2-2. Displacements of tube due to tube flexing and cable extension.

2.3.1 Spreadsheet Calculations

The following calculations assume that the wind loading is aligned with one of the guys and refer to the two-dimensional sketch in Figure 2-2.

The tube base is regarded as pinned, so the change in upper cable tensions, T_2 , due to the applied lateral load, F , is

$$T_2 = \frac{F(h_2 + h_3)}{h_2 \cos(\theta_2)}$$

From this, the tension, T_1 , in the lower cables is calculated as

$$T_1 = T_2 \frac{\sin(\theta_2)}{\sin(\theta_1)}$$

The extension in the lower cables gives rise to a vertical displacement, d_1 , at the ends of the spreader beams of

$$d_1 = \frac{T_1 h_1}{EA_1 \sin^2(\theta_1)}$$

and the lateral displacement at the attachment to the tube is

$$d_2 = d_1 \tan \theta_2 + \frac{T_2 h_2}{EA_2 \cos^2(\theta_2)}.$$

The maximum compression in the spreader beam is

$$\text{compression} = T_1 \cos(\theta_1) + T_2 \cos(\theta_2).$$

The stiffness of the cables and tube must be proportioned so that there is zero final rotation at the tube base (because the connection of the tube to the truss will, in reality, be a rigid one, and the truss is considered very stiff). This requires calculation of the rotation due to the cable extension of the cables and due to the flexing of the tube. For small angles, the rotation due to the cable extension is simply

$$\phi = d_2/h_2.$$

The rotation due to the tube flex is more complex to calculate. We have that

$$\phi_1 + \phi_2 = \int \frac{M_z dz}{EI} \quad \text{and} \quad \phi_2 h_2 = \int_0^{h_2} \frac{M dz}{EI}$$

where $M = F h_3 \frac{z}{h_2}$

$$EI = EI_1 \left[1 + (\beta - 1) \frac{z}{h_2} \right]$$

and $\beta = \frac{EI_2}{EI_1}$

where ϕ_1 is the tube rotation at the tube base and ϕ_2 is the rotation of the tube at the cable connection. The solution for ϕ_1 is

$$\phi_1 = \frac{F h_3}{EI_1} \int_0^{h_2} \frac{\left(1 - \frac{z}{h_2}\right) \frac{z}{h_2}}{\left[1 + (\beta - 1) \frac{z}{h_2}\right]} dz,$$

which can be evaluated numerically. First, the value of EI_1 was selected, and then the Excel Solver routine was used to solve for the cable cross section that satisfied the condition that

$$\phi_1 + d_2/h_2 = 0.$$

The lateral displacement, d_3 , at the rotor hub height can be calculated with reference to the same Figures 2-1 and 2-2 and is a superposition of the displacement due to cable extension and flexure of the tube. This leads to

$$d_3 = d_2 \frac{(h_2 + h_3)}{h_2} + \phi_2 h_3 + \int_0^{h_3} \frac{M z dz}{EI}$$

where $\phi_2 = \frac{Fh^3}{EI} \int_0^{h/2} \frac{(z/h)^2}{1 + (\beta - 1)z/h} dz$

and $M = Fh^3 \frac{z}{h^3}$

$EI = EI_3 \left(1 + (\alpha - 1) \frac{z}{h_3}\right)$

$\alpha = \frac{EI_2}{EI_3}$

2.4 Component Design Process

Some design capability was included in the spreadsheet. For example, the total mass of the steel tube was calculated from the dimensions supplied for the tube sections. In addition, the cross section of the horizontal spreaders was estimated based on the buckling capacity of the flanges using a safety factor of 2.0 in conjunction with the characteristic loads. The mass of the main truss members was calculated from the given cross section, and an estimate was made for the bracing members.

2.5 Cable Dynamics

A check was carried out to avoid the upper or lower sets of cables “galloping” due to excitation of their fundamental natural modes by the 1P or 3P harmonics from the rotor. This calculation considered the range of tensions that would occur during normal operation of the wind turbine. Figure 2-3 shows typical plots for the upper cables of the fundamental natural frequencies together with the change in axial stiffness with cable tension. The operating rotor speed is approximately 20 rpm, or 0.33 Hz, and 3P is at 1.0 Hz. Hence, the natural frequency of the cables will be well above the dangerous harmonics except at the very lowest tension; that condition will occur very infrequently and is likely to correspond with a stationary rotor. The natural frequencies of the lower cable will be greater than those of the upper cables and will, therefore, be further above the 1P and 3P harmonics.




Figure 2-3. Natural frequency and axial stiffness vs. tension for the upper guy cables.

The axial stiffness of the cable was calculated from the expression [4]:

$$k = \left[\frac{\ell}{EA} + \frac{\rho^2 \ell^3 \cos^2 \theta}{12T^3} \right]^{-1}$$

and the fundamental natural frequency (Hz) was calculated from [4]

$$f = \frac{1}{2\ell} \sqrt{\frac{T}{\rho}}$$

where ρ = mass density per unit length, T = tension in cable, and ℓ = cable length.

3 ANALYSIS AND DESIGN

3.1 Outline Geometries

The outline geometries considered are summarized in Table 3-1. They fall into three groups that correspond to the single parameter varied in each case. Those parameters are the length of the spreader beam, the width of the truss base, and the height of the truss.

Table 3-1. Outline Geometries Considered

Group #	Spreader Beam Length (m)	Truss Base Half-Width (m)	Truss Height (m)
1	15	10	20
Variation of spreader beam length	20	10	20
	25	10	20
	30	10	20
2	25	10	20
Variation of truss width	25	5	20
	25	15	20
3	25	10	15
Variation of truss height	25	10	20
	25	10	25

The outlines corresponding to Groups 1, 2, and 3 are shown in Figures 3-1, 3-2, and 3-3, respectively.




Figure 3-1. Outlines of Group #1: variation of spreader beam length.




Figure 3-2. Outlines of Group #2: variation of truss base width.




Figure 3-3. Outlines of Group #3: variation of truss height.

3.2 Selection of Configuration

We examined the dependence of several system properties on the governing dimensions such as truss height, truss width, and spreader beam length. The selected properties are:

- Minimum preload in the cables. The preload was selected such that the minimum cable load under peak lateral rotor load (436 kN) was zero.
- Maximum cable tension. As for the minimum tension, this calculation assumed a linear response between load and tension change.
- Lateral stiffness at the tower top. This calculation assumed a rigid truss but considered the flexibility of the tube and the cables.
- Maximum compression in the spreader beams. The design of the beam was governed by stability under peak compression.
- Estimate of the total mass of the assembly (excluding cables). This was a rough estimate of total masses, using approximate design of the spreader beam.
- Cross section of each cable pair. The cables are in pairs and the cross section values refer to the combination of both cables.
- Diameter of the base of the tube. This was fixed at 1200 mm with a thickness of 8 mm. These dimensions led to acceptable answers for other properties, such as the cable cross sections.

One limiting property was the size of the cables. The cost of the cables increases rapidly with diameter, especially the cost of the end sockets and other end fittings. The maximum acceptable cable size was 2½ inches (63 mm), which corresponds to an effective cross section for a pair of approximately 5000 mm². A preferred maximum cross section was 4000 mm², corresponding to a pair of 57-mm cables.

Figure 3-4 shows the variation in the key properties as a function of the spreader beam length (Group #1). If the cable cross section is to be within 4000 mm², then the beam length must be 25 m or more. The longer beam lengths are associated with lower cable tensions but with higher beam compression, which leads to higher overall mass.




Figure 3-4. Variation of key properties with length of spreader beam (Group #1).

Figure 3-5 illustrates the results of Group #2, in which the width of the truss base was varied while the spreader beam length was maintained at 25 m and the truss height at 20 m. The increasing width is associated with lower beam compression and lower cable tensions.




Figure 3-5. Variation of key properties with truss base width.

Figure 3-6 illustrates the results of Group #3 in which the height of the truss base was varied while the spreader beam length was maintained at 25 m and the truss half-width at 10 m. The increasing height is associated with lower maximum cable tension, lower beam compression, and higher hub-lateral stiffness.




Figure 3-6. Variation of key properties with truss height.

3.3 Natural Frequency of Wind Turbine

The fundamental natural frequency of the complete wind turbine system is predominantly one of tower sway and is affected strongly by the tower stiffness. The tower stiffness will, therefore, determine whether the tower is classed as soft-soft (fundamental natural frequency less than 1P), soft (natural frequency between 1P and 3P), or stiff (natural frequency greater than 3P).

We estimated that a hub lateral stiffness of 600 kN/m offered by the tower (typical of the results presented above), assuming a head mass of 87,000 kg, would lead to a fundamental natural frequency of about 0.37 Hz. If the rated speed of the rotor is 20 rpm, then this natural frequency is 1.11P, which is barely sufficient to place it in the soft category. However, this calculation indicates that variations in some of the basic parameters could change the tower category from soft to soft-soft.

3.4 Selection of Configuration for Costing

After examining the full range of configurations, we selected a single configuration for final drafting and costing. The dimensions of that configuration are listed in Table 3-2. A number of trade-offs must be made among cable size, compressive loads, overall stiffness, etc. These were considered in this selection.

Table 3-2. Configuration Dimensions Selected for Final Costing

Item	Units	Dimension
Total height	m	84.0
Height of truss/tube interface	m	20.0
Half-width of base of truss	m	10.0
Length of one spreader beam	m	25.0
Height of tube/cable connection	m	49.0
Diameter of cables	mm	57
Pretension in each cable of each pair	kN	370
Tube section at top	mm	2000 x 8
Tube section at cable attachment	mm	3500 x 13
Tube section at bottom	mm	1200 x 8

The key decision drivers were the spreader beam length and the base width.

Figure 3-4 shows that the required cable stiffness and size decrease with the length of the spreader beam. For the cable diameter below 57 mm to be considered reasonable, the spreader beam must have a minimum length of 25 m.

Figure 3-5 shows that a decreased base width is associated with higher compressive loads in the spreader beam, higher initial cable tension, and higher required cable size. A smaller truss footprint will also lead to higher foundation loads. This suggests that a half-width no less than 10 m is desirable. Further increasing the footprint of the truss will lead to longer and less stable bracing members.

Table 3-3. Masses of Subassemblies of the Selected Configuration

Item	Total Mass (kg)
Spreader beams (4)	13,790
Upper tube	27,096
Lower tube	22,600
Truss assembly	14,487
Upper cables and fittings	7,880
Lower cables and fittings	5,136
Base castings (4)	3,916
Tube-truss casting	1,138

4 COST ESTIMATES

We approached several suppliers to determine the estimated costs for 100 units that will affect the overall cost of fabricating and assembly. Rough cost estimates reflect the feasibility nature of the study, so all results are approximate. The suppliers approached and the responses received are summarized in Table 4-1.

Table 4-1. Summary of Vendors Approached for Cost Estimates

Item	Supplier	Response
Steel fabrication	DMI Industries 420 East Main Ave. West Fargo, ND 58078 701-282-6959	No response
	Trinity Structural Towers, Inc. Thomas Holt Dallas, TX 75207 214-589-8382	No response
	Beaird Industries, Inc. Steve Rogers 601 Benton Kelly St. Shreveport, LA 71106 318-671-5400	\$155-k/turbine
Castings	St Marys Foundry Steve Barry 405 E South St. St Marys, OH 45885 419-394-3346	\$5691 for tube-truss casting. \$1896 for each of four truss base castings
Cables and fittings	Williamsport Wire Rope Works, Inc. Rick Perry 100 Maynard St. Williamsport, PA 17701 570-326-5146	\$107-k/turbine; includes all end fittings
Field assembly	D.H. Blattner & Sons Paul Chandler 400 County Road 50 Avon, MN 56310 320-356-7351	\$20-k/turbine minimum. Crane mobilization extra. See Appendix.

A comparison with the equivalent costs from the WindPACT baseline 1.5-MW rotor [3] is given in Table 4-2.

Table 4-2. Comparison of Costs with WindPACT Baseline

Item	WindPACT Baseline [1]	Hybrid Tower
Total mass (including cables)	122,000 kg	96,000 kg
Fabrication (including castings and cable assemblies)	\$179,000	\$275,275
Tower transportation	\$37,500 ¹	\$40,000 ²
Assembly	\$7,500	\$20,000 ³
Foundations	\$63,000 ⁵	\$20,000 ⁴
Total cost	\$257,000	\$355,275

Notes:

1. This value was obtained from a \$25/kW estimate used in the WindPACT logistics report [5].
2. This value was selected to be similar to the corresponding value for the conventional tower because the total masses are similar but the hybrid towers comprise more parts.
3. D.H. Blattner & Sons supplied the cost estimate for assembly of the hybrid tower. The estimate does not include the cost of crane mobilization and demobilization.
4. D.H. Blattner & Sons supplied the cost estimate for the hybrid tower footings. The estimate was based on the company's experience with similar foundations.
5. The cost of the foundation for the single tube assumes that the Patrick & Henderson single-pile foundation is used.

5 Discussion and Conclusions

5.1 Discussion

The hybrid tower assembly is a highly redundant structure that requires a finite element analysis for an accurate solution. However, the approximate analysis performed for this project is a valid approach for an initial solution. The analysis also recognizes that any bending moment transferred from the base of the tube through the casting will greatly increase the complexity and cost of that connection but that it is usually possible to proportion the cables and the tube sizes to eliminate any bending at this key connection.

The height of the connection between the tube and the cables is dictated by the need to allow passage of the rotor blades, which are assumed to have a radius of 35 m. However, the truss height can be varied, and Figure 3-6 shows the effects of changing this height. As the height increases, the cable preload, the spreader beam compression, and the total mass are reduced, while the overall lateral stiffness is increased. Therefore, an increase of the truss height to about 25 m should be considered, despite the slight increase in required cable size.

The cost estimates for the hybrid tower show that the total fabrication costs are expensive and may ensure that this concept remains less cost-effective than the single steel tube. If the costs of the cable assemblies are neglected, then the costs of fabricating the parts for the hybrid tower are similar to those for the conventional tower. However, the cables add another \$100,000 to the cost of each turbine because 16 cables and end fittings are required for each tower.

The design of the spreader beams is controlled largely by stability under the large compressive loads. In this project, we decided to restrain the possible buckling in the horizontal plane by including two sets of cables between the system of beams. These cables are of nominal diameter, and their cost is not great, but including them will add to the assembly time.

This study has been sufficient to identify (but not fully solve) some of the technical problems associated with this hybrid concept. These include the challenges listed in Table 5-1.

Table 5-1. Technical Challenges Associated with Hybrid Tower

Technical Challenge	Comments
Ensuring near-zero bending moment at base of tube under all conditions	Requires the correct selection of cable stiffness. Extreme conditions may not satisfy this state.
Designing spreader beams to withstand buckling	These long members must carry high compressive loads. More careful design may lead to weight saving.
Applying preload to cables	Each cable must have some adjustment device, which can be expensive. The cables in each of the two principal directions must be pretensioned independently.
Designing attachments to the tube (requires detailed stress analysis)	Stress concentrations will lead to fatigue failure.
Allowing maintenance access to the nacelle	Maintenance personnel must first climb the truss and then enter the tube, which is barely large enough to accommodate one person.
Designing electrical connection	The main cable must transfer from the tube to the truss.
Installing parts	More parts implies more time required for assembly. Pretensioning can be time consuming.
Accommodating crane requirements	The hybrid tower does not lend itself to a self-erection procedure. The crane requirements are not reduced.

One purpose of this project is to open a possible approach to very tall towers for which a single-tube design will be problematic. The investigation has shown the hybrid concept to be viable and that it could be used to construct very tall towers (more than 100-m hub height) while avoiding the problem of large base-tube diameters. However, the hybrid configuration does not naturally lend itself to a self-erection process for the tower or for the nacelle and rotor; in fact, the presence of the spreader beams and cables could make such a scheme more difficult. Instead, the crane requirements will be the same as for a conventional tower.

5.2 Conclusions

The overall conclusions of the study are:


- The concept of a hybrid tower, incorporating a truss, tube, stays, and cables, appears to be technically feasible.
- The bending moment at the connection between the tube and the truss can be reduced to near zero by correct sizing of the cables and tube.
- The spreader beams constitute a subassembly with considerable mass. This is due to the large compressive load that must be carried and the unsupported length, which leads to stability problems. The cost of this assembly might be reduced by a more careful design.
- Although the maximum tube diameter has been reduced from that of a single-tube design, the mass of the total assembly has been reduced by only about 25% (see Table 4-2).
- The cable assemblies are expensive (especially the cost of the end fittings) and require careful installation.
- Cables are supplied in pairs for redundancy, to aid handling, and because of limited cable sizes.
- If this scheme is not combined with a self-erecting scheme for the tower and nacelle, the concept does not appear to facilitate higher hub heights.
- The overall cost of a hybrid design is likely to be greater than that of a single-tube design. This is due to the higher cost of fabrication and the higher assembly costs.


6 REFERENCES

1. Malcolm, D.J.; Hansen, A.C. *WindPACT Turbine Rotor Design Study*. NREL/SR-500-32495. Work performed by Global Energy Concepts LLC, Kirkland, WA, and Woodward Engineering, Salt Lake City, UT. Golden, CO: National Renewable Energy Laboratory, August 2002.
2. Frederick, G.R.; Savino, J.M. “Summary of Tower Designs for Large Horizontal Axis Wind Turbine.” *ASME Energy Source Technology Conference and Exhibition Proceedings, February 1986, New Orleans, Louisiana*. . DOE/NASA/20320-68. NASA Lewis Research Center, 1986.
3. Berger/ABAM. *Evaluation of Design and Construction Approaches for Economical Hybrid Steel/Concrete Wind Turbine Towers*. Draft Report, NREL Subcontract YAM-2-31235-01.
4. Madugula, M.K.S. (Ed.). *Dynamic Response of Lattice Towers and Guyed Masts*. Reston, VA: ASCE, 2002.
5. Smith, K. *WindPACT Turbine Design Scaling Studies, Technical Area 2: Turbine, Rotor, and Blade Logistics*. NREL/SR-500-29439. Work performed by Global Energy Concepts LLC, Kirkland, WA. Golden, CO: National Renewable Energy Laboratory, June 2001.

Appendix A

Drawings of Proposed Hybrid Tower






GLOBAL ENERGY CONCEPTS, LLC		
TITLE:		
STAYED TOWER		
SIZE	PART NO.	REV
B	N4-20-1000	A
SCALE: NONE		WEIGHT: 101,500 kg SHEET 2 OF 2



NOTES

1. PRELIMINARY DRAWING FOR ROM QUOTES. ASSUME DRAFT ANGLES 0-3 DEG WHERE NECESSARY
2. QUOTE TO INCLUDE ALLOWANCES FOR NON-DESTRUCTIVE INSPECTION
3. ALL FILLET RADII 25 MM UOS
4. DESCALE, DEGREASE, PRIME, AND PAINT DARK GREY
5. ALL DIMENSIONS BASIC UOS
6. PART VOLUME = 0.115 CU. M.


REVISIONS				
ZONE	REV.	DESCRIPTION	DATE	APPROVED
	-	PRELIMINARY		




B-B



D-D



A-A







UNLESS OTHERWISE SPECIFIED:		NAME	DATE	GLOBAL ENERGY CONCEPTS, I.L.C.	
DIMENSIONS ARE IN MILLIMETERS		DRAWN	DAR	6/5/03	
TOLERANCES		CHECKED		TITLE:	
ANGULAR		ENG APPR.		CASTING, LEG BASE	
X ± 0.5°		MFG APPR.		Q.A.	
XX ± 0.1°		COMMENTS:		SIZE	
LENGTH				PART NO.	
X ± 1mm				N4-20-1010	
X ± 0.5mm				REV	
XX ± 0.1mm				-	
INTERPRET GEOMETRIC TOLERANCING PER ANSI/ASME Y14.5-1994				SCALE: NONE	
MATERIAL				WEIGHT: 905 kg	
ASTM A536 GR. 5				SHEET 1 OF 1	
FINISH					
PER NOTE					
APPLICATION	DO NOT SCALE DRAWING				

NOTES

1. PRELIMINARY DRAWING FOR ROM QUOTES. ASSUME DRAFT ANGLES WHERE NECESSARY
2. QUOTE TO INCLUDE ALLOWANCES FOR NON-DESTRUCTIVE INSPECTION
3. ALL FILLET RADII 5 MM UOS
4. DESCALE, DEGREASE, PRIME, AND PAINT WHITE EPOXY, 5 MIL MIN PAINT THICKNESS
5. DEBUR AND/OR BREAK SHARP EDGES

REVISIONS			
REV.	DESCRIPTION	DATE	APPROVED
A	A1. CHANGED WEB THICKNESS A2. CHANGED WEB HEIGHT A3. CHANGED FLANGE THICKNESS A4. CHANGED FLANGE WIDTH A5. CHANGED HOLE SPACING A6. INTRODUCED FLANGE TAPER A7. CHANGED CABLE ATTACH BRACKETS A8. ADDED CROSS BRACE BRACKETS	12/21/03	




		UNLESS OTHERWISE SPECIFIED: DIMENSIONS ARE IN MILLIMETERS TOLERANCES: ANGULAR: X ± 1° X ± 0.3° X ± 0.1° LENGTHS: X ± 1 mm X ± 0.5 mm X ± 0.25 mm	NAME	DATE	GLOBAL ENERGY CONCEPTS, LLC	
		MATERIAL ASTM A36	DRAWN DAR	6/10/03	TITLE: SPREADER	
		FINISH PER DWG NOTES	CHECKED		SIZE B N4-20-1020	
		APPLICATION DO NOT SCALE DRAWING	ENG APPR.		REV A	
			MFG APPR.		SCALE: NONE WEIGHT: 12,194 kg SHEET 1 OF 1	
			Q.A.			
			COMMENTS:			

NOTES

1. PRELIMINARY DRAWING FOR ROM QUOTES, ASSUME DRAFT ANGLES WHERE NECESSARY
2. DESCALE, DEGREASE, PRIME, AND PAINT WHITE EPOXY, 5 MIL MIN PAINT THICKNESS
3. DEBUR AND/OR BREAK SHARP EDGES
4. MATERIAL: ASTM A36 PLATE, 15mm THICK



REVISIONS				
ZONE	REV.	DESCRIPTION	DATE	APPROVED
	A	CHANGED HOLE PATTERN AND THICKNESS	12/21/03	



		UNLESS OTHERWISE SPECIFIED: DIMENSIONS ARE IN MILLIMETERS	NAME	DATE	GLOBAL ENERGY CONCEPTS, LLC	
		TOLERANCES:	DRAWN	DAR	6/11/03	TITLE: DOUBLER
		ANGULAR:	CHECKED			
		X ± 1°	ENG APPR.			
		X ± 0.5°	MFG APPR.			
		XX ± 0.1°	Q.A.			SIZE B N4-20-1021
		LENGTH:	COMMENTS:			
		X ± 1 mm				REV A
		X ± 0.5 mm				SCALE: NONE WEIGHT: 26.8 KG SHEET 1 OF 1
		XX ± 0.1 mm				
		INTERPRET CODES:				
		ANSI Y-14.5-1994				
MATERIAL		N4-20-1000				
PER NOTES						
FINISH						
PER DWG NOTES						
DO NOT SCALE DRAWING						
APPLICATION	USED ON					

NOTES:

1. ALL DIMENSIONS IN MM UOS
2. ALL WEIGHTS IN KG UOS
3. GALVANIZE ALL STRUCTURAL SHAPES PER SPEC XXXX AFTER DRILLING
4. INSTALL ALL BRACES WITH A MINIMUM OF TWO M22 GRADE 5 BOLTS
5. SEE TOP CASTING DETAIL DRAWING




REVISIONS				
ZONE	REV.	DESCRIPTION	DATE	APPROVED
	-	PRELIMINARY		

ITEM NO.	PART NO.	QTY.	LENGTH	MATERIAL	DESCRIPTION
1	N4-20-1101	1		ASTM 536 Gr. 5	TRUSS TOP CASTING
2	N4-20-1102	4	2385	ASTM A242	STR. STL. ANGLE, 100.42 DEG
3	N4-20-1103	4	19781	ASTM A242	STR. STL. ANGLE, 150X150X15, 90 DEG
4	N4-20-1104	4	5090	ASTM A242	STR. STL. ANGLE, 75X75X8, 90 DEG
5	N4-20-1105	4	8754	ASTM A242	STR. STL. ANGLE, 75X75X8, 90 DEG
6	N4-20-1106	4	12418	ASTM A242	STR. STL. ANGLE, 75X75X8, 90 DEG
7	N4-20-1107	8	4946	ASTM A242	STR. STL. ANGLE, 75X75X8, 90 DEG
8	N4-20-1108	8	6090	ASTM A242	STR. STL. ANGLE, 75X75X8, 90 DEG
9	N4-20-1109	8	10560	ASTM A242	STR. STL. ANGLE, 75X75X8, 90 DEG
10	N4-20-1110	8	4612	ASTM A242	STR. STL. ANGLE, 75X75X8, 90 DEG
11	N4-20-1111	8	5264	ASTM A242	STR. STL. ANGLE, 75X75X8, 90 DEG
12	N4-20-1112	8	4893	ASTM A242	STR. STL. ANGLE, 75X75X8, 90 DEG

UNLESS OTHERWISE SPECIFIED:		NAME	DATE	GLOBAL ENERGY CONCEPTS, LLC	
DIMENSIONS ARE IN INCHES		DRAWN	DAR		6/5/03
TOLERANCES:		CHECKED			
FRACTIONALS ±		ENG APPR.			
ANGULAR MATCH ± BEND ±		MFG APPR.			
TWO PLACE DECIMAL ±		Q.A.			
THREE PLACE DECIMAL ±		COMMENTS:			
FINISH PER BOM					
FINISH PER NOTES					
APPLICATION		DC NOT SCALE DRAWING			

TITLE:		
<h1>Truss Assembly</h1>		
SIZE	PART NO.	REV
B	N4-20-1100	-
SCALE: NONE	WEIGHT: 14.487 kg	SHEET 1 OF 2







GLOBAL ENERGY CONCEPTS, LLC		
TITLE: TRUSS ASSEMBLY		
SIZE B	PART NO. N4-20-1100	REV -
SCALE: NONE	WEIGHT: 14,487 kg	SHEET 2 OF 2


NOTES:

1. PRELIMINARY DRAWING FOR ROM QUOTES, ASSUME DRAFT ANGLES WHERE NECESSARY
2. VOLUME: .1460 m³
3. {PRELIMINARY} APPLY EPOXY PRIMER AND WHITE EPOXY PAINT
4. ALL FILLET RADII 15mm UOS

REVISIONS				
ZONE	REV.	DESCRIPTION	DATE	APPROVED
D4	A	A1. CHANGED DIMENSION	12/21/03	
B3		A2. CHANGED HOLE SPACING		



UNLESS OTHERWISE SPECIFIED:		NAME	DATE	TITLE: TRUSS TOP CASTING
DIMENSIONS ARE IN MILLIMETERS		DRAWN	DAR	
TOLERANCES:		CHECKED		
FRACTIONALS		ENG APPR.		
ANGULAR: ± .5°		MFG APPR.		
X ± 1 mm		Q.A.		
XX ± 0.5mm		COMMENTS:		
INTERPRET GEOMETRIC TOLERANCING PER:				
MATERIAL				
ASTM 536 Gr. 5				
NEXT ASSY	USED ON	FINISH	PER NOTES	SIZE B
APPLICATION		DO NOT SCALE DRAWING		PART NO. N4-20-1101
				REV A
				SCALE: NONE
				WEIGHT: 1142 kg
				SHEET 1 OF 1





REVISIONS				
ZONE	REV.	DESCRIPTION	DATE	APPROVED
	-	PRELIMINARY		

		UNLESS OTHERWISE SPECIFIED:		NAME	DATE	GLOBAL ENERGY CONCEPTS, LLC	
		DIMENSIONS ARE IN MILLIMETERS		DRAWN	DAR	6/16/03	
		TOLERANCES:		CHECKED		TITLE:	
		ANGULAR:		ENG APPR.		UPPER TUBE ASSEMBLY	
		X ± 0.5°		MFG APPR.		SIZE	
		XX ± 0.1°		Q.A.		PART NO.	
		LENGTH:		COMMENTS:		N4-20-1200	
		X ± 1mm				REV	
		X ± 0.5mm				-	
		XX ± 0.1mm				SCALE: NONE	
		INTERPRET GEOMETRIC TOLERANCING PER:				WEIGHT: XXXX	
		MATERIAL				SHEET 1 OF 1	
		PER ITEM					
NEXT ASSY		USED ON					
		FINISH					
		PER NOTES					
APPLICATION		DO NOT SCALE DRAWING					



NOTES

1. PRELIMINARY DRAWING FOR ROM QUOTES
2. QUOTE TO INCLUDE ALLOWANCES FOR NON-DESTRUCTIVE INSPECTION
3. DESCALE, DEGREASE, PRIME, AND PAINT WHITE

REVISIONS				
ZONE	REV.	DESCRIPTION	DATE	APPROVED
		PRELIMINARY		



A-A



		UNLESS OTHERWISE SPECIFIED:	NAME	DATE	GLOBAL ENERGY CONCEPTS, LLC		
		DIMENSIONS ARE IN MILLIMETERS	DRAWN	DAR	6/9/03	TITLE:	
		TOLERANCES:	CHECKED			UPPER TUBE BOTTOM FLANGE	
		ANGULAR:	ENG APPR.				
		X ± 0.5°	MFG APPR.				
		X ± 0.7°	Q.A.			SIZE	
		LENGTH:	COMMENTS:			B	N4-20-1201
		X ± 1 mm					
		X ± 0.5mm					-
		X ± 0.1mm				SCALE: NONE	WEIGHT: 3736 kg
		X ± 0.1mm				SHEET 1 OF 1	
		INFILTRATE GEOMETRIC TOLERANCING PER:					
		MATERIAL:					
		N4-20-1200					
		ASTM A514 GR. Q					
		FINISH:					
		USH2 ON					
		APPLICATION					
		DO NOT SCALE DRAWING					




NOTES

1. PRELIMINARY DRAWING FOR ROM QUOTES
2. DEBUR AND/OR BREAK SHARP EDGES
3. DESCALE, DEGREASE, PRIME, AND PAINT WHITE EPOXY, 5 MIL MIN PAINT THICKNESS


WALL THICKNESS DRAWN AS NOMINAL VALUES. ACTUAL TUBE MAY BE STEP-TAPERED WELDMENT



REVISIONS				
ZONE	REV.	DESCRIPTION	DATE	APPROVED
		PRELIMINARY		



		UNLESS OTHERWISE SPECIFIED: DIMENSIONS ARE IN MILLIMETERS TO DRAWINGS: ANGULAR: X ± 1° XX ± 0.5° XXX ± 0.1° LENGTH: X ± 1 mm XX ± 0.5 mm XXX ± 0.1 mm		NAME	DATE	GLOBAL ENERGY CONCEPTS, LLC	
		THIRD ANGLE PROJECTION INTERPRET GDT PER ANSI Y14.5-94		DRAWN	DAR	6/18/2003	TITLE:
		MATERIAL ASTM A36		CHECKED			UPPER TUBE WELDMENT
		FINISH PER DWG NOTES		ENG APPR.			
N4-20-1200				MFG APPR.			B N4-20-1202
APPLICATION	USED ON			Q.A.			
		DO NOT SCALE DRAWING		COMMENTS:			-
						SCALE: NONE	WEIGHT: 23.263 kg
						SHEET 1 OF 1	







REVISIONS				
ZONE	REV.	DESCRIPTION	DATE	APPROVED
	-	PRELIMINARY		

		UNLESS OTHERWISE SPECIFIED:		NAME	DATE	GLOBAL ENERGY CONCEPTS, LLC	
		DIMENSIONS ARE IN MILLIMETERS		DRAWN	DAR	6/17/03	TITLE: LOWER TUBE ASSEMBLY
		TOLERANCES:		CHECK'D			
		ANGULAR:		ENG APPR.			
		X ± 0.5°		MFG APPR.			
		XX ± 0°		Q.A.			SIZE B
		LENGTH		COMMENTS:			
		X ± 1 mm					PART NO. N4-20-1300
		XX ± 0.5 mm					REV -
		XX ± 0.1 mm					SCALE: NONE WEIGHT: 22.600 kg SHEET 1 OF 1
		INTERPRET GEOMETRIC TOLERANCING PER:					
		MATERIAL					
		N4-20-1000 PER ITEM					
NEXT ASSY	USED ON	FINISH					
		PER NOTES					
APPLICATION		DO NOT SCALE DRAWING					

NOTES

1. PRELIMINARY DRAWING FOR ROM QUOTES
2. QUOTE TO INCLUDE ALLOWANCES FOR NON-DESTRUCTIVE INSPECTION
3. DESCALE, DEGREASE, PRIME, AND PAINT WHITE

REVISIONS				
ZONE	REV.	DESCRIPTION	DATE	APPROVED
		PRELIMINARY		



		UNLESS OTHERWISE SPECIFIED:	NAME	DATE	GLOBAL ENERGY CONCEPTS, LLC	
		DIMENSIONS ARE IN MILLIMETERS	DRAWN	DAR	6/10/03	TITLE: BOTTOM TUBE UPPER FLANGE
		TOLERANCES:	CHK'D			
		ANGULAR:	ENG APPR.			
		X ± 0.5°	MFG APPR.			
		XX ± 0.1°	Q.A.			COMMENTS:
		LENGTH:				
		X ± 1 mm				
		X ± 0.5 mm				
		XX ± 0.1 mm				
		INTERPRET GEOMETRIC TOLERANCING PER:				
		MATERIAL:				
		ASTM A514 GR. Q				
		FINISH:				
		PER NOTES				
		APPLICATION:				
		DO NOT SCALE DRAWING				
NEXT ASSY	USED ON	SIZE B		PART NO.	REV	
				N4-20-1301	-	
		SCALE: NONE	WEIGHT: 3735 kg	SHEET 1 OF 1		




NOTES

1. PRELIMINARY DRAWING FOR ROM QUOTES
2. DEBUR AND/OR BREAK SHARP EDGES
3. DESCALE, DEGREASE, PRIME, AND PAINT WHITE EPOXY, 5 MIL MIN PAINT THICKNESS

WALL THICKNESS DRAWN AS NOMINAL VALUES. ACTUAL TUBE MAY BE STEP-TAPERED WELDMENT



REVISIONS				
ZONE	REV.	DESCRIPTION	DATE	APPROVED
	-	PRELIMINARY		



A-A

B-B



		UNLESS OTHERWISE SPECIFIED: DIMENSIONS ARE IN MILLIMETERS TOLERANCES ANGULAR: X ± 1° XX ± 0.5° XXX ± 0.1° LENGTH: X ± 1 mm XX ± 0.5 mm XXX ± 0.1 mm		NAME	DATE	GLOBAL ENERGY CONCEPTS, LLC	
		MATERIAL ASTM A36		DRAWN	DAR	6/18/2003	TITLE: LOWER TUBE WELDMENT
		FINISH PER DWG NOTES		CHKD			
		APPLICATION DO NOT SCALE DRAWING		ENG APPR.			
				MFG APPR.			SIZE B
				Q.A.			N4-20-1302
				COMMENTS:			REV -
							SCALE: NONE WEIGHT: 18,837 kg SHEET 1 OF 1

NOTES

1. PRELIMINARY DRAWING FOR ROM QUOTES
2. MATERIAL: \varnothing 57mm (2.25 in) PER ASTM A586, STAINLESS OR GALVANIZED WIRE ROPE WITH SWAGED OPEN END CLEAVES. MINIMUM BREAKING STRENGTH = _____.

3. LENGTH MEASUREMENT AFTER PRELOAD OF _____.

REVISIONS				
ZONE	REV.	DESCRIPTION	DATE	APPROVED
		PRELIMINARY		




		UNLESS OTHERWISE SPECIFIED:		NAME		DATE		GLOBAL ENERGY CONCEPTS, LLC	
		DIMENSIONS ARE IN MILLIMETERS TO FRACTIONS:		DRAWN		DAR		6/17/2009	
		ANGLES ARE:		CHECKED				TITLE:	
		X = 1°		ENG APPR.				UPPER CABLE	
		X = 0.5°		MFG APPR.				SIZE	
		X = 0.1°		Q.A.				B	
		LENGTH		COMMENTS:				REV	
		X = 1 mm						-	
		X = 0.5 mm						SCALE: NONE	
		X = 0.1 mm						WEIGHT: 1021 kg	
		INTERPRETATION:						SHEET 1 OF 1	
		ANSI Y-14.5-1994							
		MATERIAL							
		SEE NOTES							
N4-20-1000		FINISH							
NEXT ASSY		USED ON							
		PER DWG NOTES							
APPLICATION		DO NOT SCALE DRAWING							

NOTES

1. PRELIMINARY DRAWING FOR ROM QUOTES. TURNBUCKLE AND LINK IS REPRESENTATION OF ADJUSTABLE ASSEMBLY ONLY. MANUFACTURER'S SUGGESTIONS ARE WELCOME.
2. MATERIAL: \varnothing 57mm (2.25 in) PER ASTM A586. STAINLESS OR GALVANIZED WIRE ROPE WITH SWAGED OPEN END CLEVISSES. MINIMUM BREAKING STRENGTH = _____.

3 LENGTH MEASUREMENT AFTER PRELOAD OF _____.

REVISIONS				
ZONE	REV.	DESCRIPTION	DATE	APPROVED
	A	CHANGED LENGTH	12/12/03	



		UNLESS OTHERWISE SPECIFIED:		NAME	DATE	GLOBAL ENERGY CONCEPTS, LLC	
		DIMENSIONS ARE IN MILLIMETERS		DRAWN	DAR	6/12/2009	TITLE: LOWER CABLE ASSEMBLY
		TOLERANCES:		CHECKED			
		ANGULAR:		ENG APPR.			
		X ± 1°		MFG APPR.			
		X ± 0.5°		Q.A.			
		LENGTH		COMMENTS:			
		X ± 1 mm					
		X ± 0.5 mm					
		INTERPRET CODE PER:					
		ANSI Y-14.5-1994					
		MATERIAL					
		SEE NOTES					
N4-20-1000		FINISH					
NEXT ASSY		USED ON					
		PER DWG NOTES					
APPLICATION		DO NOT SCALE DRAWING					
				SIZE	REV		
				B	A		
				SCALE: NONE		WEIGHT: 1395 kg	
						SHEET 1 OF 1	



NOTES

1. PRELIMINARY DRAWING FOR ROM QUOTES. TURNBUCKLE AND LINK IS REPRESENTATION OF ADJUSTABLE ASSEMBLY ONLY. MANUFACTURER'S SUGGESTIONS ARE WELCOME.
2. MATERIAL: ϕ 12.5mm (0.50 in) PER ASTM A586, STAINLESS OR GALVANIZED WIRE ROPE WITH SWAGED OPEN END CLEAVISES. MINIMUM BREAKING STRENGTH = _____.
3. WEIGHTS: INNER (-1) 22.3 kg
OUTER (-2) 39.2 kg

③ INNER BRACE CABLE (-1) LENGTH MEASUREMENT AFTER PRELOAD OF _____.

④ OUTER BRACE CABLE (-2) LENGTH MEASUREMENT AFTER PRELOAD OF _____.

REVISIONS				
ZONE	REV.	DESCRIPTION	DATE	APPROVED
	-	PRELIMINARY		



		UNLESS OTHERWISE SPECIFIED: DIMENSIONS ARE IN MILLIMETERS	NAME	DATE	GLOBAL ENERGY CONCEPTS, LLC	
		TOLERANCES:	DRAWN	DAR	12/21/03	TITLE:
		ANGULAR:	CHECKED			SPREADER BRACE CABLE ASSEMBLY
		X ± 1°	ENG APPR.			
		X ± 0.5°	MFG APPR.			
		X ± 0.1°	Q.A.			SIZE
		LENGTH	COMMENTS:			B
		X ± 1 mm				
		X ± 0.5 mm				REV
		X ± 0.2 mm				-
		INTERPRET CODE PER: ANSI Y-14.5-1994				SCALE: NONE
	N4-20-1000	MATERIAL SEE NOTES				WEIGHT: see notes
NEXT ASSY	USED ON	FINISH PER DWG NOTES				SHEET 1 OF 1
APPLICATION		DO NOT SCALE DRAWING				

REPORT DOCUMENTATION PAGE

Form Approved
OMB NO. 0704-0188

Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302, and to the Office of Management and Budget, Paperwork Reduction Project (0704-0188), Washington, DC 20503.

1. AGENCY USE ONLY (Leave blank)		2. REPORT DATE April 2004	3. REPORT TYPE AND DATES COVERED Subcontractor Report June 29,2000–February 28, 2004	
4. TITLE AND SUBTITLE WindPACT Rotor Design Study: Hybrid Tower Design			5. FUNDING NUMBERS WER4.3509 YAT-0-30213-01	
6. AUTHOR(S) Malcolm, D.J.				
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) Global Energy Concepts LLC 5729 Lakeview Dr. N.W., Suite 100 Kirkland, WA 98033			8. PERFORMING ORGANIZATION REPORT NUMBER	
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES) National Renewable Energy Laboratory 1617 Cole Blvd. Golden, CO 80401-3393			10. SPONSORING/MONITORING AGENCY REPORT NUMBER NREL/SR-500-35546	
11. SUPPLEMENTARY NOTES NREL Technical Monitor: J. Cotrell				
12a. DISTRIBUTION/AVAILABILITY STATEMENT National Technical Information Service U.S. Department of Commerce 5285 Port Royal Road Springfield, VA 22161			12b. DISTRIBUTION CODE	
13. ABSTRACT (<i>Maximum 200 words</i>) The cost of a wind turbine tower can represent as much as 20% of the cost of an entire megawatt-scale horizontal axis wind turbine (HAWT) and as much as 10% of the total cost of energy. The tower is a major cost component, and its design is important: Its structural properties are key to the response of the rotor; its height determines the wind regime that the rotor experiences; it allows access to the turbine nacelle and rotor; and it houses components of the electrical connection and the control and protection systems. Most large wind turbines installed in the United States use self-supporting steel tubular towers. The diameter of these tubes is limited by the size that can be transported by road (approximately 4.3 m). The base dimensions of a truss tower are not restrained by this limit, but trusses may require more maintenance. Guyed tube towers have been used, but they represent additional foundation costs and inconvenience. Addressing these limitations may lead to an alternative that avoids the problems. For this reason, the WindPACT Rotor Design Study was modified to include a study of a hybrid tower to determine the technical and economic feasibility of such a design.				
14. SUBJECT TERMS wind energy; wind turbine; tower; hybrid tower; WindPACT			15. NUMBER OF PAGES	
			16. PRICE CODE	
17. SECURITY CLASSIFICATION OF REPORT Unclassified	18. SECURITY CLASSIFICATION OF THIS PAGE Unclassified	19. SECURITY CLASSIFICATION OF ABSTRACT Unclassified	20. LIMITATION OF ABSTRACT UL	