

Cold-Climate Solar Domestic Hot Water Systems: Cost/Benefit Analysis and Opportunities for Improvement

J. Burch, T. Hillman, and J. Salasovich

*Presented at the 2004 DOE Solar Energy Technologies
Program Review Meeting
October 25-28, 2004
Denver, Colorado*

Conference Paper
NREL/CP-550-37105
January 2005

NREL is operated by Midwest Research Institute • Battelle Contract No. DE-AC36-99-GO10337



NOTICE

The submitted manuscript has been offered by an employee of the Midwest Research Institute (MRI), a contractor of the US Government under Contract No. DE-AC36-99GO10337. Accordingly, the US Government and MRI retain a nonexclusive royalty-free license to publish or reproduce the published form of this contribution, or allow others to do so, for US Government purposes.

This report was prepared as an account of work sponsored by an agency of the United States government. Neither the United States government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States government or any agency thereof.

Available electronically at <http://www.osti.gov/bridge>

Available for a processing fee to U.S. Department of Energy and its contractors, in paper, from:

U.S. Department of Energy
Office of Scientific and Technical Information
P.O. Box 62
Oak Ridge, TN 37831-0062
phone: 865.576.8401
fax: 865.576.5728
email: <mailto:reports@adonis.osti.gov>

Available for sale to the public, in paper, from:

U.S. Department of Commerce
National Technical Information Service
5285 Port Royal Road
Springfield, VA 22161
phone: 800.553.6847
fax: 703.605.6900
email: orders@ntis.fedworld.gov
online ordering: <http://www.ntis.gov/ordering.htm>



Cold-Climate Solar Domestic Hot Water Systems: Cost/Benefit Analysis and Opportunities for Improvement

J. Burch, T. Hillman, and J. Salasovich
National Renewable Energy Laboratory
1617 Cole Blvd.; Golden, CO 80401; jay_burch@nrel.gov

ABSTRACT

To determine potential for reduction in the cost of saved energy (COSE) for cold-climate solar domestic hot water (SDHW) systems, COSE was computed for three types of cold climate water heating systems. For each system, a series of cost-saving measures was considered: 1) balance of systems (BOS): tank, heat exchanger, and piping-valving measures; and 2) four alternative lower-cost collectors. Given all beneficial BOS measures in place, >50% reduction of COSE was achievable only with selective polymer collectors at half today's selective collector cost. In all three system types, today's metal-glass selective collector achieved the same COSE as the hypothesized non-selective polymer collector.

1. Objectives

The main goal for DOE's Solar Heat and Light sub-program is reducing the cost of saved energy (COSE) for SDHW systems by at least 50% [1]. The objective of this work is to determine if this goal is realistic for cold-climate SDHW systems.

2. Technical Approach

Three system types are considered: glycol, drainback, and indirect thermosiphon. For cold climates, glycol and drainback are common, whereas the thermosiphon is relatively novel. COSE is estimated by simulating performance (at TMY2 sites) and estimating costs under a *new-construction* market scenario. With new construction, the installation is more efficient and marketing costs (at 25% of hardware+installation cost) are smaller, compared to the more-common "retrofit scenario" assumed in [2]. Costs are taken either as the "best-available" costs provided by manufacturers or as estimated from similar products, rather than as costs from detailed analysis of specific designs. Costs include direct materials (collector and balance-of-system (BOS) hardware), installation (labor, materials, overhead/profit), marketing, and O&M. Cost modeling framework and algorithms are detailed in [2]. When a component is varied, installation costs and O&M costs are varied accordingly, as in [3].

We define a series of hypothetical cost-reduction measures for each system type. As in Table 1, BOS variations include unpressurized polymer storage with immersed polymer heat exchangers, integrated polymer piping, and an integrated valve package. A variation specific to glycol systems is to eliminate the storage-side pump with a thermosiphon loop between heat exchanger and solar storage tank. Collector variations and assumed costs are given in Table 2.

Table 1. Some BOS Components and Assumed Cost

Component	Description	Cost ¹
Metal Tank + heat exchanger	Conventional tank with external side-arm hx	\$460
Polymer tank + heat exchanger	Unpressurized polymer tank with immersed polymer hx	\$180
Integrated piping	Supply/return piping with integral insulation	\$25/100 ²
Valve package	Factory-assembled unit of all valves and sensors	\$200

¹ Direct cost only, does not include install costs or O&M

² \$1/ft for glycol and drainback, \$4/ft for thermosiphon

Table 2. Collectors, Properties, and Assumed Costs

Collector	$F_r(\tau\alpha)_n$ ¹	$F_r U_l$ ¹	Cost
Metal-glass-selective	0.779	4.77	\$500
Metal-glass-non-selective	0.768	7.245	\$450
Polymer-selective ²	0.779	4.77	\$250
Polymer-non-selective	0.739	8.216	\$200
Polymer-unglazed	0.88-0.029*v	10.24+4.69*v	\$100

¹ Taken from [4], except for unglazed data from [5].

² Taken as identical to the metal-glass selective collector.

3. Results and Accomplishments

The BOS enhancements do not *per se* affect system performance; their impact is on first cost only. Simulations were done for the four unique sets of collector parameters (selective polymer=selective metal-glass), for all three system types, except that the unglazed collector has not been done with the thermosiphon system because of convergence problems. Efficiency of the glycol system with the four collector parameter sets is shown in Fig. 1. The efficiency is ~constant for each collector, decreasing slightly with increasing site temperature. U.S. maps of savings, efficiency, and solar fraction for all systems/collectors can be found in [3], similar to Fig. 2.

Base case and the best two variations are shown in Table 3. With all cost-reducing BOS variations in place, the maximum reduction in COSE is obtained with the hypothetical selective polymer collector. In all three system types, the result with the non-selective polymer collector is about the same as with the base-case metal-glass selective collector.




Fig.1. Efficiency (Savings/Incidence) for the glycol system with the four different sets of collector parameters.




Fig. 3. First cost and COSE for the glycol system. COSE data are shown with/without O&M cost included.




Fig. 2. U.S. Map of Glycol-selective annual savings.

Results for all the variations on the glycol system are shown in Figure 3. BOS variations are done first, followed by collector variations. Once a BOS measure is introduced, it remains for succeeding cases. BOS measures account for most of the COSE reduction. The non-selective metal-glass collector and the unglazed polymer collector are not effective measures because they increase COSE. Even though first costs are lowered, performance is lowered proportionally more. For all cases, only the use of the polymer collectors results in first cost under \$1,500. For all three SDHW types, use of the non-selective polymer collector results in approximately the same COSE as the base-case selective metal-glass collector, but with lower first cost. For similar measures, the thermosiphon system always has the lowest COSE value by ~10%, because of elimination of the pump and controller needed in the two active systems.

Table 3. Base and Best COSE for Three System Types

System	Glycol		Drainback		Thermosiphon	
	Base	Best2*	Base	Best2*	Base	Best2*
COSE (¢/kWh)	11.2	5.5/6.3	11.8	5.2/6.3	9.3	4.8/6.6
% Reduction2*		50.5/40.7		53.5/43.8		57.0/46.4

Note: Best2 and %Reduction2 cells give results for the two best cases: polymer-selective/polymer-non-selective. The COSE with today's selective metal collector is about equal to the COSE with the hypothesized polymer non-selective collector.

4. Conclusions

COSE values have been generated for three system types, with BOS variations and five different collector types. The lowest COSE is with all BOS variations in place and use of a hypothetical selective polymer collector. Next-best COSE values were with use of a polymer non-selective or selective metal-glass collector. Polymer collectors made with commodity plastics can cause issues with overheating. Thermosiphon systems have the lowest COSE, but bring issues with pipe freezing and storage location.

REFERENCES

- [1] Solar Energy Technology Program Multi-Year Technical Plan. U.S. DOE/EERE, DOE/GO-102003-1775.
- [2] J. Burch, J. Salasovich, C. Christensen, B. Lorand, and B. Scholten, "Cost-Benefit Modeling of Solar Domestic Hot Water Systems," *Procedures of the ASES 99 Solar Conference; ASES, Boulder, CO; June 1999.*
- [3] J. Burch, T. Hillman, and J. Salasovich, "Cold Climate Solar Domestic Hot Water Systems: Cost/Benefit Analysis and Opportunities for Improvement," NREL TP-550-37012, October 2004.
- [4] Directory of SRCC Certified Solar Collector Ratings. Available at <http://solar-rating.org>
- [5] S.J. Harrison, D. McClenahan, V.H. Nielsen, "The Performance of Unglazed Solar Collectors," *Procedures of the 15th Annual Conference of the Solar Energy Society of Canada, Penticton, B.C., June 1989, pgs. 235-239.*

MAJOR FY 2004 PUBLICATIONS

Burch, J., Salasovich, J., Christensen, C., and Thornton, J., "Geographical Variation in Performance of an Unglazed Solar System Meeting Water Heating and Space Conditioning Loads", 2004 ASES Conference Proceedings, ASES, Boulder, CO.

REPORT DOCUMENTATION PAGE

Form Approved
OMB No. 0704-0188

The public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing the burden, to Department of Defense, Executive Services and Communications Directorate (0704-0188). Respondents should be aware that notwithstanding any other provision of law, no person shall be subject to any penalty for failing to comply with a collection of information if it does not display a currently valid OMB control number.

PLEASE DO NOT RETURN YOUR FORM TO THE ABOVE ORGANIZATION.

1. REPORT DATE (DD-MM-YYYY) January 2005		2. REPORT TYPE Conference Paper		3. DATES COVERED (From - To)		
4. TITLE AND SUBTITLE Cold-Climate Solar Domestic Hot Water Systems: Cost/Benefit Analysis and Opportunities for Improvement				5a. CONTRACT NUMBER DE-AC36-99-GO10337		
				5b. GRANT NUMBER		
				5c. PROGRAM ELEMENT NUMBER		
6. AUTHOR(S) J. Burch, T. Hillman, and J. Salasovich				5d. PROJECT NUMBER NREL/CP-550-37105		
				5e. TASK NUMBER SH052003		
				5f. WORK UNIT NUMBER		
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) National Renewable Energy Laboratory 1617 Cole Blvd. Golden, CO 80401-3393				8. PERFORMING ORGANIZATION REPORT NUMBER NREL/CP-550-37105		
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES)				10. SPONSOR/MONITOR'S ACRONYM(S) NREL		
				11. SPONSORING/MONITORING AGENCY REPORT NUMBER		
12. DISTRIBUTION AVAILABILITY STATEMENT National Technical Information Service U.S. Department of Commerce 5285 Port Royal Road Springfield, VA 22161						
13. SUPPLEMENTARY NOTES						
14. ABSTRACT (Maximum 200 Words) To determine potential for reduction in the cost of saved energy (COSE) for cold-climate solar domestic hot water (SDHW) systems, COSE was computed for three types of cold climate water heating systems. For each system, a series of cost-saving measures was considered: 1) balance of systems (BOS): tank, heat exchanger, and piping-valving measures; and 2) four alternative lower-cost collectors. Given all beneficial BOS measures in place, >50% reduction of COSE was achievable only with selective polymer collectors at half today's selective collector cost. In all three system types, today's metal-glass selective collector achieved the same COSE as the hypothesized non-selective polymer collector.						
15. SUBJECT TERMS PV; cost of saved energy (COSE); solar domestic hot water (SDHW); cold climate; heating systems; metal glass selective collector; balance of systems (BOS);						
16. SECURITY CLASSIFICATION OF:			17. LIMITATION OF ABSTRACT UL	18. NUMBER OF PAGES	19a. NAME OF RESPONSIBLE PERSON	
a. REPORT Unclassified	b. ABSTRACT Unclassified	c. THIS PAGE Unclassified			19b. TELEPHONE NUMBER (Include area code)	

Standard Form 298 (Rev. 8/98)
Prescribed by ANSI Std. Z39.18