

Minimizing Variation in Outdoor CPV Power Ratings



**CPV-7, Las Vegas,
Nevada**

Matthew Muller

4/4/2011

NREL/PR-5200-51370

Outline

- An overview of 6 months of CPV and tracked PV power data
- Analyze NREL's data set in an attempt to answer 3 questions:
 - 1) How much variation is actually seen in outdoor power measurements if tight filtering is placed on meteorological and spectral conditions?
 - 2) How much variation is seen in monthly power ratings using a regression based approach?
 - 3) Are there alternative methods to regression that result in less variation?
- Conclusions/Recommendations

NREL CPV Testbed & Outdoor Power Ratings

- 2-axis tracker (± 0.15 degree sun pointing error)
- Data acquisition provides module peak power tracking
- IV sweeps, 5 minute intervals
- DNI, GNI, wind speed, T_{ambient} , T_{module} , and tracking error are measured
- Spectral data available
- A unique data set of various CPV lens and module architectures
- Understanding CPV performance variation and supporting standards development



IEC 62670, Outdoor or Indoor CPV Power Ratings

Concentrator Standard Test Conditions (CSTC)

$T_{\text{cell}} = 25\text{C}$
 $\text{DNI} = 900 \text{ W/m}^2$
G173/AM 1.5

Cell Temperature Fixed

Temperature Coefficients

Concentrator Standard Operating Conditions (CSOC)

$T_{\text{ambient}} = 20\text{C}$
 $\text{DNI} = 900 \text{ W/m}^2$
Wind Speed 2m/s
G173/AM 1.5

Calculate Cell Temperature

Power Ratings at CSOC but How?



- IEC62670 describes CSOC but has not established a clear method
- ASTM-2527 regression
- ISFOC translation
- Consider other approaches
- Goal of work is to find the method that minimizes variation

Power Ratings, Autonomously Collected MONTHLY Data

- Filtering is applied to all data (based on ASTM-2527 data restrictions)
- ASTM-2527 calls for the following:
 - $10\text{C} \leq T_{\text{amb}} \leq 30\text{C}$
 - $\text{DNI} \geq 750\text{W}/\text{m}^2$
 - The average wind speed for the 5 minutes prior to a measurement is $\leq 5\text{m}/\text{s}$
 - Reject if visible clouds are within 10 degrees of sun
- Cloud restriction approximated by rejecting a 10 minute DNI deviation $> 2\%$
- Other restrictions applied above and beyond ASTM criteria
 - Reject if Diffuse radiation is $> 140\text{W}/\text{m}^2$
 - Reject if Tracking error is > 0.15 degrees



6 Months of Data with Basic Filtering in Place

- The plots below show about a 10% variation in the power produced at a given DNI for both flat-plate and CPV for a July – December





Same 6 Months of Data but Apply Temperature Correction

- The flat-plate variation is now $< 5\%$ while CPV variation decreased slightly at high DNI, increased for the lowest DNI and a bend is now more prominent at $850\text{W}/\text{m}^2$



Apply Spectral Filtering in Combination with Temp Correction

- Filter the CPV data to only accept Precipitable Water Vapor (PWV) between 1-3 cm and Aerosol Optical Depth (AOD) between 0.06-0.135
- Now the variation for CPV is about 5%. Additional filtering was considered based on geometric airmass (AM). Excluding AM>2 removes almost all data below the bend or below 850 W/m²




ASTM E2527 as an Example

- Apply the ASTM regression to the data set, reject if standard error > 3%

$$P_{\max} = \text{DNI}(a_1 + a_2 \text{DNI} + a_3 T_{\text{ambient}} + a_4 \text{Wind})$$

Report at CSOC ($T_{\text{amb}}=20\text{C}$, $W=2\text{m/s}$, $\text{DNI}=900\text{W/m}^2$)




□ How much will these results vary if applied over multiple months??

- The graph shows the % variation in a modules monthly power rating as compared to lowest monthly rating over the 2 years

- For example, CPV1 had its lowest rating in month 12, while the rating in month 11 was almost 6% greater



- The ASTM power rating varies about 10% for CPV and 5% for flat-plate



- CPV modules have their lowest ratings in the winter months
 - (At NREL, December, January minimum AM is > 2, November, February minimum AM is > 1.7)
 - Some modules show lens performance issues below 15C
- Even for flat-plate the regression coefficients don't adequately model known performance variation

Exclude highly variable winter months in comparing Power Rating Methods

- Spectral filtering considered hereafter inadvertently removes some months leading to an unfair comparison between methods
- Excluding Nov-Feb, the ASTM variation reduces to 7.6% for CPV1 and 6.8% for CPV2
- All comparison hereafter exclude AirMass > 2 (Graphs below show why)



Approaches to Reducing Outdoor Power Rating Variation

- 1) Modify ASTM
 - ASTM1: added filtering $1.3 \leq AM \leq 1.7$
 - ASTM2: add AM term, $P_{\max} = DNI(a_1 + a_2 DNI + a_3 T_{\text{ambient}} + a_4 \text{Wind} + a_5 AM)$
- 2) Build new regression from scratch considering all relevant parameters
 - The “best fit” on a year of data using statistical indicators
$$P_T = a_1 DNI + a_2 DNI^2 + a_3 AM + a_4 PWV$$
 - The PWV term was not valid on a monthly basis
 - REGRESSION1: $P_T = a_1 DNI + a_2 DNI^2 + a_3 AM$
- 3) Apply more translation/correction to the data and less regression
 - REGRESSION2: $P_{T,AM,PWV} = a_1 DNI + a_2 DNI^2$
 - $P_{T,AM,PWV}$ is a translation to CSOC cell temp, airmass of 1.5, PWV of 1.4cm
 - assumes module efficiency increases 1% per AM unit and 0.6% per PWV unit
 - ISFOC: Power translation used by ISFOC
 - ISFOC1: translation with added filtering $1.3 \leq AM \leq 1.7$
 - ISFOC2: translation with above correction for AM and PWV

Comparison of Power Rating Methods

Maximum Monthly Variation in Power Rating		
<i>Method</i>	<i>CPV1</i>	<i>CPV2</i>
ASTM 2527	7.6%	6.8%
“ASTM1”	8.7%	8.1%
“ASTM2”	8.0%	7.3%
“Regression1”	5.4%	6.7%
“Regression2”	4.2%	5.7%
“ISFOC”	6.9%	6.2%
“ISFOC1”	6.2%	6.1%
“ISFOC2”	2.9%	5.5%

- Attempts to improve on ASTM-2527 failed as variation increased
- “Regression1” showed minor improvement, AM coefficient was positive in some months, negative in others
- “Regression2”, translation for all but DNI shows even more improvement
- Both “ISFOC” and “ISFOC1” show some improvement of ASTM-2527 but are not as good as “Regression2” which include correction for AM and PWV
- The variation is the lowest for both modules when “ISFOC2” is used, ISFOC with AM, PWV corrections

Conclusions and Recommendations

- Applying filtering to a year of CPV data showed that power variation could be reduced to ~5% for a given DNI
- Regression based approaches fared poorly in attempts to minimize the variation in a monthly power rating
- Translation/Correction based approaches worked best with maximum monthly variation ranging from 2.9-5.7%

General suggestions/recommendations:

- 1) Exclude $AM > 2$, $PWV < 0.5$ from power rating data.
- 2) Exclude months that AM 1.5 does not occur.
- 3) PWV and AM should not be ignored.
- 4) Default to translation over regression approach.
- 5) Do not ignore temperature effects on lenses.

Future Work

- Apply translation based approaches to more modules and over longer time periods in order to confirm the results presented here.
- Efforts should be made to refine corrections for AM and PWV or to apply alternate corrections as data becomes available that improves ability to characterize the spectral conditions.
- Finally, corrections for variations in lens performance should be considered.

Thanks!

Questions?