



# Wind Turbine Generator System Power Quality Test Report for the Gaia Wind 11-kW Wind Turbine

Amy Curtis and Vahan Gevorgian

NREL is a national laboratory of the U.S. Department of Energy, Office of Energy Efficiency & Renewable Energy, operated by the Alliance for Sustainable Energy, LLC.

**Technical Report**  
NREL/TP-5000-51477  
July 2011

Contract No. DE-AC36-08GO28308

## NOTICE

This report was prepared as an account of work sponsored by an agency of the United States government. Neither the United States government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States government or any agency thereof.

Available electronically at <http://www.osti.gov/bridge>

Available for a processing fee to U.S. Department of Energy and its contractors, in paper, from:

U.S. Department of Energy  
Office of Scientific and Technical Information

P.O. Box 62  
Oak Ridge, TN 37831-0062  
phone: 865.576.8401  
fax: 865.576.5728  
email: <mailto:reports@adonis.osti.gov>

Available for sale to the public, in paper, from:

U.S. Department of Commerce  
National Technical Information Service  
5285 Port Royal Road  
Springfield, VA 22161  
phone: 800.553.6847  
fax: 703.605.6900  
email: [orders@ntis.fedworld.gov](mailto:orders@ntis.fedworld.gov)  
online ordering: <http://www.ntis.gov/help/ordermethods.aspx>

Cover Photos: (left to right) PIX 16416, PIX 17423, PIX 16560, PIX 17613, PIX 17436, PIX 17721



Printed on paper containing at least 50% wastepaper, including 10% post consumer waste.



**Wind Turbine Generator System  
Power Quality Test Report**

for the

**Gaia Wind 11-kW Wind Turbine  
in**

**Boulder, CO**

**Conducted for**

**National Renewable Energy Laboratory  
1617 Cole Blvd.  
Golden, CO 80401**

**Conducted by**

**Wind Energy Program  
DOE / NREL**

**Amy Curtis, Vahan Gevorgian**

**October 12, 2010**

## Notice

This report was prepared as an account of work sponsored by an agency of the United States government. The test results documented in this report define the characteristics of the test article as configured and under the conditions tested.

The United States government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Nor do they assume legal liability or responsibility for the performance of the test article or any similarly named article when tested under other conditions or using different test procedures.


Neither Midwest Research Institute nor the U. S. Government shall be liable for special, consequential or incidental damages. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States government or any agency thereof. The views and opinions of the authors expressed herein do not necessarily state or reflect those of the United States government or any agency thereof.

NREL is a National Laboratory of the U. S. Department of Energy, and as an adjunct of the U. S. Government, cannot certify wind turbines. The information in this report is limited to NREL's knowledge and understanding as of this date.

NREL is accredited by the American Association for Laboratory Accreditation (A2LA) and the results shown in this test report have been determined in accordance with the NREL's terms of accreditation unless stated otherwise in the report.

This report shall not be reproduced, except in full, without the written approval of Alliance or successor operator of NREL.

Approval By:  \_\_\_\_\_ 7/18/11  
Amy Curtis, NREL Test Engineer Date

Review By:  \_\_\_\_\_ 7/11/11  
Ismael Mendoza, NREL Test Engineer Date

## Table of Contents

1.0 Background.....	5
2.0 Test Summary .....	5
3.0 Continuous Operation Test Results .....	6
3.1 Wind Turbine Data.....	6
3.2 Active Power, Reactive Power and Power Factor.....	7
3.3 Line Voltage Distortions .....	10
3.4 Current Harmonics .....	11
3.5 Current Interharmonics .....	13
3.6 Current Distortions.....	14
3.7 Current and Voltage Imbalance.....	15
3.8 Continuous Operation Flicker .....	16
4.0 Switching Operation Tests Results .....	18
4.1 Turbine starts and stops.....	18
5.0 Exceptions.....	28
Appendix A. Test Matrix .....	29
Appendix B. Post Calibration Report .....	30

## List of Tables

Table 1: Gaia Wind 11-kW wind turbine general data .....	6
Table 2: Wind turbine rated data .....	6
Table 3: Maximum permitted power .....	6
Table 4: Number of data points per 1 m/s wind speed bins .....	7
Table 5: Data binned by real power .....	10
Table 6: Maximum instantaneous real and reactive power .....	10
Table 7: Maximum Current Harmonics (10 min averages) .....	11
Table 8: Current Interharmonics .....	13
Table 9: Current Distortions (2 - 9 kHz range) .....	14
Table 10: Resulting flicker coefficients in continuous operation .....	18
Table 11: Table of Figures for transient waveforms .....	18
Table 12. Characteristics of start at cut-in wind speed .....	27
Table 13. Characteristics of stop at cut-in wind speed .....	27
Table 14. Characteristics of start at rated wind speed .....	27
Table 15. Characteristics of stop at rated wind speed .....	28

## List of Figures

Figure 1: Turbulence intensity vs. wind speed .....	7
Figure 2: Active and reactive power vs. wind speed .....	8
Figure 3: Power factor vs. active power .....	9
Figure 4: Reactive Vs. Active Power .....	9
Figure 5: Current TDD Vs. Power .....	12
Figure 6: Voltage Imbalance Vs. Power .....	15
Figure 7: Current imbalance Vs. Power .....	15
Figure 8: $P_{st}$ vs. power for $30^\circ$ network impedance angle .....	16
Figure 9: $P_{st}$ vs. power for $50^\circ$ network impedance angle .....	16
Figure 10: $P_{st}$ vs. power for $70^\circ$ network impedance angle .....	17
Figure 11: $P_{st}$ vs. power for $85^\circ$ network impedance angle .....	17
Figure 12: Cut-in wind (4.8 m/s) start: current waveforms (August 19, 2009) .....	19
Figure 13: Cut-in wind (4.8 m/s) start: power and RMS voltage (August 19, 2009) .....	20
Figure 14: Rated wind (10.5 m/s) start, current waveforms (December 31, 2009) .....	21
Figure 15: Rated wind (10.5 m/s) start, power, and RMS voltage (December 31, 2009) .....	22
Figure 16: Cut-in wind (3.4 m/s) stop, current waveforms (August 19, 2009) .....	23
Figure 17: Cut-in wind (3.4 m/s) stop, power, and RMS voltage (August 19, 2009) .....	24
Figure 18: Rated wind (10.0 m/s) stop: current waveforms (December 31, 2009) .....	25
Figure 19: Rated wind (10.0 m/s) stop: power and RMS voltage (December 31, 2009) .....	26

## 1.0 Background

This test is being conducted as part of the U.S. Department of Energy's (DOE) Independent Testing project. This project was established to help reduce the barriers of wind energy expansion by providing independent testing results for small turbines. In total, five turbines are being tested at the NWTC as a part of this project. Power quality testing is one of up to five tests that may be performed on the turbines, including power performance, safety and function, noise, and duration tests. The results of the testing will provide the manufacturers with reports that may be used for small wind turbine certification.

## 2.0 Test Summary

This test was conducted in accordance with the International Electrotechnical Commission's (IEC) standard, Measurement and Assessment of Power Quality Characteristics of Grid Connected Wind Turbines, IEC61400-21, First Edition, 2001-12.

The power quality test for the Gaia Wind 11-kW wind turbine began on July 23, 2009 and ended on January 15, 2010. About 9,995 10-min intervals of data were collected while the turbine was available. The IEC 61400-21 Power Quality Standard requires at least five 10-min average data points for each 1 m/s wind speed bin for the wind turbulence intensity between 8 and 16%. This condition reduced the valid data to 1,021 10-min intervals. The highest bin filled (with no wind speed normalization) was the 14 m/s bin. When the data is binned by percent of rated power, more than five data points were recorded for each bin. According to the IEC 61400-21, not enough data was collected to fill the 15 m/s bin due to high turbulence intensity for the data points collected in the 15 m/s bin. The test matrix is given in Appendix A.

The test was conducted in accordance IEC 61400-21 Power Quality Standard and MEASNET procedures, and the following are the test results required by the standard and are included in this report:

- Maximum measured power (60-sec and 0.2-sec), reactive power demand
- Voltage fluctuations (flicker)
- Voltage harmonics, current harmonics, interharmonics and distortions
- Turbine start and stop tests

### 3.0 Continuous Operation Test Results

#### 3.1 Wind Turbine Data

**Table 1: Gaia Wind 11-kW wind turbine general data**

Turbine make, model, serial number, production year	Gaia-Wind 11-kW, 10711114, 2007
Wind turbine type	Horizontal axis
Number of blades	2
Hub height (m)	18.2
Blade control	None
Rotor diameter (m)	13
Speed control	Constant speed
Generator type and rating	Induction, 11 kW
Converter type	n/a

**Table 2: Wind turbine rated data**

Rated power, $P_n$ (kW)	11
Rated wind speed, $V_n$ (m/s)	9.5
Rated apparent power, $S_n$ (kVA)	13
Rated reactive power, $Q_n$ (kvar)	9.6
Rated current, $I_n$ (A)	16
Rated voltage, $V_n$ (V)	480

**Table 3: Maximum permitted power**

Peak continuous power, $P_{mc}$ (kW)	20
Normalized value, $p_{mc}=P_{mc}/P_n$	1.2

### 3.2 Active Power, Reactive Power and Power Factor

The relationship between active and reactive power was measured at the wind turbine low voltage (480 VAC) terminals. Only 10-min data points, with turbulence intensity within 8-16% range, were used for this analysis (Figure 1). Power measurements were sampled during continuous operation only, and taken so that at least five 10-min time series of power were collected for each 1 m/s wind speed (according to IEC 61400-21). The sampled data was transferred to 10-minute average data by applying block averaging for each 10-min period (Table 4 and Figure 2). The power factor (Figure 3) was calculated using active and reactive power values. The reactive power demand is shown in Figure 4.





Figure 1: Turbulence intensity vs. wind speed

Table 4: Number of data points per 1 m/s wind speed bins

Wind Speed Bin, m/s	Number of Valid 10 min Data Points
0 to 1	0
1 to 2	0
2 to 3	0
3 to 4	142
4 to 5	346
5 to 6	220
6 to 7	112

7 to 8	61
8 to 9	54
9 to 10	29
10 to 11	15
11 to 12	17
12 to 13	16
13 to 14	6
14 to 15	1



**Figure 2: Active and reactive power vs. wind speed**




Figure 3: Power factor vs. active power




Figure 4: Reactive Vs. Active Power

The 10-min average data was sorted according to the method of bins so that the reactive power could be specified for 0, 10, ..., 90, 100% of rated power (Table 5). The maximum active power was measured both as 60-sec (P60) and 0.2-sec average (P0.2)

values. The reactive power at  $P_{mc}$ ,  $P_{60}$ , and  $P_{0.2}$  was determined by extrapolation of the measured relation between the active and reactive power (Table 6).

**Table 5: Data binned by real power**

Power Bin (% of rated power)	Number of 10-min data points per bin	Output power, bin-mean-value (kW)	Reactive power, bin-mean-value (kVAR)
-5 to 5	161	0.238	-6.118
5 to 15	223	1.111	-5.695
15 to 25	182	2.180	-5.682
25 to 35	97	3.266	-5.844
35 to 45	86	4.325	-6.088
45 to 55	59	5.473	-6.493
55 to 65	43	6.594	-6.870
65 to 75	35	7.677	-7.116
75 to 85	38	8.795	-7.383
85 to 95	24	9.909	-7.807
95 to 105	25	10.932	-8.202
105 to 115	24	12.210	-8.792

**Table 6: Maximum instantaneous real and reactive power**

Max. permitted power, $P_{mc}$ :		60-sec average:		0.2-sec average:	
$P_{mc}$ , kW <b>15.00</b>	$p_{mc}=P_{mc}/P_n$ <b>1.36</b>	$P_{60}$ , kW <b>13.94</b>	$p_{60}=P_{60}/P_n$ <b>1.27</b>	$P_{0.2}$ , kW <b>19.62</b>	$p_{0.2}=P_{0.2}/P_n$ <b>1.78</b>
$Q_{mc}$ at $P_{mc}$ , kVAR <b>-10.51</b>	$q_{mc}=Q_{mc}/P_n$ <b>-0.96</b>	$Q_{60}$ at $P_{60}$ , kVAR <b>-9.78</b>	$q_{60}=Q_{60}/P_n$ <b>-0.89</b>	$Q_{0.2}$ at $P_{0.2}$ , kVAR <b>-15.77</b>	$q_{0.2}=Q_{0.2}/P_n$ <b>-1.43</b>

Note 1: Data were not normalized to sea-level density.

Note 2: The active power curve shown in Figure 2 may not be used for the Gaia Wind 11-kW wind turbine power performance evaluation. The official power curve will be published in the Gaia Wind 11-kW Power Performance Test Report.

### 3.3 Line Voltage Distortions

The average voltage Total Harmonic Distortions (THD) measured during the test are shown below for each phase:

Phase A – **2.028 %**

Phase B – **1.798 %**

Phase C – **1.734 %**

The maximum voltage THDs measured during the test are shown below for each phase:

Phase A – **4.163 %**

Phase B – **4.028 %**

Phase C – **3.595 %**

All voltage THDs were calculated from harmonic voltages. The harmonic voltages were subgrouped according to Section 5.6 of IEC 61000-4-7/CDV. The window width used during measurements  $T_w=12$ .

### 3.4 Current Harmonics

The individual harmonic currents during continuous operation were measured as 10-min average data for each harmonic order (up to 50th) at the output power giving the maximum individual harmonic current. The harmonic data and the maximum current Total Demand Distortion (TDD) values as a percentage of nominal current  $I_n$  are shown in Table 7. Figure 5 shows the plots of 10-min average data for maximum current TDD (% of  $I_n$ ) as a function of output power.

**Table 7: Maximum Current Harmonics (10 min averages)**

Order	Phase A		Phase B		Phase C	
	Power (kW)	Harm. current (%)	Power (kW)	Harm. current (%)	Power (kW)	Harm. current (%)
1	11.665	115.845	11.665	115.995	11.665	115.717
2	1.424	1.267	13.228	0.597	1.424	1.507
3	1.424	9.443	1.424	10.264	1.721	4.519
4	1.424	0.702	1.424	0.479	1.424	0.412
5	6.304	5.410	7.088	4.198	2.307	6.006
6	1.424	0.486	1.424	0.273	1.424	0.424
7	7.752	4.204	7.752	4.482	7.552	3.781
8	1.424	0.372	1.424	0.292	4.310	0.217
9	1.721	1.103	1.037	1.312	1.721	0.990
10	11.446	0.257	11.446	0.222	11.446	0.208
11	4.513	6.854	4.513	5.849	4.513	5.838
12	0.956	0.226	1.669	0.213	1.970	0.215
13	4.109	6.692	7.782	4.816	4.109	6.492
14	3.504	0.532	3.504	0.449	3.504	0.512
15	2.256	1.563	1.410	1.533	4.709	0.898
16	4.310	0.681	4.310	0.665	4.310	0.728
17	7.782	2.590	7.782	3.611	6.759	3.639
18	4.310	1.588	4.310	1.624	4.310	1.781
19	4.310	4.030	4.310	3.817	4.310	3.915
20	4.310	3.112	4.310	3.603	4.310	3.475
21	4.310	4.473	4.310	4.992	4.310	4.747
22	4.310	5.335	4.310	5.438	4.310	5.855
23	4.310	7.574	4.310	7.016	4.310	6.085
24	4.310	5.017	4.310	4.138	4.310	4.303
25	4.310	7.064	4.310	4.774	4.310	6.356
26	4.310	3.218	4.310	2.731	4.310	2.568
27	4.310	2.729	4.310	2.323	4.310	2.058
28	4.310	2.334	4.310	1.935	4.310	1.933

29	4.310	2.444	4.310	2.054	4.310	1.937
30	4.310	1.775	4.310	1.494	4.310	1.518
31	4.310	1.634	4.310	1.344	4.310	1.361
32	4.310	1.488	4.310	1.188	4.310	1.239
33	4.310	1.378	4.310	0.998	4.310	1.083
34	4.310	1.255	4.310	0.901	4.310	1.010
35	4.310	1.354	0.189	1.195	4.310	1.023
36	4.310	0.920	4.310	0.674	4.310	0.755
37	4.310	0.758	4.310	0.596	4.310	0.654
38	4.310	0.636	4.310	0.508	4.310	0.531
39	4.310	0.500	4.310	0.441	4.310	0.389
40	4.310	0.441	4.310	0.379	4.310	0.373
41	7.771	0.555	4.447	0.454	4.447	0.536
42	4.310	0.303	4.310	0.273	4.310	0.251
43	12.112	0.288	12.112	0.288	4.310	0.212
44	4.310	0.216	4.310	0.198	4.310	0.179
45	12.112	0.207	12.112	0.201	4.310	0.137
46	4.310	0.157	4.310	0.145	4.310	0.128
47	4.447	0.232	1.627	0.199	0.845	0.252
48	4.310	0.114	4.310	0.109	4.310	0.091
49	11.579	0.126	11.579	0.149	4.622	0.112
50	4.310	0.086	4.310	0.082	6.731	0.079

Max. phase A current TDD (% of $I_n$ ):	16.823	Output power at max current THD (kW):	12.780
Max. phase B current TDD (% of $I_n$ ):	15.113	Output power at max current THD (kW):	12.780
Max. phase C current TDD (% of $I_n$ ):	15.316	Output power at max current THD (kW):	12.780

The harmonic currents were subgrouped according to Section 5.6 of IEC 61000-4-7/CDV. The window width used during measurements was  $T_w=12$ .




Figure 5: Current TDD Vs. Power

### 3.5 Current Interharmonics

The individual interharmonic currents below 2 kHz are given in Table 8 as 10-min average values for each frequency at the output power giving the maximum individual interharmonic current.

**Table 8: Current Interharmonics**

f (Hz)	Phase A		Phase B		Phase C	
	Power (kW)	Interhar. current (%)	Power (kW)	Interhar. current (%)	Power (kW)	Interhar. current (%)
90	10.868	2.399	10.868	2.428	10.868	2.410
150	0.280	0.728	0.280	0.664	0.280	0.814
210	0.280	0.539	0.280	0.542	0.280	0.457
270	0.280	0.393	0.280	0.332	0.280	0.454
330	0.280	0.328	0.280	0.296	0.280	0.448
390	2.141	0.313	2.141	0.279	0.280	0.290
450	0.736	0.404	0.736	0.380	0.736	0.381
510	0.736	0.271	0.736	0.260	0.736	0.257
570	0.736	0.208	0.736	0.198	0.736	0.201
630	2.735	0.260	2.735	0.241	2.735	0.244
690	2.735	0.321	2.735	0.282	2.735	0.291
750	6.127	0.549	6.127	0.496	6.127	0.499
810	6.127	0.628	6.127	0.559	4.257	0.463
870	0.736	0.442	0.736	0.411	0.736	0.431
930	0.736	0.592	0.736	0.551	0.736	0.605
990	0.736	0.827	0.736	0.787	0.736	0.862
1050	0.736	1.231	0.736	1.199	0.736	1.315
1110	0.736	1.745	0.736	1.832	0.736	1.917
1170	0.736	2.380	0.736	2.733	0.736	2.636
1230	0.736	3.299	0.736	3.855	0.736	3.759
1290	0.736	4.413	0.736	4.923	0.736	5.014
1350	0.736	5.123	0.736	4.980	0.736	5.221
1410	0.736	5.086	0.736	4.348	0.736	4.464
1470	0.736	4.210	0.736	3.548	0.736	3.341
1530	0.736	3.417	0.736	2.884	0.736	2.609
1590	0.736	2.817	0.736	2.402	0.736	2.136
1650	0.736	2.434	0.736	2.065	0.736	1.898
1710	0.736	2.091	0.736	1.768	0.736	1.664
1770	0.736	1.821	0.736	1.552	0.736	1.499
1830	0.736	1.597	0.736	1.343	0.736	1.343
1890	0.736	1.452	0.736	1.189	0.736	1.221
1950	0.736	1.324	0.736	1.054	0.736	1.104
2010	0.736	1.234	0.736	0.927	0.736	1.001
2070	0.736	1.082	0.736	0.798	0.736	0.866
2130	0.736	0.958	0.736	0.696	0.736	0.777
2190	0.736	0.812	0.736	0.606	0.736	0.654
2250	0.736	0.672	0.736	0.528	0.736	0.551
2310	0.736	0.554	0.736	0.460	0.736	0.459
2370	0.736	0.458	0.736	0.397	0.736	0.382
2430	0.736	0.374	0.736	0.341	0.736	0.317
2490	0.736	0.323	0.736	0.297	0.736	0.276
2550	0.736	0.271	0.736	0.252	0.736	0.235
2610	0.736	0.233	0.736	0.216	0.736	0.200
2670	12.778	1.091	12.778	1.049	12.778	1.013
2730	0.736	0.175	0.736	0.164	6.127	0.163
2790	12.778	1.216	12.778	1.302	12.778	1.066

2850	6.127	0.146	6.127	0.135	6.127	0.153
2910	6.127	0.141	6.127	0.131	6.127	0.149
2970	6.127	0.138	6.127	0.128	6.127	0.145
3030	12.778	0.817	12.778	0.734	12.778	0.700

The interharmonic currents were subgrouped according to Annex A of IEC 61000-4-7/CDV. The window width used during measurements  $T_w=12$ .

### 3.6 Current Distortions

The individual current distortions in the range 2 kHz up to 9 kHz are given in Table 9 as 10-min average values for each frequency at the output power giving the maximum individual current distortion.

**Table 9: Current Distortions (2 - 9 kHz range)**

f (kHz)	Phase A		Phase B		Phase C	
	Power (kW)	Interhar. current (%)	Power (kW)	Interhar. current (%)	Power (kW)	Interhar. current (%)
0.1	12.793	117.017	12.793	117.322	12.793	119.634
0.3	4.644	6.863	4.644	5.452	4.644	6.972
0.5	7.752	4.236	7.752	4.502	7.552	3.803
0.7	1.037	8.403	1.037	6.910	4.109	7.523
0.9	2.149	3.642	2.149	3.749	2.149	3.807
1.1	1.231	11.490	1.231	12.014	1.231	11.859
1.3	2.149	47.437	2.149	56.479	2.149	40.754
1.5	2.149	38.814	2.149	29.895	2.149	31.273
1.7	1.231	11.770	1.231	10.320	1.231	8.660
1.9	1.231	6.658	1.231	5.841	1.231	5.816
2.1	2.149	14.726	2.149	13.327	2.149	14.368
2.3	2.149	14.279	2.149	11.802	2.149	11.549
2.5	2.149	2.349	2.149	1.851	2.149	1.890
2.7	1.231	2.275	1.231	2.106	1.231	2.077
2.9	2.149	7.109	2.149	6.443	2.149	6.227
3.1	1.231	1.477	1.231	1.445	1.231	1.358
3.3	2.149	0.463	2.149	0.378	2.149	0.417
3.5	2.149	1.189	2.149	1.062	2.149	1.146
3.7	2.149	0.911	1.231	0.784	2.149	0.792
3.9	2.149	0.265	2.149	0.234	2.149	0.197
4.1	2.149	0.346	2.149	0.256	1.231	0.276
4.3	1.231	1.019	1.231	0.735	1.231	0.862
4.5	2.149	0.307	1.231	0.284	2.149	0.239
4.7	1.231	0.254	1.231	0.267	1.231	0.208
4.9	1.231	0.610	1.231	0.659	1.231	0.656
5.1	1.231	0.621	1.231	0.619	1.231	0.424
5.3	1.231	0.145	1.231	0.162	1.231	0.151
5.5	1.231	0.193	1.231	0.198	1.231	0.169
5.7	1.231	0.322	1.231	0.273	1.231	0.301
5.9	1.231	0.268	1.231	0.289	1.231	0.196
6.1	1.231	0.135	1.231	0.113	1.231	0.111
6.3	1.231	0.090	1.231	0.100	1.231	0.086
6.5	1.231	0.128	1.231	0.136	1.231	0.129
6.7	2.149	0.070	2.149	0.074	1.231	0.060
6.9	2.149	0.065	1.231	0.065	1.231	0.055
7.1	2.149	0.078	2.149	0.079	2.904	0.077
7.3	2.149	0.086	2.149	0.073	2.149	0.069
7.5	2.149	0.060	2.149	0.061	1.231	0.050
7.7	2.149	0.064	2.149	0.063	2.149	0.055
7.9	2.149	0.087	2.149	0.083	2.149	0.076
8.1	2.149	0.062	2.149	0.065	2.149	0.054
8.3	2.149	0.057	1.231	0.059	1.231	0.049
8.5	1.231	0.064	2.149	0.064	2.149	0.063

8.7	2.149	0.064	2.149	0.063	2.149	0.055
8.9	2.149	0.053	2.149	0.054	1.231	0.047

The current distortions were measured and evaluated according to Annex B of IEC 61000-4-7/CDV. The window width used during measurements  $T_w=12$ .

### 3.7 Current and Voltage Imbalance

Figure 6 and Figure 7 show the voltage and current imbalance observed during the testing. The current and voltage imbalance was calculated for each 10-min period. The values are plotted against the average power of each 10-min data set.




Figure 6: Voltage Imbalance Vs. Power




Figure 7: Current imbalance Vs. Power

### 3.8 Continuous Operation Flicker

The flicker coefficients  $C(\Psi_k, V_a)$  were determined according to procedures listed in IEC61400-21. The flicker measuring and analysis methods are described in the standard. Total number of 10-min interval data collected for this test:  $N_{bin}=1021$ .

Figure 8, Figure 9, Figure 10, and Figure 11 show the graphs of fictitious grid flicker coefficients as a function of 10-min average active power for four different impedance phase angles ( $30^\circ$ ,  $50^\circ$ ,  $70^\circ$  and  $85^\circ$ ). The resulting flicker coefficients for continuous operation are shown in Table 10. The ratio between three-phase short circuit apparent power of the fictitious grid  $S_{k, fic}$  and turbine rated apparent power  $S_n$  used for the analysis is 50. During the power quality test there was a nearby dynamometer test and a neighboring turbine test that were both known to affect the power quality on the grid. These tests may have contributed to the variations in  $P_{st}$ .




Figure 8:  $P_{st}$  vs. power for  $30^\circ$  network impedance angle




Figure 9:  $P_{st}$  vs. power for  $50^\circ$  network impedance angle




Figure 10:  $P_{st}$  vs. power for  $70^\circ$  network impedance angle




Figure 11:  $P_{st}$  vs. power for  $85^\circ$  network impedance angle

The simulated flicker values  $P_{st}$  depend on  $S_{k, fic}$  and the grid impedance angle. To reduce this dependence, IEC 61400-21 defines flicker coefficients  $C(\Psi_k, V_a)$  which are calculated as a normalized quantity according to Equation 6 of the standard ( $\Psi_k$  - network impedance phase angle,  $V_a$  - annual average wind speed). The flicker coefficient of the wind turbine for the actual  $\Psi_k$  and  $V_a$  at the site, may be found from the Table 10 by applying linear interpolation.

**Table 10: Resulting flicker coefficients in continuous operation**

Network impedance phase angle, $\Psi_k$ (deg)	30°	50°	70°	85°
Annual average wind speed, $V_a$ (m/s)	Flicker coefficients, $C(\Psi_k, V_a)$			
6.0	98.42	116.35	125.85	122.40
7.5	97.77	116.35	122.18	119.08
8.5	97.18	116.35	121.93	118.65
10.0	96.37	116.35	120.92	117.95

## 4.0 Switching Operation Tests Results

### 4.1 Turbine starts and stops


Normal start tests were conducted at cut-in, moderate, and rated wind speeds. The wind speed was recorded during the tests along with voltage and current waveforms, and 10-min average wind speed during the switching operation was within  $\pm 2$  m/s of the required wind speed. The measurements were taken for a period long enough to ensure that the transient of the switching operation was abated, though limited to exclude possible power fluctuations due to turbulence. Table 11 lists the figure numbers for the current waveforms for all starting and stopping cases.

**Table 11: Table of Figures for transient waveforms**


Wind Regime	Starts	Stops
Cut-in	Figure 12, Figure 13	Figure 16, Figure 17
Rated	Figure 14, Figure 15	Figure 18, Figure 19

The active and reactive powers were calculated for each start and stop case. The time series RMS voltage for Phase A also are shown for each case to illustrate voltage fluctuations during switching operations.

The voltage and current time series were combined in Equation 1 of the standard to simulate fictitious voltage time series  $u_{fic}(t)$  for four different network impedance angles. The flicker step factors and voltage change factors were determined for each switching operation for four impedance angles (Table 12-15).



**Figure 12: Cut-in wind (4.8 m/s) start: current waveforms (August 19, 2009)**



**Figure 13: Cut-in wind (4.8 m/s) start: power and RMS voltage (August 19, 2009)**




Figure 14: Rated wind (10.5 m/s) start, current waveforms (December 31, 2009)




Figure 15: Rated wind (10.5 m/s) start, power, and RMS voltage (December 31, 2009)




Figure 16: Cut-in wind (3.4 m/s) stop, current waveforms (August 19, 2009)






Figure 17: Cut-in wind (3.4 m/s) stop, power, and RMS voltage (August 19, 2009)



**Figure 18: Rated wind (10.0 m/s) stop: current waveforms (December 31, 2009)**



**Figure 19: Rated wind (10.0 m/s) stop: power and RMS voltage (December 31, 2009)**

The maximum number of switching operations for 10-min and 120-min intervals ( $N_{10}$  and  $N_{120}$ ) for each type of switching operation was not provided by the turbine manufacturer. So, the  $N_{10}$  and  $N_{120}$  values were assumed based on the method given by IEC61400-21. The flicker step factor and voltage change factors were determined as the average results of five values are shown in the tables below.

**Table 12. Characteristics of start at cut-in wind speed**

Case of switching operation:	<i>Start at cut-in wind speed</i>			
Maximum number of switching operations, $N_{10}$ :	10			
Maximum number of switching operations, $N_{120}$ :	120			
Network impedance angle, $\Psi_k$	$30^\circ$	$50^\circ$	$70^\circ$	$85^\circ$
Flicker step factor, $k_f(\Psi_k)$ :	4.165	4.956	5.128	4.856
Voltage change factor, $k_U(\Psi_k)$ :	0.095	0.071	0.049	0.056

**Table 13. Characteristics of stop at cut-in wind speed**

Case of switching operation:	<i>Stop at cut-in wind speed</i>			
Maximum number of switching operations, $N_{10}$ :	10			
Maximum number of switching operations, $N_{120}$ :	120			
Network impedance angle, $\Psi_k$	$30^\circ$	$50^\circ$	$70^\circ$	$85^\circ$
Flicker step factor, $k_f(\Psi_k)$ :	1.167	1.067	0.892	0.753
Voltage change factor, $k_U(\Psi_k)$ :	0.029	0.039	0.048	0.048

**Table 14. Characteristics of start at rated wind speed**

Case of switching operation:	<i>Start at rated wind speed</i>			
Maximum number of switching operations, $N_{10}$ :	1			
Maximum number of switching operations, $N_{120}$ :	12			
Network impedance angle, $\Psi_k$	$30^\circ$	$50^\circ$	$70^\circ$	$85^\circ$
Flicker step factor, $k_f(\Psi_k)$ :	4.100	4.851	5.022	4.773
Voltage change factor, $k_U(\Psi_k)$ :	0.082	0.064	0.051	0.066

**Table 15. Characteristics of stop at rated wind speed**

Case of switching operation:	<i>Stop at rated wind speed</i>			
Maximum number of switching operations, $N_{10}$ :	1			
Maximum number of switching operations, $N_{120}$ :	12			
Network impedance angle, $\Psi_k$	$30^\circ$	$50^\circ$	$70^\circ$	$85^\circ$
Flicker step factor, $k_f(\Psi_k)$ :	1.544	1.171	1.001	1.046
Voltage change factor, $k_U(\Psi_k)$ :	0.056	0.062	0.066	0.067

The flicker step factor and voltage change factor of the wind turbine for the actual  $\Psi_k$  at the site can be found from the above tables by applying linear interpolation.

## 5.0 Exceptions

Exceptions to IEC61400-21:

- The current and voltage sensors used for this testing do not meet the Standard requirements for compliance with the IEC 60044-1 and IEC 60186 respectively, but they do exceed the minimum accuracy required by the Standard. This should have no effect on results or uncertainty.
- The 15 m/s wind speed bin was not filled because it is difficult for our site to have high wind speed within the 8% to 16% turbulence intensity required in the standard due to our diverse terrain.

## Appendix A. Test Matrix

Test Type	Measured	Required by IEC 61400-21 and MEASNET
Continuous operation: number of 10 min intervals	5 for each bin, except 15 m/s bin	At least 5 for each 1 m/s wind speed bin
Switching operation: number of wind turbine starts (cut- in wind speed)	5	At least 5
Switching operation: number of wind turbine stops (cut- in wind speed)	5	At least 5
Switching operation: number of wind turbine starts (rated wind speed)	5	At least 5
Switching operation: number of wind turbine stops (rated wind speed)	5	At least 5


# Appendix B. Post Calibration Report



## Calibration Report

Report #: NREL PQ Sampling System Cal (sn PQ04) 100125

Calibration of: NREL PQ Sampling System



**Calibration Method:** GI28 010717  
**Calibration Results:** Within tolerance  
**Device Condition:** good  
**Date Calibrated:** 1/25/10  
**Calibration Due Date:** 1/25/11  
**NREL Metrology Laboratory:** Ibrahim Reda

Senior Scientist-II  
 Date: 1/28/2010

**Environmental Conditions During Calibration**

Temperature: 23C, +/- 1C  
 Relative humidity: 40%, +/-10%

**Calibration Standard:**

Rotek Current Calibrator

Model: 8000A	Calibration Date: 7/29/05
Serial #: 267	Calibration Due Date: 7/29/06
DOE Tag: 126314	

Fluke Voltage Calibrator

Model: 5520A	Calibration Date: 8/3/05
Serial #: 7930013	Calibration Due Date: 8/3/06
DOE Tag: 126410	

Accuracy

Current (<50A):	0.036 % of setting	+	0.005 % of range
Current (>50A):	0.05 % of reading	+	0.008 % of range
Voltage:	0.03 % of reading	+	0.01 V

Full Scale Settings

Rotek 8000A Current:	200 A
Fluke 5520A Voltage:	700 V

**Unit Under Test (UUT):**

Current sensors

Model: SR759	Accuracy: 0.3 % of F.S.	Output: -1 to 1 V
Full scale: -100 100 A		Nominal Slope: 100
		Nominal Offset: 0

Voltage sensors

Model: LEM CV 3-1500	Accuracy: 0.2 % of F.S.	Output: -10 to 10 V
Full scale: -1500 1500 V		Nominal Slope: 150.00
		Nominal Offset: 0

Communication unit

Model: NI 9127	Filter cut-off: 25 kHz
----------------	------------------------

A/D Converter

Model: NI-9233
----------------

Combined accuracy of A/D Converter: 0.02 % of F.S.

**Uncertainty of UUT:**

Current Total Uncertainty = **0.30 A**  
 Voltage Total Uncertainty = **3.01 V**

Note:

1. The Test Uncertainty Ratio (TUR) = The uncertainty of the unit under test (UUT) divided by the uncertainty of the standard.
2. All uncertainties are calculated using the Volt or Amper values, not percentages.
3. The total uncertainty for the UUT is calculated as the RSS of the uncertainties of the current and voltage sensors, and A/D converter

### Current Measurements

ROTEK 8000A	Within Tolerance?	Unit Under Test						TUR
		Phase 1		Phase 2		Phase 3		
		V	Error, A	V	Error, A	V	Error, A	
RMS Current								
A								
0	Yes	0.000	0.02	0.000	0.01	0.002	0.19	30
2	Yes	0.020	0.01	0.020	0.01	0.020	-0.01	28
4	Yes	0.040	0.01	0.040	0.01	0.040	-0.01	26
6	Yes	0.060	0.01	0.060	0.00	0.060	-0.02	25
8	Yes	0.080	0.00	0.080	0.00	0.080	-0.02	23
10	Yes	0.100	0.00	0.100	-0.01	0.100	-0.02	22
12	Yes	0.120	-0.01	0.120	-0.01	0.120	-0.02	21
14	Yes	0.140	-0.01	0.140	-0.01	0.140	-0.02	20
16	Yes	0.160	-0.01	0.160	-0.02	0.160	-0.03	19
18	Yes	0.180	-0.02	0.180	-0.02	0.180	-0.03	18
20	Yes	0.200	-0.02	0.200	-0.03	0.200	-0.03	17
30	Yes	0.3	-0.04	0.301	0.05	0.3	-0.04	14
40	Yes	0.401	0.05	0.401	0.03	0.4	-0.05	12
50	Yes	0.501	0.03	0.501	0.01	0.501	0.04	11
60	Yes	0.601	0.01	0.601	-0.01	0.601	0.03	10
70	Yes	0.701	-0.01	0.701	-0.03	0.701	0.02	9
80	Yes	0.801	-0.02	0.801	-0.05	0.801	0.01	8
90	Yes	0.901	-0.04	0.902	0.03	0.901	0.00	7
100	Yes	1.002	0.04	1.002	0.01	1.001	-0.01	7

Calculated slope and offset:

Slope:	99.83	99.80	99.90
Offset:	0.0156183	0.01464	-0.0092

TUR is always >4

### Frequency Measurements

Fluke 5520A	Within Tolerance?	Unit under test	
		Wind Speed Input	
		Hz	Error, Hz
Frequency			
Hz			
100	Yes	100.000	-0.01
200	Yes	199.999	-0.01
300	Yes	300.009	0.00
400	Yes	400.009	0.01
500	Yes	500.004	0.00
600	Yes	600.006	0.00
800	Yes	800.008	0.01
1000	Yes	999.988	-0.01

Calculated slope and offset:

Slope:	1.00
Offset:	-0.0067166

## Voltage Measurements

Line-to-neutral or line-to-ground measurements

ROTEK 8000A		Unit Under Test						
RMS Voltage	Within Tolerance?	Phase 1		Phase 2		Phase 3		TUR
V		V	Error, V	V	Error, V	V	Error, V	
240	Yes	1.6	-0.03	1.6	-0.03	1.601	0.03	31
250	Yes	1.667	0.01	1.667	0.01	1.668	0.07	30
260	Yes	1.734	0.06	1.734	0.06	1.734	-0.04	29
270	Yes	1.8	-0.05	1.8	-0.05	1.801	0.00	28
277	Yes	1.847	0.00	1.847	0.00	1.847	-0.10	27
280	Yes	1.867	0.00	1.867	0.00	1.868	0.04	27
290	Yes	1.934	0.04	1.934	0.04	1.934	-0.06	26
300	Yes	2	-0.06	2	-0.06	2.001	-0.02	26
310	Yes	2.067	-0.02	2.067	-0.02	2.068	0.02	25
320	Yes	2.134	0.03	2.134	0.03	2.135	0.06	24

Calculated slope and offset:

Slope:	149.92	149.92	149.88
Offset:	0.0902444	0.09024	0.07042

TUR is always >4

