

Addendum to the Building America House Simulation Protocols

C. Engebrecht Metzger, E. Wilson,
and S. Horowitz
National Renewable Energy Laboratory

December 2012

NOTICE

This report was prepared as an account of work sponsored by an agency of the United States government. Neither the United States government nor any agency thereof, nor any of their employees, subcontractors, or affiliated partners makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States government or any agency thereof.

Available electronically at <http://www.osti.gov/bridge>

Available for a processing fee to U.S. Department of Energy
and its contractors, in paper, from:

U.S. Department of Energy
Office of Scientific and Technical Information
P.O. Box 62
Oak Ridge, TN 37831-0062
phone: 865.576.8401
fax: 865.576.5728
email: <mailto:reports@adonis.osti.gov>

Available for sale to the public, in paper, from:

U.S. Department of Commerce
National Technical Information Service
5285 Port Royal Road
Springfield, VA 22161
phone: 800.553.6847
fax: 703.605.6900
email: orders@ntis.fedworld.gov
online ordering: <http://www.ntis.gov/ordering.htm>



Printed on paper containing at least 50% wastepaper, including 20% postconsumer waste

Acknowledgments

The authors thank the following current and former National Renewable Energy Laboratory staff members for their significant contributions to the development of this document:

Ren Anderson
Dennis Barley
Jay Burch
Craig Christensen
Mark Eastment
Xia Fang
Rob Guglielmetti
Sara Farrar-Nagy
Kristin Field
Marcia Fratello
Michael Gestwick
Robert Hendron
Ron Judkoff
Neal Kruis
Ben Polly
Stacey Rothgeb
Jennifer Scheib
Paul Torcellini
Jon Winkler
Gail Werren
Stefanie Woodward

The authors would also like to thank Ed Hancock, Greg Barker, and Paul Reeves for their valuable technical contributions. In addition, the simulation experts for each of the Building America teams provided important new perspectives and critical assistance with the development of these protocols. Finally, we would like to express our gratitude to David Lee, Eric Werling, and Sam Rashkin of the U.S. Department of Energy for the program leadership and financial resources needed to complete this work over many years.

Addendum to the Building America House Simulation Protocols

Prepared for:

The National Renewable Energy Laboratory

On behalf of the U.S. Department of Energy's Building America Program

Office of Energy Efficiency and Renewable Energy

15013 Denver West Parkway

Golden, CO 80401

NREL Contract No. DE-AC36-08GO28308

Prepared by:

C. Engebrecht Metzger, E. Wilson, and S. Horowitz

National Renewable Energy Laboratory

15013 Denver West Parkway

Golden, CO 80401

December 2012

Definitions

AFUE	Annual Fuel Utilization Efficiency
ASHRAE	American Society of Heating, Refrigerating and Air-Conditioning Engineers
ASTM	American Society for Testing and Materials
BA	Building America
CEC	California Energy Commission
CFA	conditioned floor area
cfm	cubic feet per minute
COU	coefficient of utilization
DOE	U.S. Department of Energy
DOE-2	building energy analysis program that can predict the energy use and cost for all types of buildings
EF	energy factor
HSP	House Simulation Protocols
IECC	International Energy Conservation Code
IESNA	Illuminating Engineering Society of North America
MAT	monthly average temperature
MEL	miscellaneous electric load
NCTH	New Construction Test Home
NREL	National Renewable Energy Laboratory
NREMD	National Residential National Residential Efficiency Measures Database
SEER	seasonal energy efficiency ratio
SLA	specific leakage area

Contents

Acknowledgments	iii
Definitions	v
Introduction	1
Purpose of the House Simulation Protocols	1
Purpose of the Addendum to the House Simulation Protocols.....	2
Analysis Tools	2
1 New Construction	3
B10 Benchmark Specifications.....	3
1.1 Building Envelope	4
1.2 Space Conditioning/Air Distribution Equipment.....	6
1.3 Domestic Hot Water	7
1.4 Air Infiltration.....	8
1.5 Mechanical Ventilation.....	8
1.6 Lighting.....	9
1.7 Appliances and Miscellaneous Electric Loads	9
1.8 Site Generation.....	9
Modeling the NCTH	9
2 Existing Homes	10
Analysis Tools Specific to Existing Buildings	10
Pre-Retrofit Specifications.....	10
2.1 Building Envelope	10
2.2 Space Conditioning/Air Distribution Equipment.....	11
2.3 Domestic Hot Water	11
2.4 Air Infiltration and Ventilation	11
2.5 Lighting.....	11
2.6 Appliances and Miscellaneous Electric Loads	11
2.7 Site Generation.....	12
Modeling the Post-Retrofit Case.....	12
3 Operating Conditions	13
3.1 Vacation Periods	13
3.2 Space Conditioning.....	13
3.3 Domestic Hot Water	14
3.4 Lighting.....	14
3.5 Appliances and Miscellaneous Electric Loads	14
3.6 Occupancy.....	14
3.7 Internal Mass.....	14
4 Reporting Energy Use and Energy Savings	15
5 Overall Document Format	22
6 Bibliography	23

List of Tables

Table 1. Previous Benchmark Framing Factors	5
Table 2. New Benchmark Framing Factors	5
Table 3. Fenestration Assembly Characteristics	6
Table 4. Benchmark Space Conditioning Equipment Efficiencies	6
Table 5. Benchmark Domestic Hot Water Storage and Burner Capacity	7
Table 6. Determination of Benchmark Water Heater Location	8
Table 7. Benchmark Ventilation Specifications	9
Table 8. Natural Ventilation Seasonal Temperature Limits	13
Table 9. Cost Assumptions	16
Table 10. Cash Flow Assumptions	21

Introduction

Building America (BA) is an industry-driven research program sponsored by the U.S. Department of Energy (DOE) that applies systems engineering approaches to accelerate the development and adoption of advanced building energy technologies in new and existing residential buildings. This program supports multiple building research teams in the production of advanced residential buildings on a community scale. These teams use a systems engineering process to perform cost and performance assessments to improve each builder or retrofit contractor's standard practice; the overall goal is to significantly reduce energy use with only a nominal increase in initial construction costs. The energy efficiency concepts incorporated into these houses are evaluated by conducting successive design, test, redesign, and retest iterations. This process results in innovations that can be used cost effectively in production-scale housing.

Additional goals of the BA program are to:

- Encourage a systems engineering approach in the design and construction of new homes and retrofits.
- Accelerate the development and adoption of high performance residential energy systems.
- Improve indoor air quality, comfort, and durability.
- Integrate clean onsite power systems.

Purpose of the House Simulation Protocols

As BA has grown to include a large and diverse cross-section of the home building and retrofit industries, it has become more important to develop accurate, consistent analysis techniques to measure progress towards the program's goals. The House Simulation Protocol (HSP) document provides guidance to program partners and managers so they can compare energy savings for new construction and retrofit projects. The HSP provides the program with analysis methods that are proven to be effective and reliable in investigating the energy use of advanced energy systems and of entire houses.

The HSP document is divided into three sections.

- Section 1 provides information about program design assumptions and analysis methods for **new construction**. In new construction, the project house (also known as prototype, or New Construction Test Home [NCTH]) is compared to a reference building that represents a "typical" code-built house at the time of the contract recompetition. The most recent contract recompetition was in 2010, so this benchmark house is referred to as the "B10 Benchmark" hereafter in this document.
- Section 2 provides similar information for the analysis of **existing homes**, including design assumptions and analysis methods for comparing pre-retrofit to post-retrofit homes. Using as many aspects of the real house as possible, this section also provides default values for components of an existing house with unknown performance characteristics.

- Section 3 provides information about standard **operating conditions** for the analysis of new and existing homes. Standard user profiles, which represent an average of many occupants rather than actual profiles for an average or typical set of occupants, were developed based on review of the available literature.

Purpose of the Addendum to the House Simulation Protocols

Traditionally, the HSP has been updated annually to incorporate newly available research results. This year, BA is taking a new approach to this update, in which an addendum to the changes is released first. A public comment period will be offered so the changes can be tested and vetted before they are final.

Specifically, one of the major goals this year for the HSP is to provide the opportunity to plot the benchmark building on BEopt optimization curves (Christensen et al. 2006)¹. To do this, it is necessary to have physical options that can have costs associated with each measure. Fortunately, NREL also recently developed the National Residential Efficiency Measures Database (NREMD), which includes costs for all types of measures. View the NREMD at: <http://www.nrel.gov/ap/retrofits/about.cfm>.

This addendum follows the same structure as the HSP and notes cases in which no changes were made.

Analysis Tools

A key decision in any building energy analysis is determining which tool or program to use to estimate energy consumption. An hourly simulation is often necessary to fully evaluate the time-dependent energy impacts of advanced systems used in BA houses. Thermal mass, solar heat gain, and wind-induced air infiltration are examples of time-dependent effects that can be accurately modeled only by using a model that calculates heat transfer and temperature in short time intervals. An hourly simulation program is also necessary to accurately estimate peak energy loads. Because it has been specifically developed and tailored to meet BA's needs, BEopt (using either DOE-2 or EnergyPlus as the simulation engine) is the hourly simulation tool recommended for systems analysis studies performed under the DOE BA program.

The BA teams are also encouraged to use other simulation tools when appropriate for specialized building simulation analysis (new technologies, some multifamily projects, etc.), provided the tool has met the requirements of the Building Energy Simulation Test and Diagnostic Method in accordance with the software certification sections of RESNET (2006). Regardless of the tool selected, teams should present complete analysis results in their final project summaries.

¹ The National Renewable Energy Laboratory (NREL) developed BEopt to simulate residential building energy performance.

1 New Construction

To track progress toward aggressive multiyear, whole-house energy savings goals of 30%–50% for new homes, NREL developed the concept of a new construction reference building that represents the “typical” code-built house at the time of the contract recompetition. The most recent contract recompetition was in 2010, so this reference building is called the “B10 Benchmark” or “Benchmark” in this document. This reference building is generally consistent with the 2009 International Energy Conservation Code (IECC), with additional definitions that enable the analyst to evaluate all residential end uses consistent with typical homes built in 2010.

The goal is to essentially maintain the energy performance of the Benchmark construction throughout the contract period (in this case, through the end of calendar year 2014). However, updating the HSP is beneficial when a statement needs further clarification, or when more accurate information becomes available through research. These types of changes do not affect the overall reference point-in-time of the building.

A series of user profiles, intended to be an average over many homes, rather than the behavior of an individual set of typical occupants, was created for use in conjunction with the Benchmark. The Benchmark is intended for use with detached and attached single-family housing, as well as multifamily housing.

The following house designs shall be included as part of the analysis of a new home design:

B10 Benchmark. A reference case representing a house built to the 2009 IECC, as well as the federal appliance standards in effect as of January 1, 2010, and lighting characteristics and miscellaneous electric loads (MELs) most common in 2010. The Benchmark is used as the point of reference for tracking progress toward multiyear energy savings goals established by BA.

NCTH. A research home or prototype home built as part of a community-scale project that includes advanced systems and design features built as part of the BA program.

B10 Benchmark Specifications

The following sections summarize the Benchmark definition. NREL and other BA partners have also developed a series of tools, including spreadsheets with detailed hourly energy use and load profiles, to help analysts quickly and consistently apply the Benchmark. These tools are available on the BA website

(http://www1.eere.energy.gov/buildings/residential/ba_house_simulation.html). BEopt can also automatically simulate the Benchmark when the specifications for an NCTH are entered.

The Benchmark may be applied to either a single-family or a multifamily home. A single-family home is contained within walls that go from the basement or the ground floor (if there is no basement) to the roof. A single-family attached home is defined as a residence that shares one or more walls with another unit. This definition includes, but is not limited to, duplexes, row houses, and townhomes.

A multifamily home (or multifamily building) has at least five housing units. Each unit must share at least a floor or a ceiling with another unit.² Also, a given multifamily building may have no more than three stories; otherwise, it is considered a commercial building, which is outside the scope of this document. These definitions are consistent with those provided by the DOE Residential Energy Consumption Survey (DOE 2005) database (except the requirement on the number of units).

1.1 Building Envelope

Modification 1.1.1—Modeling the Benchmark, Second Bullet

Language was added to clarify this statement, which now reads, “...and for climate zones 3 through 8, the *basement or* crawlspace, which shall be unvented and insulated at the walls...” This was simply a clarification of the basement insulation location, which was omitted in previous versions. The crawlspace and basement of the Benchmark will always be unvented and the floor will not be insulated in any case. Climate zones 1 and 2 will have unvented crawlspaces but no insulation anywhere.

Modification 1.1.2—Modeling the Benchmark, Fourth Bullet

The basement wall construction for the Benchmark building will be fixed at 8 in. of concrete instead of being the same type of construction as the NCTH. This decision is driven by the desire to cost a more fixed Benchmark building.

Modification 1.1.3—Modeling the Benchmark, New Bullet

Because BEopt has added capability, the following new language was added: “Surfaces adjacent to neighboring units (attached walls, floors, and ceilings) shall be modeled as adiabatic for both the Benchmark and NCTH.”

Modification 1.1.4—Window Analysis, Option 2

Currently, option 2 allows for equally distributed window area on each of the four walls (including attached walls). The goal of this analysis technique is to have the glazing influences on energy use become independent of the NCTH orientation. To maintain the goal of the fixed Benchmark building, the front door will now be fixed in the north-facing position, rather than following the NCTH. The latest version of BEopt will use option 2 with a fixed orientation, which will keep the simulation run time as low as possible.

Modification 1.1.5—Insulated Ceiling Analysis

There is an inherent decrease in attic floor insulation levels near the attic perimeter and roof edges with most common construction practices. In the past, the HSP specified a workaround to model this effect by slightly increasing the ceiling framing factor. BEopt can now calculate the effect of the reduced insulation depth at roof edges, accounting for roof type, roof pitch, eave depth, and insulation thickness.

² The qualifications for a project being labeled “multifamily” will be discussed in 2013.

Modification 1.1.6—Cathedral Ceilings

To provide similar guidance to the IECC 2009, cathedral ceilings in the reference building (Benchmark in this case) required only R-30 in all climates. After much discussion, it was decided that in the future, all cathedral ceilings in the Benchmark building shall be modeled with the same insulation levels that are required in all other ceilings.

Modification 1.1.7—Attached Walls Analysis

Going forward, the Benchmark shall be modeled with attached walls where the NCTH has attached walls.

Modification 1.1.8—Benchmark Framing Factors

The framing factors for the Benchmark wood-framed walls in the HSP have been inconsistent with BEopt (see previous HSP values in Table 1).

Table 1. Previous Benchmark Framing Factors

Enclosure Element	Frame Spacing (in. on center)	Framing Fraction (% area)
Walls (Above Grade)	16	23%
Floors/Basement Ceiling/Crawlspace Ceiling	16	13%
Ceilings Below Unconditioned Space	24	11%

To make these values consistent and referenceable, wood-framed walls shall have the framing factors listed in Table 2. These are referenced from the ASHRAE (2009). Ceiling framing factors in Table 2 reflect the fact that BEopt now accounts for the attic perimeter insulation taper effect.

Table 2. New Benchmark Framing Factors

Enclosure Element	Frame Spacing (in. on center)	Framing Fraction (% area)
2 × 4 Walls (Above Grade)	16	25% ³
2 × 6 Walls (Above Grade)	24	22% ³
Floors/Basement Ceiling	16	13%
Ceilings Below Unconditioned Space	24	7%
Roof, When Insulated At Roof	24	7%

³ 2009 ASHRAE Handbook Fundamentals (I-P Edition), p.27.3

Modification 1.9—Benchmark Fenestration

Because of the desire to cost the Benchmark, it is important to have the values associated with the Benchmark window properties to be more realistic and to reflect real-world availability and still comply with IECC 2009. Real windows that were chosen were similar for similar climates. (See Table 3.)

Table 3. Fenestration Assembly Characteristics

Climate Zone	Vertical Fenestration U-Value (U _F) (Btu/h·ft ² ·°F)	Vertical Fenestration Solar Heat Gain Coefficient
1 to 3	0.37	0.30
4 to 8	0.35	0.44

Modification 1.10—Solar Absorptivity of Roofs

The solar absorptivity of roofs shall be equal to 0.85, which corresponds with medium-colored asphalt shingles. These are some of the most common shingles applied to new construction homes, and the Benchmark building should reflect that.

1.2 Space Conditioning/Air Distribution Equipment

Modification 1.2.1—Space Conditioning Equipment Type and Efficiency⁴

In line with the goal to create a fixed Benchmark that can be graphed on a BEopt curve, the space conditioning equipment and fuel types for the Benchmark building are now fixed. (See Table 4 for details.) In the 2010 HSP, an NCTH with electric baseboard heat would be compared to a Benchmark building with a 7.7 heating seasonal performance factor (HSPF)/13 seasonal energy efficiency ratio (SEER) air source heat pump.

Table 4. Benchmark Space Conditioning Equipment Efficiencies

Function	Benchmark Space Conditioning Device
Heating	78% AFUE* gas furnace
Cooling	13 SEER air conditioner

* Annual Fuel Utilization Efficiency

Modification 1.2.2—Stand-Alone Dehumidification

Because research is still being conducted on the issue of universally recommending stand-alone dehumidification in homes, the Benchmark shall not include a stand-alone dehumidifier, regardless of whether the NCTH actively controls relative humidity.

⁴ This change will be further analyzed in the year 2013 to determine the exact impact on BA analysis.

Modification 1.2.3 – Number of Stories

The following language will be added to the HSP that states, “For purposes of specifying the Benchmark duct system, the number of stories is defined as each level of living space in the home, including basements (finished and unfinished) and finished attics.”

Modification 1.2.4—Duct Return Registers

To properly cost the Benchmark building, the number of return ducts must be fixed (instead of dependent on NCTH, as currently written). For single-family detached homes, the number of returns is equal to 1 plus the number of stories in the home. For multifamily and attached homes, the number of returns shall be equal to zero, which signifies that the only return is directly into the air handler with no ducts. Values chosen here were based on field experience from the Consortium for Advanced Residential Buildings (CARB), IBACOS, and NREL teams.

Modification 1.2.5—Duct Insulation Levels

For ducts to be part of a plottable Benchmark house that is not dependent on the options in the NCTH, the insulation levels were changed to R-6 for all duct locations. Previously, the Benchmark building was consistent with IECC 2009, which specified that supply ducts in unconditioned attics have an insulation level of R-8.

1.3 Domestic Hot Water

Modification 1.3.1—Hot Water Equipment Type and Efficiency

Due to the goal of costing the Benchmark building, the Benchmark shall now have a fixed water heating type and efficiency (as opposed to changing depending on the NCTH). The Benchmark shall use a natural gas storage-type water heater, with recovery efficiency of 0.78.⁵ The volume, energy factor (EF), capacity, and tank location are specified in Table 5 and Table 6. EF must comply with the federal minimum standard ($0.67 - 0.0019 \times V$) for the corresponding storage capacity (DOE 2001a). Real combinations of storage capacity, EF, and burner capacity are important for costing, so values in Table 5 were obtained from NREMD.

Table 5. Benchmark Domestic Hot Water Storage and Burner Capacity

# Bedrooms	1–2	3		4		5	6
# Bathrooms	All	≤ 1.5	≥ 2	≤ 2.5	≥ 3	All	All
Storage (gal)	30	30	40	40	50	50	50
EF	0.61	0.61	0.59	0.59	0.58	0.58	0.58
Gas Burner (kBtu/h)	36	36	36	36	38	47	50

Source: ASHRAE 2007b and NREMD

⁵ This change will be further analyzed in the year 2013 to determine the exact impact on energy savings models.

Table 6. Determination of Benchmark Water Heater Location

BA Climate Zone	Benchmark Water Heater Location
Hot-Humid, Hot-Dry	Attached garage if one exists, otherwise in conditioned space
Marine, Mixed-Humid, Cold, Very Cold, Subarctic	Basement if one exists, otherwise in conditioned space

Source: Lstiburek 1999

1.4 Air Infiltration

Modification 1.4.1—Separation of Infiltration and Ventilation

The written HSP document will now have section separation between Infiltration and Mechanical Ventilation.

Modification 1.4.2—SLA to ACH50

Because the ACH50 metric is predominant (compared with specific leakage area [SLA]), the Benchmark air infiltration shall be specified in ACH50. The new Benchmark airtightness metric is 7 ACH50. The teams may now report infiltration in the form of ACH50.

Equation 6 in the HSP (which references above-ground basement wall area) will be removed. Above-grade basement walls cannot be modeled in BEopt at this time.⁶

1.5 Mechanical Ventilation

Modification 1.5.1—Benchmark Ventilation Rate

To accommodate costing the Benchmark, the ventilation rate for the Benchmark building shall be a single-point exhaust ventilation system, consistent with ASHRAE 62.2.

There is much debate on the appropriate ventilation rate for homes. This is one case where more research is needed. The authors would like the analysts to remember that the Benchmark building is simply a reference point for comparing homes to each other. The ASHRAE 62.2 standard is used because it can be referenced.

Modification 1.5.2—Exhaust Fan Flow Rates in Benchmark

Previously, some details about exhaust fan flow rates were not clear in the Benchmark specifications. Details are now presented in the HSP (see Table 7).

⁶ The best workaround for above-grade basement wall area is to increase the wall height of the first floor equal to the above-grade basement wall height.

Table 7. Benchmark Ventilation Specifications

Ventilation Type	Flow Rate (cfm)	Power (W/cfm)	Time
Kitchen Spot Exhaust	100	0.30	6:00 p.m.–7:00 p.m.
Bathroom Spot Exhaust	50 per bathroom	0.30	7:00 a.m.–8:00 a.m.
Whole-House Ventilation	Per ASHRAE 62.2	0.30	All-day
Clothes Dryer	100	*	11:00 a.m.–12:00 p.m.

* Clothes dryer fan power is already included in clothes dryer appliance energy. The authors realize the inconsistency between the profile of the electricity use (spread out over a day) and ventilation (one hour discrete event) of the clothes dryer. The authors will explore this difference during discussions with the teams in 2013.

The NCTH shall also provide whole-house mechanical ventilation consistent with ASHRAE Standard 62.2, or provide justification otherwise. It is important for the program to require ventilation rates consistent with ASHRAE 62.2 at this time so that decreased ventilation rates are not used as an energy efficiency measure.

1.6 Lighting

Modification 1.6.1—Lighting Takeback Effect

Clarification: In all calculations, a takeback is included in the form of an increase in operating hours when incandescent lamps are replaced with energy-efficient lamps (Greening et al. 2000). The takeback factor is proportional to the ratio of the NCTH and Benchmark average efficacies. The modified operating hours are calculated using equation 1:

$$\text{Operating Hours} = \left[0.9 + 0.1 \left(\frac{\text{Efficacy, NCTH}}{\text{Efficacy, Benchmark}} \right) \right] \times \text{Operating Hours, Benchmark} \quad (1)$$

1.7 Appliances and Miscellaneous Electric Loads

Modification 1.7.1—Fixed Appliance Type

Because the goal is to simplify the Benchmark building so that it may be graphed on a BEopt curve, the cooking range and clothes dryer will now be modeled as electric appliances in the Benchmark building, regardless of the NCTH.

1.8 Site Generation

No modifications.

Modeling the NCTH

No modifications.

2 Existing Homes

This section in the HSP provides a set of guidelines for estimating the energy savings achieved by a package of retrofits or an extensive rehabilitation of an existing home. BA developed a set of standard operating conditions that will be used for a building simulation model to objectively compare energy use before and after a series of retrofits is completed. Actual occupant behavior is extremely important for determining the cost effectiveness of a retrofit package, especially if the homeowner is paying the bills. But for tracking progress toward programmatic goals, and for comparing the performance of one house to another, a hypothetical set of occupants with typical behavioral patterns must be used.

Certain field test and audit methods are also described. These tests help establish accurate building system performance characteristics that are needed for a meaningful simulation of whole-house energy use. Several sets of default efficiency values have also been developed for certain older appliances that cannot be easily tested and for which published specifications are not readily available.

Analysis Tools Specific to Existing Buildings

NREL does not recommend that utility bills be heavily relied on as a tool for model validation in the context of research houses, except as an approximate check of model accuracy. There are two important reasons for this position:

- Occupant behavior is extremely difficult to determine accurately during the period reflected in the utility bills.
- The large number of uncertain input parameters allows multiple ways to reconcile the model with the small number of utility bills, and there is no reliable methodology for performing this calibration because the problem is mathematically undetermined.

Instead, detailed inspections, short-term testing, and long-term monitoring should be used to the greatest extent possible to minimize the uncertainty in model inputs. Default values may be used when certain building features are inaccessible (wall insulation) or efficiency characteristics cannot be readily determined through inspection or short-term testing (furnace AFUE).

Throughout the remainder of this section, the term *pre-retrofit case* refers to the state of an existing house immediately before it undergoes a series of upgrades, repairs, additions, or renovations. These measures may be limited to a focused set of energy efficiency improvements or may be part of a larger remodeling or gut rehabilitation effort. The term *post-retrofit case* refers to the same existing house after the package of improvements is complete.

Pre-Retrofit Specifications

Any element of the pre-retrofit case that is not specifically addressed in the corresponding HSP sections, or is not changed as part of the package of energy efficiency measures, is assumed to be the same as the post-retrofit case.

2.1 Building Envelope

No modifications.

2.2 Space Conditioning/Air Distribution Equipment

Modification 2.2.1—Maintenance Factors

When true equipment efficiency has not been tested, default values for simulations are provided in the HSP document. Previously, the HSP values projected a decrease in efficiency over time for all types of heating and cooling equipment. Values were dependent on different levels of homeowner maintenance. Further research did not verify whether all types of equipment degrade over time; thus, installation quality may be a more significant performance factor than age. More data are needed in this area.

Until more data are available on the performance of the same installed equipment over many years, the authors have decided to remove the maintenance factor equations.

A point of clarification is the use (or nonuse) of filters. In homes that have no filters or have significant filter bypass, coil fouling can lead to severe equipment degradation. However, because this usually leads to equipment failure and eventual replacement of the filter and cleaning of the coils, the authors have decided not to include this type of incident in the calculation.

The decision is further backed by the requirement of a degradation equation that pertains to a single piece of equipment over its lifetime. With instances of failure and subsequent repair, there is no degradation equation that would capture such neglect.

2.3 Domestic Hot Water

No modifications.

2.4 Air Infiltration and Ventilation

Modification 2.4.1—Infiltration Units

For the same reasons as discussed in the New Construction section, SLA values for existing homes will now be represented as ACH50 values in BEopt.

2.5 Lighting

Modification 2.5.1—Lighting Analysis Clarification

If the home is unoccupied at the time of the pre-retrofit lighting audit, the pre-retrofit model should include additional plug-in lighting to meet Illuminating Engineering Society of North America (IESNA) illumination levels (Rea et al. 2000). If the home is occupied at the time of the lighting audit, no additional lighting is necessary; actual installed lighting levels should be used for the analysis.

2.6 Appliances and Miscellaneous Electric Loads

Modification 2.6.1—Default Internal Loads, Table Typographical Errors

Two typographical errors in the table titled, “Default Internal Loads From Appliances and Small Electric End Uses in the Pre-Retrofit Case” were corrected. MELs sensible load fraction is actually 0.74 and latent load fraction is actually 0.02. The BA analysis spreadsheet did not have these errors.

2.7 Site Generation

No modifications.

Modeling the Post-Retrofit Case

Modification—Post-Retrofit Lighting Modeling

Previously, modeled post-retrofit lighting levels were specified to match those in the post-retrofit home. A slight change was made to declare that if the actual post-retrofit lighting levels do not meet IESNA guidelines in an effort to conserve more energy, the post-retrofit home shall be modeled with IESNA lighting levels.

3 Operating Conditions

Operating conditions in the HSP shall apply to all simulations conducted for official BA reporting purposes, including the analysis of new homes and retrofits of existing homes, unless otherwise specified.

Modification 3.1—Modeling Clarification

For technologies such as ceiling fans that are designed to save energy related to operating conditions, the NCTH may use operating conditions that differ from those required for the Benchmark building. A published reference that proves those specific operating conditions can be changed and maintain occupant comfort, must be included in the analysis section of the related reports for the team to implement those changes in BEopt. The Benchmark shall always use the operating conditions outlined in the HSP.

3.1 Vacation Periods

No modifications.

3.2 Space Conditioning

Modification 3.2.1—Monthly Average Temperature (MAT) Basis

A clarification was made so that the MAT measurement is less than 66°F for heating and greater than *or equal to* 66°F for cooling.

Modification 3.2.2—Dehumidification Simulation

Because the requirement for blanket stand-alone dehumidification is still in the early research phase, the Benchmark shall not be modeled with a stand-alone dehumidifier, regardless of whether the NCTH actively controls relative humidity.

Modification 3.2.3—Natural Ventilation

Previously, the logic for the natural ventilation stated that the windows were assumed to be closed once the indoor temperature dropped below 1°F above the heating set point. This could lead to overcooling during the heating season. Table 8 shows a new set of parameters that uses natural ventilation more intelligently throughout all seasons.

Table 8. Natural Ventilation Seasonal Temperature Limits

Season	Windows Close If Indoor Temperature Drops Below:
Heating Only	75°F (1°F below cooling set point)
Cooling Only	72°F (1°F above heating set point)
Both Heating and Cooling Enabled	72°F (1°F above heating set point)

Windows in BEopt will only open if natural ventilation can meet the cooling load for that hour.

3.3 Domestic Hot Water

No modifications.

3.4 Lighting

No modifications.

3.5 Appliances and Miscellaneous Electric Loads

No modifications.

3.6 Occupancy

No modifications.

3.7 Internal Mass

No modifications.

4 Reporting Energy Use and Energy Savings

Modification 4.1—Cost Assumptions

The motivation for some of the changes addressed in this report is to respond to the frequent requests made to have real costs associated with the Benchmark building. Table 9 shows the default values for the Benchmark house and their associated costs. These costs can be selected automatically in the BEopt software, by choosing “B10 Benchmark” as the reference building.

There are two possible reasons a category is listed, but no cost is listed: (1) the option (for example, natural ventilation/opening windows) has no associated cost; and (2) it appears in BEopt, and is therefore part of this list, but is not part of the Benchmark building (for example, electric baseboards).

These costs are currently consistent with the NREMD. Because this database is dynamic and changes as more relevant data become available, these values may change over time. However, the units will likely remain consistent.

Table 9. Cost Assumptions

Group	Category	Option	BA Zone(s)	Cost	Cost Units	2 nd Cost	2 nd Cost Units
Building	Orientation	North	All	0	\$		
	Neighbors	North	All	0	\$		
Operation	Heating set point	71°F	All	0	\$		
	Cooling set point	76°F	All	0	\$		
	Humidity set point	60% relative humidity	All	0	\$		
	MELs	1	All	0	\$		
	Miscellaneous gas loads	1	All	0	\$		
	Natural ventilation	Benchmark	All	0	\$		
	Interior shading	Benchmark	All	0	\$		
Walls	Wood Stud						
		R-13 fiberglass batt, Gr-1, 2 × 4, 16 in. o.c.	1,2,3,4	3.4	\$/ft ² net exterior wall		
		R-21 fiberglass batt, Gr-1, 2 × 6, 24 in. o.c.	7,8	3.5	\$/ft ² net exterior wall		
		R-13 fiberglass batt, Gr-1, 2 × 4, 16 in. o.c., R-5 XPS	4C,5,6	4.4	\$/ft ² net exterior wall		
	Double wood stud	None	All	0	\$		
	Concrete masonry unit	None	All	0	\$		
	Structurally insulated panel	None	All	0	\$		
	Insulating concrete form	None	All	0	\$		
	Other	None	All	0	\$		
	Exterior finish	Medium/dark stucco ⁷	All	5.3	\$/ft ² Exterior		

⁷ This default value will be discussed in 2013 to determine the most “standard” across the country

					Wall			
	Interzonal (e.g., between attached garage and conditioned space) walls							
		R-13 fiberglass batt, Gr 1, 2 × 4, 16 in. o.c.	1,2,3,4	2.6	\$/ft ² wall			
		R-21 fiberglass batt, Gr 1, 2 × 6, 24 in. o.c.	7,8	2.7	\$/ft ² wall			
	R-13 fiberglass batt, Gr 1, 2 × 4, 16 in. o.c., R-5 XPS	4C,5,6	3.6	\$/ft ² wall				
Ceilings/ Roofs	Unfinished attic							
		Ceiling R-30 cellulose, vented	1,2,3	0.95	\$/ft ² ceiling			
		Ceiling R-38 cellulose, vented	4,4C,5	1.1	\$/ft ² ceiling			
		Ceiling R-49 cellulose, vented	6,7,8	1.2	\$/ft ² ceiling			
	Finished roof							
		R-30C fiberglass batt, 2 × 10	1,2,3	2.1	\$/ft ² roof			
		R-38C fiberglass batt, 2 × 12	4,4C,5	2.7	\$/ft ² roof			
		R-30 + R-19 fiberglass batt	6,7,8	3.2	\$/ft ² roof			
		Roof material	Asphalt shingles, medium	All	1.8	\$/ft ² roof		
		Radiant barrier	None	All	0	\$		
Foundation/ Floors	Slab							
		Uninsulated	1,2,3					
		2-ft R-10 perimeter, R-5 gap	4,4C,5	1.9	\$/ft ² slab insulation (perimeter)	1.2	\$/ft ² gap insulation	
		4-ft R-10 perimeter, R-5 gap	6,7,8	1.9	\$/ft ² slab insulation (perimeter)	1.2	\$/ft ² gap insulation	
	Finished Basement							
	Uninsulated	1,2,3						

		Wall 8-ft R-10 XPS, furring strips, 0.5 in. gypsum board ⁸	4,4C,5	2.7	\$/ft ² wall		
		Wall 8-ft R-15 XPS, furring strips, 0.5-in. gypsum board	6,7,8	3.3	\$/ft ² wall		
	Unfinished Basement						
		Uninsulated	1,2,3				
		Whole Wall, R-10 XPS, furring strips, 0.5-in. gypsum board	4,4C,5	2.7	\$/ft ² basement wall		
		Whole Wall, R-15 XPS, furring strips, 0.5-in. gypsum board	6,7,8	3.3	\$/ft ² Basement Wall		
	Crawlspace						
		Uninsulated, vented	1,2				
		Wall R-5 XPS, unvented	3	0.84	\$/ft ² floor	0.97	\$/ft ² wall
		Wall R-10 XPS, unvented	4,4C,5,6,7,8	0.84	\$/ft ² floor	1.5	\$/ft ² wall
	Interzonal floor						
		R-13 fiberglass batt	1,2	0.68	\$/ft ² floor		
		R-19 fiberglass batt	3,4	0.81	\$/ft ² floor		
		R-30 fiberglass batt	4C,5,6	1	\$/ft ² floor		
		R-38 fiberglass batt	7,8	1.2	\$/ft ² floor		
	Carpet	80% carpet	All	0	\$		
Thermal Mass	Floor mass	Wood surface	All	1.8	\$/ft ² floor		
	Exterior wall mass	½-in. drywall	All	1.2	\$/ft ² wall		
	Partition wall mass	½- in. drywall	All	1.2	\$/ft ² wall		
	Ceiling mass	½-in. drywall	All	1.4	\$/ft ² ceiling		
Windows and	Window areas	15.0% F25 B25 L25 R25	All	0	\$		

⁸ This default composition to meet code will be discussed in 2013 to determine the most “standard” across the country

Doors	Windows						
		Double-pane, low-gain low-e, nonmetal frame, air fill	1,2,3	22	\$/ft ² window		
		Double-pane, medium-gain low-e, nonmetal frame, argon fill	4,4C,5,6,7,8	23	\$/ft ² window		
	Eaves	2 ft	All	5.8	\$/ft ² eave		
	Overhangs ⁹	None	All	0	\$		
Airflow	Air leakage	7 ACH50, 0.5 shelter coefficient	All	0.25	\$/ft ² finished floor		
	Mechanical ventilation	Exhaust	All	1100	\$		
Major Appliances	Refrigerator	Benchmark	All	1100	\$		
	Cooking range	Benchmark	All	920	\$		
	Dishwasher	Benchmark	All	880	\$		
	Clothes washer	Benchmark	All	590	\$		
	Clothes dryer	Benchmark	All	760	\$		
Lighting	Lighting	Benchmark	All	0.04	\$/ft ² living + garage		
Space Conditioning	Central air conditioner	SEER 13	All	64	\$/kBtu/h	410	\$(labor)
	Furnace	Gas, 78% AFUE	All	9	\$/kBtu/h	1200	\$(labor)
	Boiler	None	All	0	\$		
	Electric baseboard	None	All	0	\$		
	Air source heat pump	None	All	0	\$		
	Ground source heat pump	None	All	0	\$		
	Ducts	15% leakage, R-6	All	5.8	\$/ft ² duct surface		

⁹ Overhangs are defined as the shading provided over each window. The Benchmark building does not have overhangs.

	Ceiling fan	Benchmark	All	240	\$/fan	290	\$/fan (labor)
	Dehumidifier	None	All	0	\$		
Water Heating	Water heater	Benchmark	All	10	\$/gal	640	\$
	Distribution	Uninsulated, TrunkBranch, copper	All	8.6	\$/ft Piping		
	Solar water heating	None	All	0	\$		
	Solar water heating azimuth	Back roof	All	0	\$		
	Solar water heating tilt	Roof pitch	All	0	\$		
	Power Generation	None			0	\$	

Clarification 4.2—Cash Flow Assumptions

There have also been requests to state explicitly what the cash flow assumptions are for the Benchmark and retrofit analyses. These values are documented in Table 10 and are consistent with the default values in BEopt.

Table 10. Cash Flow Assumptions

Group	Category	Construction Type	Value
Economics	Project analysis period	All	30 years ¹⁰
	Inflation rate	All	3.0%
	Discount rate	All	3.0%
Mortgage	Down payment	New, existing with loan, and existing with tax deductible loan	0.0%
		Existing, cash	100%
	Mortgage interest rate	All applicable	7.0%
	Mortgage/loan period	New	30 years
		Existing with loan, existing with tax deductible loan	5 years
	Marginal income tax rate, federal	New	28%

The analyst should use OpenEI to find whatever utility rate is the closest to the actual rate the homeowner pays. This is applicable to all analyses, including for the Benchmark, NCTH, and pre- and post-retrofit. The site to source ratios for electricity, gas, propane, and oil are 3.365, 1.092, 1.151, and 1.158, respectively in all locations and are automatically implemented in BEopt.

¹⁰ The analysis period versus the mortgage period for existing homes is part of a larger, ongoing discussion about how to report on energy savings metrics in existing homes. This will be discussed further in 2013.

5 Overall Document Format

Recommendation 5.1.1—Internal Versus External

Although the BA HSP document was never meant for use outside of the BA program, some people reference its values simply because few such references are available.

There have been some suggestions for a change in the overall report format. Some believe that the report would benefit from a division of information. There would be two reports to represent the current HSP, one internal to the BA program, and one external for all simulation analysts. In cases where not enough research has been done to provide a recommendation to outside users, the external version of the HSP would be silent.

Pros: It would be clear to outside users which values have proper justification for general use. All values that are meant only for programmatic calculations would be used only for the BA program, as was the original intent.

Cons: The magnitude of effort required for such a task is unclear. However, the report used by outside stakeholders would be fairly short, because there are few statistically significant values for simulation assumptions in the current version.

At this point, the report will remain the same because of budget constraints. However, feedback on this possible division is welcomed by the authors.

Recommendation 5.1.2—Directions versus Justifications

There are also discussions about the usefulness of the current written format, which consists of tables of data, followed by explanations and justifications. One suggestion was to break the report into two parts. The first part would be similar to an executive summary with only short tables of information for how to model the benchmark or retrofit building. The descriptions and justifications would be provided in the main body of the report. It has also been suggested that a separate report be created to describe only the operating conditions and corresponding separate section for the justification for those values.

Pros: It will be easier for an analyst to choose inputs for any modeling program and know which values to use for the Benchmark without having to read the entire report.

Cons: The magnitude of effort required for such a task is unclear. Separating the two elements might promote inappropriate use of some of the assumptions that are detailed in this report.

At this point, the report will remain the same because of budget constraints. However, feedback on this possible division is welcomed by the authors.

6 Bibliography

- Abrams, D.W.; Shedd, A.C. (1996). "Effect of Seasonal Changes in Use Patterns and Cold Inlet Water Temperature on Water Heating Load." *ASHRAE Transactions*, AT-96-18-3.
- Aquacraft. (2008). "Hot & Cold Water Data from EPA Retrofit Studies—EBMUD & Seattle." Boulder, CO: Aquacraft Inc.
- ASHRAE. (2009). *Handbook—Fundamentals*. Atlanta, GA: American Society of Heating, Refrigerating and Air-Conditioning Engineers.
- ASHRAE. (2008). *HVAC Systems and Equipment Handbook*. Atlanta, GA: American Society of Heating, Refrigerating and Air-Conditioning Engineers.
- ASHRAE. (2007a). Ventilation and Acceptable Indoor Air Quality in Low-Rise Residential Buildings. ASHRAE Standard 62.2-2007, Atlanta, GA: American Society of Heating, Refrigerating and Air-Conditioning Engineers.
- ASHRAE. (2007b). *HVAC Applications Handbook*. Atlanta, GA: American Society of Heating, Refrigerating and Air-Conditioning Engineers.
- ASHRAE. (2004a). Method of Test for Determining the Design and Seasonal Efficiencies of Residential Thermal Distribution Systems, ASHRAE Standard 152-2004, Atlanta, GA: American Society of Heating, Refrigerating and Air-Conditioning Engineers.
- ASHRAE. (2004b). "Thermal Environmental Conditions for Human Occupancy," ASHRAE Standard 55-2004, Atlanta, GA: American Society of Heating, Refrigerating and Air-Conditioning Engineers.
- ASHRAE. (1993). A Method of Determining Air Change Rates in Detached Dwellings, ASHRAE Standard 136-1993, Atlanta, GA: American Society of Heating, Refrigerating and Air-Conditioning Engineers.
- ASHRAE. (1988). Air Leakage Performance for Detached Single-Family Residential Buildings, ASHRAE Standard 119-1988, Atlanta, GA: American Society of Heating, Refrigerating and Air-Conditioning Engineers.
- ASTM. (1994). *Moisture Control in Buildings*. Conshohocken, PA: American Society for Testing and Materials.
- ASTM. (2007). Standard Test Methods for Determining External Air Leakage of Air Distribution Systems by Fan Pressurization. ASTM E1554-07. Conshohocken, PA: American Society for Testing and Materials.
- ASTM. (2003). Standard Test Method for Determining Air Leakage Rate by Fan Pressurization. ASTM E779-03. Conshohocken, PA: American Society for Testing and Materials.
- AWWA. (1999). "Residential End Uses of Water." Denver, CO: American Water Works Association AWWA.
- Becker, B.R.; Stogsdill, K.E. (1990). "Development of Hot Water Use Data Base." *ASHRAE Transactions* 96(2):422–427. Atlanta, GA: American Society of Heating, Refrigerating and Air-Conditioning Engineers.

- Burch, J.; Christensen, C. (2007). "Towards Development of an Algorithm for Mains Water Temperature." In Proceedings of the 2007 ASES Annual Conference, Cleveland, OH.
- Burch, J.; Erickson, P. (2004). "Using Ratings Data to Derive Simulation-Model Inputs for Storage-Tank Water Heaters." 2004 National Solar Energy Conference. Boulder, CO: American Solar Energy Society.
- Burch, J.; Salasovich, J. (2002). "Flow Rates and Draw Variability in Solar Domestic Hot Water Usage." In Proceedings of the Solar 2002 Conference Including Proceedings of the 31st ASES Annual Conference and Proceedings of the 27th National Passive Solar Conference, 15–20 June 2002, Reno, Nevada. Boulder, CO: American Solar Energy Society, Inc.; pp. 287–292; Golden, Colorado: National Renewable Energy Laboratory, NREL Report No. CP-550-31779.
- California Energy Commission (CEC). (2010). Appliance Efficiency Database. <http://www.appliances.energy.ca.gov/>. Sacramento, CA: California Energy Commission. Last accessed September 2010.
- California Energy Commission (CEC). (2002). California Building Energy Efficiency Standards, Part 1, Measure Analysis and Life Cycle Cost. Sacramento, CA: California Energy Commission.
- Christensen, C.; Anderson, R.; Horowitz, S.; Courtney, A; Spencer, J. (2006). "BEopt Software for Building Energy Optimization: Features and Capabilities." Golden, CO: National Renewable Energy Laboratory, NREL Reprot No. TP-550-39929.
- Christensen, C.; Barker, G.; Thornton, J. (2000). "Parametric Study of Thermal Performance of Integral Collector Storage Solar Water Heaters." Golden, CO: National Renewable Energy Laboratory, NREL Report No. CP-550-28043.
- DEG. (2006). Prototype Floor Plans—Hot Water Distribution System Layouts. Report to Lawrence Berkeley National Laboratory under funding by the California Energy Commission. Davis, CA: Davis Energy Group.
- Deru, M.; Torcellini, P. (2007). *Source Energy and Emission Factors for Energy Use in Buildings*. Golden, CO: National Renewable Energy Laboratory, NREL/TP-550-38617.
- DOE. (2010). Residential Heating Products Final Rule Technical Support Document. Chapter 7: Energy Use Characterization. http://www1.eere.energy.gov/buildings/appliance_standards/residential/heating_products_fr_tsd.html. Washington, DC: U.S. Department of Energy. Last accessed May 2012.
- DOE. (2005). "2005 Residential Energy Consumption Survey." www.eia.doe.gov/emeu/recs/contents.html. Washington, DC: U.S. Department of Energy. Last accessed August 2010.
- DOE. (2004). Code of Federal Regulations Title 10, Energy, Part 430, Subpart B, Appendices C, D, J, and J1, Washington, DC: U.S. Department of Energy.
- DOE. (2004a). Technical Support Document: Energy Efficiency Program for Consumer Products: Energy Conservation Standards for Residential Furnaces and Boilers. www.eere.energy.gov/buildings/appliance_standards/residential/furnaces_boilers.html. Washington, DC: U.S. Department of Energy. Last accessed June 2010.
- DOE. (2004b). 2004 Buildings Energy Databook. <http://btscoredatabook.eren.doe.gov/>. Washington, DC: U.S. Department of Energy. Last accessed June 2010.

- DOE. (2003a). New and Alternative Insulation Materials and Products. Energy Savers Fact Sheet. www.eere.energy.gov/consumerinfo/factsheets/eb9.html (accessed August 2005). Washington, DC: U.S. DOE.
- DOE. (2003b). Appliances and Commercial Equipment Standards. www.eere.energy.gov/buildings/appliance_standards/. Washington, DC: U.S. Department of Energy. Last accessed May 2004.
- DOE. (2002a). Technical Support Document: Energy Efficiency Standards for Consumer Products: Residential Central Air Conditioners and Heat Pumps. www.eere.energy.gov/buildings/appliance_standards/residential/central_ac_hp.html. Washington, DC: U.S. Department of Energy. Last accessed June 2010.
- DOE. (2002b). Residential Energy Efficiency and Appliance Standards. www.eere.energy.gov/consumerinfo/refbriefs/ee8.html. Washington, DC: U.S. Department of Energy. Last accessed May 2004.
- DOE. (2001a). Code of Federal Regulations Title 10, Energy, Part 430, Energy Conservation Program for Consumer Products: Energy Conservation Standards for Water Heaters; Final Rule. www1.eere.energy.gov/buildings/appliance_standards/residential/pdfs/water_heater_fr.pdf. Washington, DC: U.S. Department of Energy. Last accessed August 2010.
- DOE. (2001b). Residential Energy Consumption Survey. Washington, DC: U.S. Department of Energy.
- DOE. (2001). Annual Energy Outlook 2002. Washington, DC: U.S. Department of Energy.
- DOE. (2000a). Technical Support Document: Energy Efficiency Standards for Consumer Products: Residential Water Heaters. Appendix D-2. www.eere.energy.gov/buildings/appliance_standards/residential/waterheater.html. Washington, DC: U.S. Department of Energy. Last accessed June 2010.
- DOE. (2000b). Final Rule Technical Support Document: Energy Efficiency Standards for Consumer Products: Clothes Washers. www.eere.energy.gov/buildings/appliance_standards/residential/clothes_washer.html. Washington, DC: U.S. Department of Energy. Last accessed June 2010.
- DOE. (1999). “1997 Residential Energy Consumption Survey.” www.eia.doe.gov/emeu/recs/pubs.html Washington, DC: U.S. Department of Energy. Last accessed December 2009).
- DOE. (1997). Code of Federal Regulations Title 10, Energy, Part 430, “Energy Conservation Program for Consumer Products: Test Procedure for Kitchen Ranges, Cooktops, Ovens, and Microwave Ovens; Final Rule.” Washington, DC: U.S. Department of Energy.
- DOE. (1996). Residential Lighting Use and Potential Savings. DOE/EIA-0555(96)/2. Washington, DC: U.S. Department of Energy.
- DOE. (1995). Measuring Energy Efficiency in the United States Economy: A Beginning. Chapter 7. www.eia.doe.gov/emeu/efficiency/ee_report_html.htm. Washington, DC: U.S. U.S. Department of Energy. Last accessed June 2010.
- DOE. (1993). Technical Support Document for Residential Cooking Products. Volume 2. www.eere.energy.gov/buildings/appliance_standards/residential/cooking_products_0998_r.html. Washington, DC: U.S. Department of Energy. Last accessed June 2010.

- EPRI. (1986). Trends in the Energy Efficiency of Residential Electric Appliances. EM-4539, Research Project 2034-9. Palo Alto, CA: Electric Power Research Institute.
- EPRI. (1987). *TAG Technical Assessment Guide: Volume 2: Electricity End Use*. EPRI P-4463-SR. Palo Alto, CA: Electric Power Research Institute.
- E-Source. (1993). Space Heating Technology Atlas. Boulder, CO: E-Source Inc.
- E-Star Colorado. (2005). R-Value Table. www.e-star.com/ecalcs/table_rvalues.html. Last accessed August 2005.
- Gleick, P.H.; Haasz, D.; Henges-Jeck, C.; Srinivasan, V.; Wolff, G.; Kao-Cushing, K.; Mann, A. (2003). Waste Not, Want Not: The Potential for Urban Water Conservation in California. Prepared for Pacific Institute for Studies in Development, Environment and Security. Oakland, CA.
- Greening, L.A.; Greene, D.L.; Difiglio, C. (2000). Energy Efficiency and Consumption—The Rebound Effect—A Survey. *Energy Policy* 28:389–401. Amsterdam, Netherlands: Elsevier B.V.
- Hancock, E.; Norton, P.; Hendron, R. (2002). *Building America System Performance Test Practices: Part 2, Air-Exchange Measurements*. NREL/TP-550-30270. Golden, CO: National Renewable Energy Laboratory.
- Hendron, R. (2008). *Building America Research Benchmark Definition Updated December 19, 2008*. NREL/TP-550-44816. Golden, CO: National Renewable Energy Laboratory.
- Hendron, R.; Eastment, M. (2006). “Development of an Energy-Savings Calculation Methodology for Residential Miscellaneous Electric Loads.” ACEEE Summer Study on Energy Efficiency in Buildings. Washington, DC: American Council for an Energy-Efficient Economy.
- Huang, J.; Gu, L. (2002). Prototype Residential Buildings to Represent the U.S. Housing Stock. Draft LBNL Report. Berkeley, CA: Lawrence Berkeley National Laboratory.
- HUD. (1982). “Minimum Property Standards for One- and Two-Family Living Units.” No. 4900.1-1982. Washington, DC: U.S. Department of Housing and Urban Development.
- ICC. 2003. International Energy Conservation Code 2003. Falls Church, VA: International Code Council.
- Jiang, W.; Jarnagin, R.E.; Gowri, K.; McBride, M.; Liu, B. (2008). Technical Support Document: The Development of the Advanced Energy Design Guide for Highway Lodging Buildings. Richland, WA: Pacific Northwest National Laboratory.
- Judkoff, R.; Balcomb, J. D.; Hancock, C. E.; Barker, G.; Subbarao, K. (2000). *Side-By-Side Thermal Tests of Modular Offices: A Validation Study of the STEM Method*. Golden, CO: National Renewable Energy Laboratory. NREL/TP-550-23940.
- KEMA. (2009). “Residential Lighting Metering Study: Preliminary Results.” February 2009 Presentation to Stakeholders. Oakland, CA: KEMA. www.energydataweb.com/cpuc/home.aspx.
- Kolb, G. (2003). Private communication. Albuquerque, NM: Sandia National Laboratories.
- Lithgow, M.; Filey, D.; Kaszczij, R.; Liotta, J.; Den-Elzen, P. (1999). Multi-Unit Residential Clothes Washer Replacement Pilot Project. Prepared by the City of Toronto Works and Emergency Services and the Toronto Community Housing Corporation, Toronto, Canada.

- Lstiburek, J. (1999). Heating Choices. Research Report—9911. Somerville, MA: Building Science Corporation. <http://www.buildingscience.com/documents/reports/rr-9911-heating-choices>
- Matson, N.; Wray, C.; Walker, I.; Sherman, M. (2002). Potential Benefits of Commissioning California Homes. LBNL-48258. Berkeley, CA: Lawrence Berkeley National Laboratory.
- Mills, E. 2008. The Home Energy Saver: Documentation of Calculation Methodology, Input Data, and Infrastructure, LBNL-51938. Berkeley, CA: Lawrence Berkeley National Laboratory.
- Navigant Consulting. (2002). U.S. Lighting Market Characterization: Volume 1: National Lighting Inventory and Energy Consumption Estimate. Washington, DC: Navigant Consulting.
- NRC. (2002). “A National Study of Water & Energy Consumption in Multifamily Housing: In-Apartment Washers vs. Common Area Laundry Rooms.” Multi-housing Laundry Association. Boulder, CO: National Research Center.
- NREL. (2009). “Benchmark Midrise Apartment NewV1(2).1_3.1(SI).” Golden, CO: National Renewable Energy Laboratory.
- Parker, D.; Fairey, P.; Hendron, R. (2010). Updated Miscellaneous Electricity Loads and Appliance Energy Usage Profiles for Use in Home Energy Ratings, the Building America Benchmark Procedures and Related Calculations. FSEC-CR-1837-10. Cocoa, FL: Florida Solar Energy Center.
- Parker, D. (2002). Research Highlights from a Large Scale Residential Monitoring Study in a Hot Climate (and personal communication). FSEC-PF369-02. Cocoa, FL: Florida Solar Energy Center.
- Parker, D.; Sherwin, J.R.; Anello, M.T. (2000). FPC Residential Monitoring Project: Assessment of Direct Load Control and Analysis of Winter Performance. Prepared for the Florida Power Corporation, Cocoa, FL, FSEC-CR-1112-99.
- PNNL; ORNL. (2007). High-Performance Home Technologies: Guide to Determining Climate Regions by County. Building America Best Practices Series. http://apps1.eere.energy.gov/buildings/publications/pdfs/building_america/climate_region_guide.pdf. Richland, WA: Pacific Northwest National Laboratory. Last accessed July 2010.
- Pratt, R.; Conner, C.; Richman, E.; Ritland, K.; Sandusky, W.; Taylor, M. (1989). Description of Electric Energy Use in Single-Family Residences in the Pacific Northwest—End-Use Load and Consumer Assessment Program, Richland, WA: Pacific Northwest National Laboratory, DOE/BP-13795-21.
- Rea, M., et al. (2000). Lighting Handbook, Ninth Edition. New York, NY. Section 3, Chapter 10: Illuminance Selection.
- RESNET. (2006). 2006 Mortgage Industry National Home Energy Rating Systems Accreditation Standards. San Diego, CA: Residential Energy Services Network.
- Sachs, H.M. (2005). Opportunities for Elevator Energy Efficiency Improvements. Washington D.C.: American Council for an Energy-Efficient Economy.

- Sherman, M.H.; Grimsrud, D.T. (1980). "Infiltration-Pressurization Correlation: Simplified Physical Modeling." *ASHRAE Transactions* 86(2):778. Atlanta, GA: American Society of Heating, Refrigerating and Air-Conditioning Engineers.
- SWA. (1995). Simplified Multizone Blower Door Techniques for Multifamily Buildings. NYSERDA Report # 95-16. Norwalk, CT: Steven Winter Associates, Inc..
- Stokes, M.; Rylatt, M.; Lomas, K. (2004). "A Simple Model of Domestic Lighting Demand." *Energy and Buildings* 36:103–116. United Kingdom: Institute of Energy and Sustainable Development.
- Szydlowski, R.; Cleary, P. (1988). "In-Situ Appliance Efficiency Audit Procedures." *ASHRAE Transactions* 94(1):1107–1023. Atlanta, GA: American Society of Heating, Refrigerating and Air-Conditioning Engineers.
- Taylor, Z.T.; Conner, C.C.; Lucas, R.G. (2001). "Eliminating Window-Area Restrictions in the IECC." Report No. PNNL-SA-35432. Richland, WA: Pacific Northwest National Laboratory.
- Wassmer, M. (2003). A Component-Based Model for Residential Air Conditioner and Heat Pump Energy Calculations. Masters Thesis, University of Colorado at Boulder.
- Wenzel, T.; Kooney, J.; Rosenquist, G.; Sanchez, M.; Hanford, J. (1997). Energy Data Sourcebook for the U.S. Residential Sector. Berkeley, CA: Lawrence Berkeley National Laboratory, LBL-40297.

buildingamerica.gov

U.S. DEPARTMENT OF
ENERGY | Energy Efficiency &
Renewable Energy

DOE/GO-102012-3855 • December 2012

Printed with a renewable-source ink on paper containing at least 50% wastepaper, including 10% post-consumer waste.