



# Renewables Integration for 85% carbon emissions reduction by 2030... and beyond


## Grid Performance Evaluation of IBRs

Hari Singh, PhD, PE  
Integrated System Planning

NREL Power Electronics Grid Interface (PEGI) Workshop  
May 24-25, 2023



# Xcel Energy



## Serving eight states

**3.7** million electricity customers


**2.1** million natural gas customers

## Nationally recognized leader:

- Wind energy
- Energy efficiency
- Carbon emissions reductions
- Innovative technology
- Storm restoration

Data based on 2021 Sustainability Report. To view full report: [xcelenergy.com/sustainability](https://www.xcelenergy.com/sustainability).

# 2022 Energy Mix – Xcel Energy



# Clean Energy Transition

**2005**

**21% Carbon-free**

Nuclear, Wind, Solar  
and Other Renewables

Coal and Natural Gas

**2022**

**53% Carbon-free**

Nuclear, Wind, Solar  
and Other Renewables

Coal and Natural Gas

**2030 Estimate**


**79% Carbon-free**

Nuclear, Wind, Solar  
and Other Renewables

Coal and Natural Gas





# A Bold Vision for a Carbon-free Future





Company-wide carbon emissions reductions from serving our customers, compared to 2005

### Upper Midwest energy mix




### Colorado energy mix





# Colorado's Clean Energy Plan (CEP) for 80x2030 Goal



Resource Additions between 2025 and 2030: 5700 MW on Tx, 1200 MW on Dx

Wind = 2400 MW

Solar = 1600 MW

Storage = 400 MW

Firm Dispatchable = 1300 MW

Distributed Solar = 1200 MW



# Colorado's Power Pathway for Access to ERZs












Table 2-1: Selected Disturbances

Disturbance		TPL Category
No.	Description	
1	3ph fault at Comanche 345 kV followed by loss of Comanche - Daniels Park 345 kV and Tundra - Daniels Park 345 kV lines	P7.1
2	3ph fault at Comanche 230 kV followed by loss of Comanche - Midway 230 kV and Mirasol - Midway 230 kV lines	P7.1
3-1	3ph fault at Comanche 230 kV followed by loss of Comanche - Mirasol 230 kV line	P1.2
3-2	3ph fault at Mirasol 230 kV followed by loss of Mirasol - Midway 230 kV line	P1.2
4-1	3ph fault at Comanche 345 kV followed by loss of Comanche - Tundra 345 kV line	P1.2
4-2	3ph fault at Tundra 345 kV followed by loss of Tundra - Daniels Park 345 kV line	P1.2
5	3ph fault at Comanche 230 kV followed by loss of Comanche - Boone 230 kV line	P1.2

Scenarios	Comanche Area Aggregate IBRs	3ph Fault Clearing Time	Notes
Base	1135 MW	345kV = 4.5 cy 230kV = 5.5 cy	At Coman = 560 MW Proximate = 575 MW Normal Clearing Time (NCT)
1	1135 MW	345kV = 18 cy 230kV = 22 cy	4 x NCT
2	2360 MW (~2 x Base)	same as above	At Coman = 1210 MW Proximate = 1150 MW
3	3020 MW (~2.7 x Base)	same as above	At Coman = 1860 MW Proximate = 1150 MW
4	3020 MW	NCT	
5	3020 MW	NCT	SynCond @ Coman

Disturbance No.	Base Scenario	Sensitivity Scenario				
		1	2	3	4	5
1				(1)	(2)	(3)
2					Not Tested	
3-1		Not Tested				
3-2						
4-1						
4-2						
5			Not Tested			
(1) System unable to maintain stability						
(2) System is stable with undamped oscillations						
(3) System is stable with undamped oscillations. Oscillation magnitude smaller compared to (2)						

Scenarios	Comanche Area Aggregate IBRs	3ph Fault Clearing Time	Notes
Base	1135 MW	345kV = 4.5 cy 230kV = 5.5 cy	At Coman = 560 MW Proximate = 575 MW Normal Clearing Time (NCT)
1	1135 MW	345kV = 18 cy 230kV = 22 cy	4 x NCT
2	2360 MW (~2 x Base)	same as above	At Coman = 1210 MW Proximate = 1150 MW
3	3020 MW (~2.7 x Base)	same as above	At Coman = 1860 MW Proximate = 1150 MW
4	3020 MW	NCT	
5	3020 MW	NCT	SynCond @ Coman

**Xcel Energy**<sup>®</sup>



# EMT (PSCAD) Model Verification (Validation?) Tests

Model Usability Verification

Model Electrical Configuration Verification

Plant Controller Verification

Basic Performance Verification

- Initialization Test
- Balanced / Unbalanced Fault Ride-through Test
- Overvoltage Ride-through Test
- Voltage & Active Power Reference Step Change Tests
- Grid Frequency Response and Ride-through Test
- Grid Voltage Phase-Angle Change Ride-through Test
- POI SCR Change Test

Basic Protection Verification



# High Fidelity Validated IBR Models – the Value

- Essential for gaining confidence in grid performance study results
  - ✓ identify grid performance improvement need and evaluate solutions in planning horizon
  - ✓ establish operating limits (SOLs/IROLs) in operating horizon
- Are simulation-based IBR model verification/validation tests sufficient?  
**probably better than nothing**
- Is system disturbance event-recording based IBR model validation ideal?  
**perhaps, but does not help with predictive grid performance studies**
- Is laboratory-based IBR model testing & validation the pragmatic middle ground?  
**if capable of validating plant-level models**
- Could a grid-interface platform help enhance confidence in IBR model fidelity and/or help evaluate grid reliability solutions?  
**absolutely!**



