



Evaluation of the Performance of the PVUSA Rating Methodology Applied to DUAL Junction PV Technology

Preprint


Daryl Myers

*To be presented at the American Solar Energy Society Annual
Conference
Buffalo, New York
11-16 May 2009*

Conference Paper
NREL/CP- 550-45376
Revised July 2009

NREL is operated for DOE by the Alliance for Sustainable Energy, LLC

Contract No. DE-AC36-08-GO28308



NOTICE

The submitted manuscript has been offered by an employee of the Alliance for Sustainable Energy, LLC (ASE), a contractor of the US Government under Contract No. DE-AC36-08-GO28308. Accordingly, the US Government and ASE retain a nonexclusive royalty-free license to publish or reproduce the published form of this contribution, or allow others to do so, for US Government purposes.

This report was prepared as an account of work sponsored by an agency of the United States government. Neither the United States government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States government or any agency thereof.

Available electronically at <http://www.osti.gov/bridge>

Available for a processing fee to U.S. Department of Energy and its contractors, in paper, from:

U.S. Department of Energy
Office of Scientific and Technical Information
P.O. Box 62
Oak Ridge, TN 37831-0062
phone: 865.576.8401
fax: 865.576.5728
email: <mailto:reports@adonis.osti.gov>

Available for sale to the public, in paper, from:

U.S. Department of Commerce
National Technical Information Service
5285 Port Royal Road
Springfield, VA 22161
phone: 800.553.6847
fax: 703.605.6900
email: orders@ntis.fedworld.gov
online ordering: <http://www.ntis.gov/ordering.htm>



ERRATA SHEET

NREL REPORT/PROJECT NUMBER: NREL/CP-550-45376

TITLE: Evaluation of the Performance of the PVUSA Rating Methodology Applied to
DUAL Junction PV Technology

AUTHOR(S): Daryl Myers

ORIGINAL PUBLICATION DATE: March 2009

DATE OF CORRECTIONS: July 17, 2009

The following corrections were made to this report/document:

A previous version of this paper, available until July 17, 2009, mistakenly referred to a triple junction roof mounted USSC system, which was incorrect. The Title, Abstract, Introduction paragraphs 1, 3, and 4, and Conclusion paragraph 1 were changed to reflect the correct setup, which was a rack-mounted dual-junction PV system.

EVALUATION OF THE PERFORMANCE OF THE PVUSA RATING METHODOLOGY APPLIED TO DUAL JUNCTION PV TECHNOLOGY

Daryl Myers
National Renewable Energy Laboratory
1617 Cole Boulevard
Golden, CO 80402
daryl.myers@nrel.gov

NOTE: a previous version of this paper, available until July 17, 2009, mistakenly referred to a triple junction roof mounted USSC system, which was incorrect. The author is solely responsible for, and regrets, that error.

ABSTRACT

The PVUSA (Photovoltaics for Utility Scale Applications) project in the 1990's developed a rating methodology for PV performance evaluation which has become popular, and even incorporated into concentrating PV rating standards. The method is based on collecting solar, meteorological, and system power output data for a period of time, and regressing the system output against a combination of irradiance, wind speed, and ambient temperature. The selected irradiance, wind speed, and temperature rating conditions are $I_s=1000 \text{ Wm}^{-2}$, $W_s=1 \text{ ms}^{-1}$, and $T_s=20 \text{ }^\circ\text{C}$, respectively, for a flat plate collector. Here, we apply the method to a rack-mounted dual-junction PV system, and produce a system rating. We also describe in detail the uncertainties associated with the method, and mathematical issues associated with the technique.

1. INTRODUCTION

The PVUSA (Photovoltaics for Utility Scale Applications) project in the 1990's developed a rating methodology [1, 2] for PV performance evaluation which has become popular, and even incorporated into concentrating PV rating standards [3]. The method is based on collecting solar, meteorological, and system power output data for a period of time, and regressing the system output, P, against a combination of irradiance, I, wind speed, W, and ambient temperature, T, variables in the form of equation 1.

$$P = I * (a + b * I + c * W + d * T) \quad (1)$$

The selected irradiance, wind speed, and temperature rating conditions are $I_s=1000 \text{ Wm}^{-2}$, $W_s=1 \text{ ms}^{-1}$, and $T_s=20 \text{ }^\circ\text{C}$, respectively, for a flat plate collector. For concentrating

collectors (not addressed here, but our analysis is generally applicable) the only difference is that the rating condition (direct beam) irradiance is $I_s=850 \text{ Wm}^{-2}$.

In this paper, we apply the method to a rack-mounted dual-junction PV system, and produce a system rating. We also describe in detail the uncertainties associated with the method, and mathematical issues associated with the technique. In particular, the relative contribution of each combination of variables is quantified, and it is argued that simpler regressions of PV power with respect to irradiance perform as well if not better.

This analysis is based upon one United Solar System Corp. (USSC) system of 96 dual-junction rack-mounted modules at a 40 degree (NREL latitude) tilt, facing due south. The array has a system Standard Test Condition (STC) direct current (DC) rating of 1800 Watts peak (Wpac) and an alternating current (AC) rating of 1600 Wpac. Recall that STC are 1000 Watt per square meter, Wm^{-2} , irradiance, 25° cell temperature, and under the American Society for Testing and Materials (ASTM) Air Mass 1.5 hemispherical tilt spectrum [4].

2. PV SYSTEM DATA COLLECTION

The PV system parameters listed in table 1 were measured with a Campbell Scientific CR 21X Data logger, with signal conditioning of the array electrical parameters including monitors for voltage, current, and module temperature. The data were sampled every 3 seconds and integrated over 1 minute. Fifteen minute averages of the data were reported.

In this subsection, we address the uncertainty associated with the measurement of performance parameters and input variables for the model. The combined CR21X data logger and sensor uncertainties are summarized and applied to the range of parameters applicable to this system.

Table 2 reports the measurement uncertainty in each parameter and combined overall measurement uncertainty for the NREL Photovoltaic Energy Rating Testbed (PERT) as reported in NREL technical report NREL/TP-520-26909 “Validation of a Photovoltaic Module Energy Ratings Procedure at NREL” [5].

TABLE 1: USSC 1.6 kW SYSTEM MEASUREMENTS.

Field	Parameter
SYS_ID	System Identification
YEAR	Year
DAY	Day of the year (1 to 365)
TIME	Mountain Standard Time HHMM
POA_IRR	Plane of Array solar irradiance Wm^{-2}
DC_POWER	Array Direct Current power output Watts (W)
AC_POWER	Array Alternating Current power output (W)
POS_VOLTS	Array Positive leg voltage, Volts (V)
POS_AMPS	Array Positive leg current, Amperes (I)
NEG_VOLTS	Array negative leg voltage, (V)
NEG_AMPS	Array negative leg current, (I)
AC_VOLTS	Array Alternating current volts (V)
AC_AMPS	Array Alternating current (I)
T_AMB	Ambient Temperature °C
T_MOD1	Module 1 Temperature °C
T_MOD2	Module 2 Temperature °C (not measured)
T_MOD3	Module 3 Temperature °C(not measured)
T_INV	Inverter Temperature °C
T_DAS	Data Acquisition System (DAS) Temperature °C
DAS_BATV	DAS battery Voltage (V)

2.1 System Monitoring Transducer Accuracy

The accuracy of the CR21X data logger with respect to the several electrical parameters measured (as derived from Campbell Scientific and Ohio Semitronics Incorporated (OSI) specifications) is summarized here.

CR21X current and voltage accuracy:

DC & AC Voltage: (range: 0 to 233 V DC, 0 -126 AC V)

Ohio Semitronics Inc (OSI) VT8-005B RMS Voltage Transducer, 0-150 V ac and/or dc input, 0-1 mA output, Temperature Coefficient. $T_c = \pm 1.0\%$ of reading (-10°C to +60°C).

Accuracy = $\pm 0.25\%$ F.S. (Full Scale)

Note 0.25% of system voltage of 150 V = 0.38 V Ac

DC & AC Current: (0- 3.8 DC amp, 0-12 AC amp)
 OSI CTA-214 RMS Current Sensor Signal Conditioner
 0-1 mA output proportional to RMS value of ac and/or dc input, Linearity: $\pm 0.1\%$ F.S.
 $T_c = \pm 0.005\%/^{\circ}C$ (0° to +70°C),
 with OSI CTL-50 Hall-Effect Current Sensor
 50 Ampere (A) rms input
 30 mV output typical,
 $T_c = -0.15\%/^{\circ}C$ (-40°C to +65°C).

0.1% of 50 Arms = 0.05 Amp out of 12 A ac = 0.42%

AC Power: (0-1900 Watts)
 OSI PC8-003-01B Variable-Frequency Watt Transducer
 0-150 V and 0-100 A input; ± 1 mA output
 $T_c = \pm 1.0\%$ of reading, $\pm 0.1\%$ F.S. output (0°C to +40°C).

Accuracy = $\pm 1.0\%$ F.S. (includes combined effects of voltage, current, load, & power factor),

We compute the total uncertainty in the AC power by root sum square of

$$(1^2 + 1^2 + 0.1^2)^{1/2} = 1.45\% \text{ of } 1900 \text{ Wp} = \pm 27.5 \text{ Watts AC}$$

For power computed from AC Amps and AC Volts:

$$(0.422 + 0.25^2)^{1/2} = 0.5\% \text{ of } 1900 \text{ Wp} = \pm 9.5 \text{ Watts.}$$

TABLE 2: PERT UNCERTAINTY SUMMARY

PARAMETER	%Uncertainty
Voltage	0.1%
Current	0.1%
Irradiance	4.0%
ModuleTemp	0.5%
Module Power	N/A
RSS	4.0%

Excluding the irradiance component in table 2 (discussed below), the root-sum-square of the current, voltage, and power uncertainty measurements from table 2 is 0.22%.

3. PVUSA TEST CONDITION MODEL

3.1 PVUSA Model Structure

The PVUSA TC method is based on the regression of AC power output (P) in W (or kW) against a function of three variables: Plane of Array Irradiance (I) in Wm^{-2} (or $kW m^{-2}$), Wind speed (W) in meters per second (ms^{-1}), and ambient temperature (T) in °C. Recall the form of the PVUSA TC model, as in equation 1, is:

$$P = I * (a + b * I + c * W + d * T)$$

Note the model includes *four* irradiance terms (one of which is squared) and only one each of temperature and wind speed related terms. This fact leads to some interesting conclusions regarding the accuracy of the model. Only conditions where the irradiance data is greater than 500 Wm⁻² (sometimes 700 Wm⁻² is recommended) are used to determine the regression coefficients a, b, c, and d. We note the following:

- Uncertainty in the irradiance carries significantly more weight than uncertainty in the other variables.
- Ambient temperature is highly positively correlated with solar irradiance
- Rating condition is established for a wind speed of 1 ms⁻¹; a relatively infrequent condition

The selected values for irradiance, wind speed, and temperature to produce a rating for a flat plate collector are I_s=1000 Wm⁻², W_s=1 ms⁻¹, and T_s=20 °C, respectively.

3.2 Meteorological Data

In addition to the irradiance independent variable in eq. 1, wind speed and temperature are also required. Ambient temperature is monitored at the system, but for the wind speed, we utilized wind speed data from the Reference Meteorological and Irradiance System (RMIS) deployed at the OTF along the north side of the OTF test field boundary. RMIS data is collected and archived at 1 minute intervals. We downloaded the archived 2006 1 minute RMIS data, and averaged the wind speed data over 15 minute intervals to provide average wind speed data for the regression analysis.

3.3 Model Sensitivity Coefficients

Considering eq. 1, the uncertainty in the ‘rating’ at test conditions, P_s, is dependent upon the uncertainty in each of the independent variables. The uncertainty in each variable is propagated through sensitivity coefficients, which are the partial derivatives of the right hand side of eq. 1 with respect to each ‘independent’ variable [6, 7]:

$$\partial P / \partial I = a + 2 * I * b + c * W + d * T \quad (2)$$

$$\partial P / \partial W = c * I \quad (3)$$

$$\partial P / \partial T = d * I \quad (4)$$

Given measurement errors, or uncertainties, e, in each of the independent variables, e_I, e_T, and e_W, the error in P, e_P is computed from:

$$e_p^2 = (\partial P / \partial I * e_I)^2 + (\partial P / \partial W * e_W)^2 + (\partial P / \partial T * e_T)^2 \quad (5)$$

$$e_p = [(\partial P / \partial I * e_I)^2 + (\partial P / \partial W * e_W)^2 + (\partial P / \partial T * e_T)^2]^{1/2}$$

Note that e_p is dependent upon the absolute magnitude of the irradiance, wind speed, and ambient temperature, as well as the measurement errors or uncertainties of e_I, e_W, and e_T, through equations 2, 3, and 4.

4. USSC PTSC REGRESSION FITS

AC power output for the USSC system was first filtered for:

- Daylight only data
- Removal of any record with missing data for any parameter
- Removal of any record with Irradiance < 500 Wm⁻²
- Removal of any record where the AC power was less than 1.2 x Irradiance (indicating the array was shadowed, covered with snow, shut down for maintenance, or otherwise not in a standard operational mode).

The ‘floor’ value of P > 1.2 * Irradiance was chosen based on the nominal 1.6 kW rating of the system at 1.0 kWm⁻² Standard Reporting Condition irradiance.

Figure 1 shows the data set as received, and figure 2 shows the filtered data set, from which the regression coefficients for the model were derived.




Fig 1. All raw USSC Array data versus plane of array irradiance for 2006




Fig 2. USSC Array data after filtering for non-standard operating conditions and for POA > 500 Wm⁻²

The derived regression coefficients for this filtered data set were:

$a = 1.4187, b = 5.0583 \cdot 10^{-5}, c = 2.2908 \cdot 10^{-3},$
 $d = 3.61332 \cdot 10^{-4}$

It is instructive to examine the relative magnitude of the coefficients, since all are coefficients of I three times over, as well as the b coefficient of I². Using Watts as the units of power, at a rating condition of I = 1000 Wm⁻², the relative contribution of each term in the PVUSA model to the rating value is approximately (in the absence of any measurement error at all):

a: 96.4%, b: 2.9%, c: 0.4%, and d: 0.4%. (sums to 100.1% due to rounding).

Note that a and b (irradiance and irradiance square terms only) contribute 99.3% of the eventual rating value. This will be discussed further below. A linear fit ($1.5284 \cdot I - 46.48, r^2 = 0.975$, standard deviation of regression = 45.2 Wm⁻²) of the array power to the irradiance (only) is shown by the line in fig 2. The quadratic fit is also shown.

5. PVUSA TC (PTC) RATING

Using the regression coefficients, a, b, c, and d, and the rating standard condition of I_s=1000 Wm⁻², W_s=1 ms⁻¹, and T_s=20 °C, in equation (1) we compute:

$P_s = I_s * (a + b \cdot I_s + c * W_s + d * T_s) = 1480.6 \text{ W.}$

Table 3 shows the measured and modeled power data for the POA irradiance within ±0.5 Wm⁻² of the 1000 Wm⁻² PVUSA TC point.

TABLE 3: MEASURED AND MODELED P
(I=1 kW ± 0.5 W)

AC Power W	POA Irradiance Wm ⁻²	Wind Speed m/s	Temp °C	PTC Model AC W
1506.4	999.9	7.4	9.0	1489.28
1467.4	999.8	2.8	19.5	1482.39
1506.8	1000.0	2.3	16.6	1480.50
1504.0	999.6	2.3	16.2	1479.74
1454.4	1000.1	2.0	26.6	1483.58
1468.4	999.7	2.2	25.1	1482.08
1481.9	999.9	2.8	26.6	1485.11
1528.8	999.9	2.0	16.4	1479.49
1558.7	999.9	2.2	17.9	1480.59
1545.3	1000.4	1.7	1.1	1474.13
1565.1	1000.2	3.8	16.9	1484.35
1513.3	1000.0	0.5	11.4	1474.50
1493.0	1000.4	1.4	4.0	1474.50
1516.7	1000.1	1.3	0.4	1472.51
PTCRATE	1000.0	1.0	25.0	1480.56

Note this one watt per meter square window is somewhat unrealistic, since typical pyranometer calibration error for a well characterized pyranometer is ±0.5% at 1000 Wm⁻², or ± 5 Wm⁻², ten times our specified window here.

There is measurement uncertainty associated with the array power, as well. An estimate of this measurement uncertainty is ±1%, or 15 Watts. Note the standard deviation, sigma, of the measured AC power in table 3 is ±36 Watts, (2.4% of the 1480 W rating) and 2-sigma would be ±72 Watts.

The mean measured AC power for the table 3 data points is 1507.8 ± 36.6 Wm⁻²; the mean PTC modeled AC power is 1480.3 ± 4.8 Wm⁻² (a 1.8% difference). Mean Wind speed and temperatures are 2.4 ± 1.6 ms⁻¹ and 14.5 ± 8.7 °C, respectively. This difference is about the measurement uncertainty in the power from V and A transducer measurement (1.2%, 2 sigma) derived in section 2.1.

Figure 3 shows the residuals (measured – modeled) between measured and modeled array power (for prevailing temperature and wind speeds) over a twenty watt irradiance ‘window’ centered on the PVUSA TC rating point of 1000 Wm⁻². With the exception of one residual of -307 Wm⁻² (where T = 0.6 °C and W = 1.7 ms⁻¹; possible frost or snow on the array) the range of residuals is -124 Wm⁻² to + 100 Wm⁻² in this irradiance regime. This range represents – 0.8% to +0.7% of the rating at PVUSA TC. Thus, an uncertainty component due to the model fit can be assumed as ~ ± 1.0%. This same scatter is apparent in figure 2, about the linear fit line in that plot.




Fig. 3. Residuals (measured – modeled) of measured data from the PVUSA TC model line for irradiance levels from 990 Wm⁻² to 1000 Wm⁻². Note this includes temperature range from -32.5 °C to 36 °C and wind speeds from 0.4 to 9.1 ms⁻¹.

6. CORRELATIONS OF POWER WITH MODEL VARIABLES

Since the PVUSA TC model is based on an assumed correlation of array power with the three independent variables, expressed as four terms in the model equation 1, it

is interesting to look at the correlation of the array power with each model term, as in figure 5. Here we plot the array power versus the corresponding term of the model, e.g. a times Irradiance, $a * I$, b times Irradiance squared, $b * I^2$, c times Irradiance times wind speed, $c * I * W$, and $d * I * T$. The strong correlation of the array power with the irradiance terms is immediately obvious. There is a great deal of noise and virtually zero correlation between array power and the wind and temperature terms, except for the extremely cold days (Feb 16, 2006, March 27, 28 2006 where the reported temperature was less than $-5 \text{ }^\circ\text{C}$).




Fig. 5. Correlations of array power with each independent term of the PVUSA TC model. Top left to bottom right: array power versus $a * I$, $b * I^2$, $c * I * w$, $d * I * T$. The values of a, b, c, and d developed from the model are used. Note the lack of strong correlation between wind speed and temperature components of the model and the array output, except for very cold ($T < -5 \text{ }^\circ\text{C}$) day [135 data points] in the bottom right graph.

7. UNCERTAINTY IN THE PTC RATING

The uncertainty in the PTC rating value depends on the magnitude of the measurement errors in the independent variables, the magnitudes of the fixed reporting conditions, and the sensitivity coefficients, equation 5.

7.1 NREL USSC 1.6 kW System Rating Uncertainty

An Excel spreadsheet was constructed which permits one to compute the absolute uncertainty in P at various combinations of I, W, and T, with assumed values of e_I , e_W , and e_T , of course incorporating equation 6.

Table 4 displays a typical result, with error terms (assumed for measurements) of $e_I = 25 \text{ Wm}^{-2}$, $e_W = 1 \text{ ms}^{-1}$, and $e_T = 1 \text{ }^\circ\text{C}$ for the USSC 1.6 kW system at NREL at each of the indicated plane of a array (POA) irradiance levels in column 1. The P_s 'error' result is computed from eq. 5 and the values in the columns to the left.

The results of these computations need to be combined with the measurement uncertainty in the array power, the

dependent variable of the model, to achieve an overall uncertainty for the entire method. If instrumentation similar to that described in table 2 above (used in the PV Energy Rating Testbed experiments) then the combined current, voltage, and power measurement uncertainty is 0.22%. Note the magnitude of the uncertainty in P_s (gray cell), 42 Watts, or about 2.8% of the rating. Compare this with the fact that 0.7% of the rating value, or 10.3 W, is contributed by the combined wind speed and temperature terms in the model equation. These latter two elements contribute to the rating value an amount that is 4 times smaller than the uncertainty contributed by the irradiance uncertainty. The 25 Wm^{-2} irradiance uncertainty is 2.5% of the rating irradiance value of 1000 Wm^{-2} . Such accuracy is representative of an exceptionally well

TABLE 4: UNCERTAINTY IN P AS FUNCTION OF UNCERTAINTY IN VARIABLES (USSC 1.6 kW)

POA kWm^{-2}	Note: $e_I = 25 \text{ Wm}^{-2}$, $e_W = 1 \text{ ms}^{-1}$, and $e_T = 1 \text{ }^\circ\text{C}$. PTC Rating = 1480 W.			P_s RSS ERROR	% error wrt 1480
	$(e_I * \partial/\partial I)^2$	$(e_W * \partial/\partial W)^2$	$(\partial/\partial T)^2$		
0.5	781.39	1.3	0.033	28.0	1.9%
0.6	942.90	1.9	0.047	30.7	2.1%
0.7	1119.57	2.6	0.064	33.5	2.3%
0.8	1311.41	3.4	0.084	36.3	2.5%
0.9	1518.40	4.3	0.106	39.0	2.6%
1.0	1740.56	5.2	0.131	41.8	2.8%
1.1	1977.87	6.3	0.158	44.5	3.0%

Mean residual when $990 \text{ Wm}^{-2} < \text{POA} < 1010 \text{ Wm}^{-2}$ is 2.5 W

calibrated and maintained pyranometer. This irradiance uncertainty in table 1 is typical. Combining the 2.8% combined uncertainty contributions from the independent variables with the 0.22% uncertainty in measured power, the overall uncertainty in the PVUSA TC approach for the USSC system tested is 2.8%.

7.2 Uncertainty in PVUSA Ratings for Other Systems

From PVUSA TC model coefficients for several large (~200 kW or larger) PV systems in a 1993 PVUSA project progress report [8]. IPC US-1, at Davis, CA and SSI-US-2 at Kerman systems were selected (page 3-9). We replicated the above calculations for these systems. The systems in tables 5 and 6 are much larger than the NREL, rated at ~190 kW and 500 kW, respectively. The units of power for the systems and the input irradiance in these cases are kW and kWm^{-2} .

Results in tables 4, 5 and 6, for assumed measurement uncertainty in irradiance, temperature, and wind speed of $\pm 25 \text{ Wm}^{-2}$, $\pm 1 \text{ }^\circ\text{C}$ and $\pm 1 \text{ ms}^{-1}$, respectively, show that the

derived uncertainty in the PVUSA TC results is between 2% and 3% at the rating condition. This uncertainty is primarily driven by the uncertainty in irradiance measurement (25 Wm^{-2} at $1000 \text{ Wm}^{-2} = 2.0\%$). Factors of 10 increases in the measurement errors for the temperature and wind speed hardly influence the resultant uncertainty at all. In these two cases, PVUSA quoted an uncertainty in their rating at

TABLE 5: UNCERTAINTY IN P AS FUNCTION OF UNCERTAINTY IN VARIABLES IPC US-1 DAVIS

POA kWm ⁻²	Note: $e_t=25 \text{ Wm}^{-2}$, $e_w = 1 \text{ ms}^{-1}$, and $e_r=1^\circ \text{ C}$ PVUSA* rating $192.25 \text{ kW} \pm 3 \text{ kW} = 1.6\%$. $a=282.14$ $b=-70.152$ $c=1.5824$ $d=-0.8998$			RSS Power Uncert (kW)	% error wrt 190 kW
	$(e_i * \partial/\partial i)^2$	$(e_w * \partial/\partial w)^2$	$(\partial/\partial t)^2$		
0.5	28.17	0.6	0.198	5.4	2.7%
0.6	24.59	0.8	0.285	5.1	2.6%
0.7	21.26	1.1	0.388	4.8	2.4%
0.8	18.17	1.4	0.506	4.5	2.3%
0.9	15.32	1.8	0.641	4.2	2.2%
1.0	12.71	2.3	0.792	4.0	2.0%
1.1	10.35	2.7	0.958	3.7	1.9%

*Quoted uncertainty by PVUSA; no documentation of derivation. Presumably model standard error

TABLE 6: UNCERTAINTY IN P AS FUNCTION OF UNCERTAINTY IN VARIABLES KERMAN

POA kWm ⁻²	Note: $e_t=25 \text{ Wm}^{-2}$, $e_w = 1 \text{ ms}^{-1}$, and $e_r=1^\circ \text{ C}$ PVUSA* Rating: $498.4 \pm 6 \text{ kW} = 1.2\%$. $a=701.1$ $b=-142.2$ $c=6.412$ $D=-3.384$			Power RSS Uncert	% error wrt 498 kW
	$(e_i * \partial/\partial i)^2$	$(e_w * \partial/\partial w)^2$	$(\partial/\partial t)^2$		
0.5	196.35	10.2	2.89	14.5	2.9%
0.6	177.16	14.7	4.16	14.0	2.8%
0.7	158.95	20.1	5.66	13.6	2.7%
0.8	141.73	26.2	7.39	13.2	2.7%
0.9	125.50	33.2	9.36	13.0	2.6%
1.0	110.25	41.0	11.56	12.8	2.6%
1.1	95.99	49.6	13.98	12.6	2.5%

*Quoted uncertainty by PVUSA; no documentation of derivation. Presumably model standard error

about 1/2 that of the analysis here; however there is no report of how the uncertainty was calculated.

7.3 Residual Analysis for the USSC PVUSA Model.

The residuals for the PVUSA TC (eq. 1) fit, and a linear and quadratic fit of the AC power as a function of irradiance alone (see figure 2) for the NREL USSC 1.6 kW system are shown in figure 6.

Note that the PVUSA TC model produces the widest range of residuals (Squares), due mainly to the additional wide

dispersion of the correlation of the AC power with respect to the wind and temperature components of the model shown in figure 5. The range of residuals for the linear (+) and quadratic (circles) fits are somewhat smaller. The mean residual for the PVUSA model is -0.56 W, however the mean residuals for the linear and quadratic fits are 10 orders of magnitude smaller and near very near zero ($1.6 \cdot 10^{-12} \text{ W}$ and $6.2 \cdot 10^{-12} \text{ W}$, respectively).




Fig. 6. Residuals between measured and modeled PTC (gray squares), and quadratic (open circle) and linear (+) fits of AC power versus irradiance alone for the USSC system.

This suggests that the addition of the wind speed and temperature terms in the PVUSA model *results in additional noise being introduced into the model*, and not improvement in the model performance.

Multicollinearity [9] between the ambient temperature and the irradiance, and the ‘weighting’ of the wind and temperature data by the irradiance term increases the multiple correlation coefficient of the PVUSA TC model, *but* increases the residuals to the fit, and results in a lower performance model than a simple linear or quadratic for of AC power versus irradiance.

The uncertainty in the irradiance measurements is the largest contributor to the uncertainty in the model results. To achieve a rating uncertainty of 1.0%, the uncertainty in the irradiance must be reduced to this level (better than $\pm 1\%$ accuracy). The only way to achieve this level or uncertainty is to apply incidence angle modifiers to the pyranometer data used to collect the irradiance data.

8. CONCLUSION

We applied the PVUSA rating system to a thin film dual junction 1.6 kW (nominal) PV system at NREL. Our analysis of the uncertainties associated with the

measurement instrumentation, and propagation of errors through sensitivity coefficients for the variables in the model equation demonstrated an uncertainty in the rating using the PVUSA PTC model of about 2.8 % for a rating of 1.480 kW, or ± 41 watts. Analogous results were obtained for two other larger PV systems reported by PVUSA. We have shown a lack of strong correlation between system output and two variables (wind speed, ambient temperature) in the PTC rating model. The lack of true independence in the ‘independent’ variable terms, or multicollinearity, engendered by multiplying these variables by irradiance, artificially inflates the correlation coefficient for the model, and may be adding noise to the model. Simple linear and quadratic regressions of AC power versus plane of array irradiance produce within 3% of the PVUSA TC results; with essentially same uncertainties (3%), the error bars about the simple and PVUSA TC results would overlap, and the results would be considered comparable. Residuals from the three fits essentially overlay one another, however the spread in the residuals from the PTC model have a somewhat larger spread. Measured AC power with POA irradiance within ± 0.5 watts of 1 kWm^{-2} , over several days produced a rating within 1.8% of the PTC rating, or within the PTC uncertainty.

From these results, we conclude that the PTC, simple linear and quadratic regression of AC power versus POA irradiance, and measured AC power near STC irradiance conditions all produce results (‘ratings’) within about 3% of each other, with similar uncertainties. The results from all four techniques are comparable, and have uncertainties on the order of 3%, mainly due to measurement system (particularly radiometer) uncertainties.

9. ACKNOWLEDGMENTS

NREL Outdoor Test Facility measurement data for the USSC system was kindly provided by Bill Marion and Peter McNutt. This work was supported by the U.S. Department of Energy under Contract No. DE-AC36-99GO10337 with the National Renewable Energy Laboratory.

10. REFERENCES

1. Whitaker, C.M., Townsend, T.U., Wenger, H.J., et al., “Effects of Irradiance and Other Factors on PV Temperature Coefficients” Proceedings”, 22nd IEEE Photovoltaic Specialists Conference, October 1991.
2. Whitaker, C.; Newmiller, J. . *Photovoltaic Module Energy Rating Procedure: Final Subcontract Report*, NREL/SR-520-23942, Golden, CO: National Renewable Energy Laboratory, 1998.
3. ASTM, ASTM E2527-09, “Standard Test Method for Rating Electrical Performance of Concentrator Terrestrial Photovoltaic Modules and Systems Under

- Natural Sunlight”, American Society for Testing and Materials, West Conshohocken, PA. 2009.
4. ASTM, ASTM E1036 - 08 “Standard Test Methods for Electrical Performance of Nonconcentrator Terrestrial Photovoltaic Modules and Arrays Using Reference Cells” American Society for Testing and Materials, West Conshohocken, PA. 2008.
5. Marion, B.; Kroposki, B.; Emery, K.; del Cueto, J.; Myers, D.; Osterwald, C. “Validation of a Photovoltaic Module Energy Ratings Procedure at NREL” NREL/TP-520-26909. National Renewable Energy Laboratory. 1999.
6. BIPM, “Guide to the Expression of Uncertainty in Measurement.” Published by ISOTAG 4, 1995. International Bureau of Weights and Measures (BIPM) Sevres, France. 1995.
7. Taylor, B. N., C E Kuyatt, “Guidelines for Evaluation and Expressing the Uncertainty of NIST Measurement Results.” NIST Technical Note 1297. National Institute of Standards and Technology. 1993.
8. PVUSA Project Team, 1993 PVUSA Project Report. PVUSA, 1993.
9. Myers, Raymond H. Classical and Modern Regression with Applications. Duxbury Press, Boston MA. 1986.

REPORT DOCUMENTATION PAGE

Form Approved
OMB No. 0704-0188

The public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing the burden, to Department of Defense, Executive Services and Communications Directorate (0704-0188). Respondents should be aware that notwithstanding any other provision of law, no person shall be subject to any penalty for failing to comply with a collection of information if it does not display a currently valid OMB control number.

PLEASE DO NOT RETURN YOUR FORM TO THE ABOVE ORGANIZATION.

1. REPORT DATE (DD-MM-YYYY) Revised July 2009		2. REPORT TYPE Conference Paper		3. DATES COVERED (From - To)	
4. TITLE AND SUBTITLE Evaluation of the Performance of the PVUSA Rating Methodology Applied to Dual Junction PV Technology: Preprint				5a. CONTRACT NUMBER DE-AC36-08-GO28308	
				5b. GRANT NUMBER	
				5c. PROGRAM ELEMENT NUMBER	
6. AUTHOR(S) D.R. Myers				5d. PROJECT NUMBER NREL/CP-550-45376	
				5e. TASK NUMBER PVD93110	
				5f. WORK UNIT NUMBER	
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) National Renewable Energy Laboratory 1617 Cole Blvd. Golden, CO 80401-3393				8. PERFORMING ORGANIZATION REPORT NUMBER NREL/CP-550-45376	
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES)				10. SPONSOR/MONITOR'S ACRONYM(S) NREL	
				11. SPONSORING/MONITORING AGENCY REPORT NUMBER	
12. DISTRIBUTION AVAILABILITY STATEMENT National Technical Information Service U.S. Department of Commerce 5285 Port Royal Road Springfield, VA 22161					
13. SUPPLEMENTARY NOTES					
14. ABSTRACT (Maximum 200 Words) The PVUSA (Photovoltaics for Utility Scale Applications) project in the 1990's developed a rating methodology for PV performance evaluation which has become popular, and even incorporated into concentrating PV rating standards. This report apply that method to rack-mounted dual-junction PV system, and produces a system rating.					
15. SUBJECT TERMS PFUSA; performance; concentrating solar; CSP, dual junction					
16. SECURITY CLASSIFICATION OF:			17. LIMITATION OF ABSTRACT UL	18. NUMBER OF PAGES	19a. NAME OF RESPONSIBLE PERSON
a. REPORT Unclassified	b. ABSTRACT Unclassified	c. THIS PAGE Unclassified			19b. TELEPHONE NUMBER (Include area code)

Standard Form 298 (Rev. 8/98)
Prescribed by ANSI Std. Z39.18