



# Timescales of Energy Storage Needed to Reduce Renewable Energy Curtailment: Report Summary

Paul Denholm and Trieu Mai

October, 2017

NREL/PR-6A20-70238

P. Denholm and T. Mai, "Timescales of energy storage needed for reducing renewable energy curtailment," NREL/TP-6A20-68960, 23 pp. (Sept 2017).

# Introduction

# Our goal

- Integrate large amounts of variable generation (VG) from wind and solar into a region's power grid,
- Minimize significant VG curtailment, and
- Preserve VG's environmental and economic value.

# Reaching this goal

This goal will likely require an increase in system flexibility by a combination of

- Changing grid operations, and
- Deploying enabling technologies.

# Energy storage as an enabler

Energy storage is of increasing interest because actual and projected prices of storage have declined.

But questions remain:

- What **amount and configuration** of storage is needed to reduce VG curtailment?
- How do we **value the multiple benefits** that storage offers VG integration and grid operations?

# Focus of our report

What we analyzed:

- The **storage duration** required to reduce VG curtailment under high-penetration (55%) VG scenarios.
- The **storage value** under varying storage durations.

## Some overarching remarks

- Our initial valuation approach can provide storage developers with insight on optimal storage sizing.
- We consider a 55% VG penetration, but are not implying that energy storage is required to reach this level.
- Multiple options exist for integrating VG, and their effectiveness should be evaluated with and without the use of storage.

# Timescales of Energy Storage

# What is energy storage size?

The size of energy storage is defined by

- **Power capacity**—rate of charge or discharge (in kilowatts or megawatts), and
- **Energy capacity**—amount of stored energy (in kilowatt-hours or megawatt-hours).

# Storage duration links these two capacities

**Storage duration**—amount of time that storage can discharge at its *power capacity* before depleting its *energy capacity*

- Consider a battery with
  - 1 MW of power capacity, and
  - 4 MWh of usable energy capacity

=> Its *storage duration* is 4 hours

# Energy-storage timescales and their applications

- **Seconds to minutes**
  - Operating reserves, including frequency regulation
- **Several hours**
  - Peaking capacity
  - Shifting energy from off-peak to peak periods
  - Ramp events
  - Daily mismatch of renewable supply and electricity demand
- **10 hours or more**
  - Arbitrage between weekday and weekend price differences
  - Seasonal mismatches

# Methods and Scenarios

# Our approach/methodology

- NREL's Renewable Energy Flexibility (REFlex) model
  - To dispatch the power system under each scenario
  - To analyze use of energy storage to avoid curtailment
- Assumptions
  - New transmission construction avoids significant transmission-related curtailment
  - All curtailment results from system-generation constraints.

- REFlex perform chronological dispatch of
  - Aggregated thermal and hydro units
  - Energy storage
- Simulations performed using 6 years (2007–2012) of
  - Historical load patterns
  - Corresponding wind and solar generation data
- Dispatch of increasing levels of VG to examine curtailment patterns and ability to avoid curtailment using energy storage.

# Our scenarios

- They are based on DOE's Wind Vision study, which examined the potential for wind to provide a large fraction of the nation's electricity supply.
- We examine a scenario where VG provides 55% of the electricity demand in the Electricity Reliability Council of Texas (ERCOT) grid system in 2050.
  - In 2016, ERCOT used wind generation to meet ~15% of its annual electricity demand.


# Three primary scenarios of 55% VG

<b>Scenario</b>	<b>% Wind</b>	<b>% PV</b>
<b>Wind Vision</b>	44	11
<b>Minimum Curtailment</b>	37	18
<b>Equal Mix</b>	27.5	27.5

# Adding wind and PV to our scenarios

- Adding wind
  - Calculate energy value
  - Estimate capacity credit
  - Estimate capacity value (= capacity credit x assumed annualized value of new capacity value in ERCOT)
- Adding PV
  - Select PV sites generated for SunShot 2030 study
  - Simulate PV at each site using SAM to generate hourly profiles for the 6 years of data.

# Calibrate aggregated minimum generation (1 of 2)



- Actual load, winds, and average price conditions in ERCOT on March 22–23, 1026.

## Calibrate aggregated minimum generation (2 of 2)


- 2016 minimum output was ~ 14,000 MW from 2 to 4 a.m. on March 23 (see blue band on previous chart)
  - Relatively low load and high wind output
  - Day-ahead price for energy fell to \$9/MWh
  - Assumed only modest increase in grid flexibility from now to 2050
  - Assumed all existing nuclear capacity receives license extension and operates at least until 2050.

Results:

## Curtailment in No-Storage Scenarios


- *Base Curtailment Levels*
- *Curtailment Patterns*

# Base curtailment levels (1 of 3)




- **Total VG curtailment rate** under increasing VG penetrations, with different mixes of wind and solar and no energy storage.

# Base curtailment levels (2 of 3)




- **Total VG energy curtailed** under increasing VG penetrations, with different mixes of wind and solar and no energy storage.

# Base curtailment levels (3 of 3)




- Total VG curtailed at an annual VG penetration of 55% as a function of wind/solar mix, with no energy storage.
- Wind/solar ratio that minimizes curtailment is 38% wind/17% solar (2.2:1)

# Curtailment patterns (1 of 4)




- **Simulated curtailment** during January 20–21 in ERCOT with no storage using 2012 wind, solar, and load patterns.
- Wind and solar have different diurnal and seasonal production patterns that impact duration of curtailment events and required storage duration.

# Curtailment patterns (2 of 4)




- **Duration curve of curtailment** at 55% VG in ERCOT with no storage using 2012 wind, solar, and load patterns.
- The scenarios have a large range in both instantaneous curtailment and length of curtailment events.

# Curtailment patterns (3 of 4)



- Distributions of **durations** of curtailment events with no storage using 2012 wind, solar, and load patterns.


# Curtailment patterns (4 of 4)



- Distributions of **energy** of curtailment events with no storage using 2012 wind, solar, and load patterns.


Results:  
Impact of Storage Capacity on  
Curtailment

# Impact of Storage on Curtailment (1 of 2)




- **Total curtailment** at 55% VG as a function of **storage power capacity** for the three study scenarios at varying storage durations.

# Impact of Storage on Curtailment (2 of 2)




- **Curtailment rate** at 55% VG as a function of **storage power capacity** for the three study scenarios at varying storage durations.
- With no storage: ~11%–16% of VG energy is curtailed
- With 8.5 GW storage capacity (using Wind Vision Mix):
  - VG curtailment is ~8%–10%
  - Curtailment is thus reduced by ~24%–38%
- **Impact: 4 hours of storage can substantially reduce curtailment**

# Diminishing returns with greater storage duration




- **Avoided curtailment** at 55% VG as a function of **storage power capacity** for the Equal-Mix and Wind Vision scenarios with varying amounts of additional storage duration.
- Additional storage duration and power capacity provides diminishing avoided-curtailment returns.

# Fixed storage capacity (8.5 GW)



- **Total curtailment** at 55% VG as a function of **storage duration** assuming 8.5 GW of storage power capacity for the three study scenarios.
- Storage capacity of 8.5 GW is equivalent to about one-third of ERCOT's projected peaking capacity in 2050.
- **Impact: Additional storage duration (beyond 8 hours) and power capacity yield diminishing returns with respect to avoided curtailment.**

# Avoided curtailment



- **Avoided curtailment** at 55% VG as a function of **storage duration** assuming 8.5 GW of storage power capacity for the three study scenarios.

## Further results

- Storage duration of 4 hours in the Wind Vision scenario avoids 35% of the curtailment that could be avoided with an 8.5-GW storage device of unlimited duration and about 70% in the Equal-Mix scenario.
- Storage duration of 8 hours would reduce curtailment by 49% (in Wind Vision scenario) and 88% (in Equal-Mix scenario), relative to an unlimited duration device.
- The incremental amount of avoided curtailment falls off rapidly when increasing storage duration beyond these levels, especially with greater amounts of PV.


# Results:

## Impact of Storage Duration on Value

# Value—more of the storage story

- **Capacity value**—the ability of storage to replace conventional peaking capacity.
  - Several U.S. markets award full capacity credit to devices with 4 hours of capacity, further decreasing the need for longer-duration storage.
- **Energy value**—stored, otherwise-curtailed energy that benefits from energy price arbitrage/time-shifting.
- There are many other values provided by energy storage that are not considered here.

# Annual capacity value




- **Capacity credit and annualized capacity value of storage** (value assumes avoided \$97/kW of firm capacity).

# Annual energy value (1 of 4)

Name	VG Penetration (%)	Wind/Solar Ratio	Natural Gas Price (\$/MMBtu)	CO <sub>2</sub> Cost (\$/ton)
Low Value	35	2.2:1	4	0
Medium Value	45	4:1	5	20
High Value	55	1:1	6	40


- Three cases evaluated

# Annual energy value (2 of 4)




- **Energy value** of energy storage under different cases.

# Annual energy value (3 of 4)



- **Total value of storage** as a function of storage duration.

# Annual energy value (4 of 4)



- **Incremental value** of energy storage, medium-value case.
- Once a storage device achieves the bulk of its value from the first few hours, the incremental value of additional energy is relatively low under a range of scenarios.


# Conclusions

# Overall conclusions

- Relatively short-duration energy storage may be an effective path to reduce VG curtailments at penetrations up to 55%.
- Across all mixes of wind and solar resources analyzed, at least half the potential avoided-curtailment benefits are realized with 8 hours of storage—and the first 4 hours provide the largest benefit.
- At VG penetrations up to 55%, very-long-duration or seasonal storage appears to provide little incremental benefit.


Additional slides

# Price-load data used in REFlex model




- Price and net load relationship in ERCOT in 2016.
- Graph used to determine marginal energy value of wind to site each wind cluster.

# Variation in curtailment



a) Full Range



b) At highest penetration levels

- Variation in curtailment across all six years of data in Wind Vision scenario, without storage.

[www.nrel.gov](http://www.nrel.gov)

