



# Grid Integration and Market Analysis of Adjustable-Speed Pumped Storage Hydropower

---

Erol Chartan  
HydroVision International 2019  
July 25<sup>th</sup> 2019

# NREL at a Glance

2,200

## Employees,

including postdoctoral researchers, interns, visiting professionals, and subcontractors



## World-class

facilities, renowned technology experts

over  
800

## Partnerships

with industry, academia, and government



## Campus

campus operates as a living laboratory

\$400M+  
annually

## Approximate Operating Budget

# How Valuable is Adjustable-Speed Pumped Storage Hydropower?

## **Situation**

Variable renewable energy is increasing, affecting variability and range of energy prices and requiring extra power system flexibility

## **Opportunity**



Adjustable-speed pumped storage hydropower (AS-PSH), can provide value to ancillary service markets and take benefit of energy arbitrage

## **Research**


Present results from production cost models showing the effects of adding 50 MW of AS-PSH to three Independent System Operators (ISOs)

# Production Cost Modeling

- Hourly or sub-hourly chronological
- Commits and dispatches generating and storage units based on:
  - Electricity demand
  - Operating parameters of generators and storage units
  - Transmission grid parameter
  - Reserve requirements
- Outputs for all generation, storage and transmission objects, including:
  - Generation profiles, start & shutdown costs, curtailment, emissions Reserve shortages and provision
  - Storage levels and operational profiles
  - Line and interface flows and congestion
  - Local marginal prices, unserved and dump energy



# Regions Modeled and Methodology




- Modeling 2024
- Minimizing total production cost
- Added AS-PSH can provide all modeled reserve services, as well as perform energy arbitrage

## Independent System Operator for New England (ISO-NE)

- 3327 nodes with thermal transmission constraints activated
  - Contingency Spinning Reserve – 10-minute timeframe, 824MW
  - Regulation up / down reserve – based on wind power forecast errors and a load component
- ## Californian Independent System Operator (CAISO) and North West Power Pool (NWPP)
- Flexibility reserve – based on wind power and solar power forecast errors and load forecasts
  - Spinning reserve – 10-minute timeframe, 3% of regional load

# Further Methodology



- CAISO and NWPP were taken from a larger study, Low Carbon Grid Study
- Save run-time and improve fidelity

For all three modeled regions:

1. Simulate the base case
2. Add the AS-PSH unit and simulate again
3. Compare differences

# The AS-PSH Turbine

Property	Value
Generation Capacity	50 MW
Pumping Capacity	50 MW
Storage Quantity	12 hours
Round Trip Efficiency	80 %
Ramp Rate	Infinite
Variable Operational and Maintenance Cost	0, \$
Minimum Generation Level	0 MW
Minimum Pumping Level	0 MW

Note: The production cost model optimizes each time-step as a mixed integer linear program, MILP. In CAISO, 8 turbines were added; following results are all for a single turbine.

Minimizing system cost – we can analyze production cost and curtailment savings.

# Results

	<b>Production Cost Saving, \$</b>		<b>Curtailment Saving, %</b>	
<b>Region</b>	<b>Day-Ahead</b>	<b>Real-Time</b>	<b>Day-Ahead</b>	<b>Real-Time</b>



# Results

	<b>Production Cost Saving, \$</b>		<b>Curtailment Saving, %</b>	
<b>Region</b>	<b>Day-Ahead</b>	<b>Real-Time</b>	<b>Day-Ahead</b>	<b>Real-Time</b>
CAISO (modeled with no transmission constraints)				
ISO-NE (modeled with transmission constraints)				
NWPP (modeled with no transmission constraints)				

# Results

<b>Region</b>	<b>Production Cost Saving, \$</b>		<b>Curtailment Saving, %</b>	
	<b>Day-Ahead</b>	<b>Real-Time</b>	<b>Day-Ahead</b>	<b>Real-Time</b>
CAISO (modeled with no transmission constraints)	Negligible			
ISO-NE (modeled with transmission constraints)	Negligible			
NWPP (modeled with no transmission constraints)	Negligible			

“Negligible” refers to results within the error tolerance.

The day-ahead has a 24-hour foresight.

# Results

Region	Production Cost Saving, \$		Curtailment Saving, %	
	Day-Ahead	Real-Time	Day-Ahead	Real-Time
CAISO (modeled with no transmission constraints)	Negligible		Negligible	
ISO-NE (modeled with transmission constraints)	Negligible		None	
NWPP (modeled with no transmission constraints)	Negligible		None	

ISO-NE and NWPP had no curtailment in the base case. CAISO did, due to a high penetration of variable renewable energy.

# Results

<b>Region</b>	<b>Production Cost Saving, \$</b>		<b>Curtailment Saving, %</b>	
	<b>Day-Ahead</b>	<b>Real-Time</b>	<b>Day-Ahead</b>	<b>Real-Time</b>
CAISO (modeled with no transmission constraints)	Negligible	Negligible	Negligible	
ISO-NE (modeled with transmission constraints)	Negligible		None	
NWPP (modeled with no transmission constraints)	Negligible	Negligible	None	

Storage is a net-user of energy and generally adds production cost, unless there is significant variation of prices (energy arbitrage) or reserve shortage.

Running as a single region suppresses prices.

# Results

	<b>Production Cost Saving, \$</b>		<b>Curtailement Saving, %</b>	
<b>Region</b>	<b>Day-Ahead</b>	<b>Real-Time</b>	<b>Day-Ahead</b>	<b>Real-Time</b>
CAISO (modeled with no transmission constraints)	Negligible	Negligible	Negligible	
ISO-NE (modeled with transmission constraints)	Negligible	2,850,000 – 5,293,000	None	
NWPP (modeled with no transmission constraints)	Negligible	Negligible	None	

The AS-PSH unit can contribute to reserves in the real-time market.

Variable renewable energy forecast errors encourage higher reserve provisions.

As ISO-NE is multi-nodal, the analysis was done for a selection of nodes.

# Results

Region	Production Cost Saving, \$		Curtailment Saving, %	
	Day-Ahead	Real-Time	Day-Ahead	Real-Time
CAISO (modeled with no transmission constraints)	Negligible	Negligible	Negligible	Saves 1.3% compared to Base
ISO-NE (modeled with transmission constraints)	Negligible	2,850,000 – 5,293,000	None	Negligible
NWPP (modeled with no transmission constraints)	Negligible	Negligible	None	Negligible

CAISO experiences significant curtailment in the real-time market.

Due to an ability for variable pumping output, the AS-PSH unit absorbs this well.

# Conclusion

ISO-NE saw large savings in production costs. With the additional value of load-shifting, this production cost saving would be potentially even higher.

The flexibility of NWPP in 2024 is expected to be sufficient, without considering transmission constraints.

In CAISO, the pump turbine provides system value, which is expected to increase as variable renewable energy penetration increases.

Thank you,

Any Questions?



---

[www.nrel.gov](http://www.nrel.gov)

NREL/PR-5D00-74348

This work was authored in part by the National Renewable Energy Laboratory, operated by Alliance for Sustainable Energy, LLC, for the U.S. Department of Energy (DOE) under Contract No. DE-AC36-08GO28308. Funding provided by the U.S. Department of Energy Office of Energy Efficiency and Renewable Energy Water Power Technologies Office. The views expressed in the article do not necessarily represent the views of the DOE or the U.S. Government. The U.S. Government retains and the publisher, by accepting the article for publication, acknowledges that the U.S. Government retains a nonexclusive, paid-up, irrevocable, worldwide license to publish or reproduce the published form of this work, or allow others to do so, for U.S. Government purposes.



# Results – ISO-NE Nodal

## Production Cost for All Regions from Real-Time (\$000)

Node	Base	Pump Turbine	Savings
Highest load	6,354,238	6,351,126	3,112
Day-ahead highest peak price	6,354,238	6,348,945	5,293
Large wind power plant	6,354,238	6,349,712	4,526
Day-ahead highest energy generated	6,354,238	6,350,251	3,988
Real-time highest peak price	6,354,238	6,351,388	2,850

Real-time – therefore all reserve contribution.

Order of savings magnitude is the same as the order of reserve provision met.

# Results – ISO-NE Nodal

Node	Up-Regulation	Down-Regulation	Contingency Spinning	Total (GWh)
	Reserve (GWh)	Reserve (GWh)	Reserve (GWh)	
Day-ahead highest load	3.6	0.5	33.5	37.6
Day-ahead highest peak price	6.3	0.5	31.7	38.6
Large wind power plant	7.3	0.4	30.2	37.9
Day-ahead highest energy generated	3.8	0.5	33.4	37.7
Real-time highest peak price	4.6	0.4	32.3	37.3

# Price-Taker Results (400 MW)

Turbine Type	ISO-NE Energy Arbitrage Revenue Potential, \$million		CAISO Energy Arbitrage Revenue Potential, \$	
	Day-Ahead	Real-Time	Day-Ahead	Real-Time
C-PSH	11.8	39.9	7.7	50.4
AS-PSH	11.8	40	7.7	50.4