

ADMS Performance: VVO Application on Xcel Energy Feeders

Shibani Ghosh

Researcher, Grid Automation & Control

Shibani.Ghosh@nrel.gov

Workshop on Advanced Distribution
Management System (ADMS) Test Bed

November 13, 2019

Data Remediation




Advanced Grid
Research

OFFICE OF ELECTRICITY
US DEPARTMENT OF ENERGY

Evaluate performance of the ADMS VVO* application for different levels of model quality and different levels of measurement density:

- Performance improvements from accurate model
 - Offset model inaccuracies with additional telemetry
 - Trade-off between model quality and telemetry density.
-
- Results from this project inform ADMS Test Bed Use Case 1.



*Advanced distribution management system volt/VAR optimization

ADMS Deployment



Advanced Grid
Research

OFFICE OF ELECTRICITY
US DEPARTMENT OF ENERGY

What level of data remediation does the utility need for a successful deployment?

How many and which type(s) of sensors need to be installed for optimal ADMS performance?

What is the impact of the lower data remediation level on the performance of ADMS and its applications?

How much will additional remediation improve the ADMS performance?

Levels of Model Quality




Advanced Grid
Research

OFFICE OF ELECTRICITY
US DEPARTMENT OF ENERGY

- **Level 1 (Q1):** Base-level data extracted from the Xcel Energy Geographic Information System (GIS) adjusted just enough for power flow convergence
- **Level 2 (Q2):** In addition to Level 1, field verification at select locations to obtain wire size/material (if unknown), capacitor, regulator, recloser, and step transformer attributes (locations noncontiguous)
- **Level 3 (Q3):** In addition to Level 2 remediation, phasing information collected through field verification at select locations
- **Level 4 (Q4):** In addition to Level 3, field confirmation performed for each primary circuit to obtain distribution transformer attributes, identifying new assets not shown in the GIS data and identifying assets that no longer exist in the field.

Levels of Measurement Density



Advanced Grid
Research

OFFICE OF ELECTRICITY
US DEPARTMENT OF ENERGY

Level 1 (D1): Feeder-head and tail-end measurements.

Level 2 (D2): Measurements from Level 1, voltage regulators, capacitor banks, reclosers, and one tail-end voltage sensor (advanced metering infrastructure [AMI] sensor) per feeder with communications

Level 3 (D3): Measurements from Level 2 and a total of 10 AMI sensors per feeder

Level 4 (D4): Measurements from Level 2 and a total of 20 AMI sensors per feeder.


Test Setup



Advanced Grid
Research

OFFICE OF ELECTRICITY
US DEPARTMENT OF ENERGY

ADMS under test



Test Setup: VVO Settings



Advanced Grid
Research

OFFICE OF ELECTRICITY
US DEPARTMENT OF ENERGY

Conservation
voltage
reduction
(CVR)

Objective functions

Power consumption reduction

Power factor improvement

Active power losses reduction

Consumer voltages improvement

VAR control

Constraints

Consumer voltage

Medium voltage

AMI voltage

Power factor measurements

Voltage unbalance index

Test Setup: VVO Configuration



Advanced Grid
Research

OFFICE OF ELECTRICITY
US DEPARTMENT OF ENERGY

Profile Editor

Basic | **Advanced** | Verification | Resources | CVR Settings

Approved:

Profile name: VVO_Profile1_CVR_3012

Profile description:

> Objective functions

> Constraints

Consumer voltage

114.0 ≤ V ≤ 126.0 Deadband: 0.0 [V-120] Emergency limits

Medium voltage

114.0 ≤ V ≤ 126.0 Deadband: 0.6 [V-120]

AMI voltage

114.0 ≤ V ≤ 126.0 Deadband: 0.6 [V-120]

Low voltage reading

114.0 ≤ V ≤ 126.0 Deadband: 0.6 [V-120]

> High constraints

OK Cancel

Test Setup: Daily Simulations



Advanced Grid
Research

OFFICE OF ELECTRICITY
US DEPARTMENT OF ENERGY



VVO configuration: Select objective/constraints



Feeder: Select feeder to perform VVO (CVR)



Days: Select days (load profiles, loading levels)



Data: Collect required data for post-processing

Selected Feeders



**Advanced Grid
Research**

OFFICE OF ELECTRICITY
US DEPARTMENT OF ENERGY

Feeder	Type	Circuit Miles (apprx.)	Customers (#)	Underground (UG %) / Overhead (OH %)	Peak Load (MW, apprx.)
Feeder 1	Rural	80	1571	54/46	1.07
Feeder 2	Rural	125	2143	70/30	7.13
Feeder 3	Semi-urban	47	2799	87/13	6.73
Feeder 4	Urban	22	477	13/87	12.34
Feeder 5	Urban	14	351	25/75	11.3
Feeder 6	Urban	61	2880	73/27	12.46


Test Metrics



Advanced Grid Research

OFFICE OF ELECTRICITY
US DEPARTMENT OF ENERGY

Test Metric	Description
CVR energy reduction	Feeder energy consumption before and after application of CVR
System average voltage fluctuation index	Average voltage fluctuations for all nodes within the time period. Represents the flatness of the voltage profile
System control device Operation index	<ul style="list-style-type: none"> i. Number of times the capacitor banks were turned on or off ii. Number of times the LTC/voltage regulators were operated
Capacitor bank operations, load tap changer (LTC), or voltage regulator operations	
System energy loss index	Ratio of total energy loss during the entire simulation time to the total load
Power factor	Power factor computed at selected nodes



Results: Voltage Reduction





Advanced Grid
Research

OFFICE OF ELECTRICITY
US DEPARTMENT OF ENERGY

Feeder 1 (rural, even mix of underground and overhead assets)

Q1D1 Scenario

Q4D4 Scenario




Results: Voltage Violations



Advanced Grid
Research

OFFICE OF ELECTRICITY
US DEPARTMENT OF ENERGY

Feeder 1 (rural, even mix of underground and overhead assets)



Results: Energy Savings with VVO




Advanced Grid Research


OFFICE OF ELECTRICITY
US DEPARTMENT OF ENERGY

Feeder 1 (rural, even mix of underground and overhead assets)

Energy consumption estimates (MWh)



Power (MW, daily median)



Results: Energy Savings with VVO




Advanced Grid
Research


OFFICE OF ELECTRICITY
US DEPARTMENT OF ENERGY

Feeder 2 (rural, mostly underground assets)

Energy consumption estimates (MWh)



Power (MW, daily median)



Results: Energy Savings with VVO




Advanced Grid Research


OFFICE OF ELECTRICITY
US DEPARTMENT OF ENERGY

Feeder 6 (longest urban, 73% underground assets)

Energy consumption estimates (MWh)



Power (MW, daily median)



Findings



Advanced Grid
Research

OFFICE OF ELECTRICITY
US DEPARTMENT OF ENERGY

Impacts of
feeder
features

Impacts of
model
quality

Impacts of
measure-
ment
density

Impacts of
loading
conditions

Findings: Summary



Advanced Grid
Research

OFFICE OF ELECTRICITY
US DEPARTMENT OF ENERGY

- **Model quality** impacts are less evident on urban feeders because they are relatively new and have been field-verified in recent years.
- **Rural feeders** show better improvement on energy savings under VVO application with different levels of model improvement.
- For a **long feeder**, VVO function might not perform CVR well enough because of narrow margin to reduce voltage/energy consumption at feeder-end locations.
- **Measurement density levels** generally have less pronounced impact than model quality levels.
- With same VVO settings, **high-loading conditions** might create more voltage violations than **low-loading** conditions with same model quality.

Thank you

Shibani.Ghosh@nrel.gov

www.nrel.gov

NREL/PR-5D00-75413



Advanced Grid
Research

OFFICE OF ELECTRICITY
US DEPARTMENT OF ENERGY



This work was authored in part by the National Renewable Energy Laboratory, operated by Alliance for Sustainable Energy, LLC, for the U.S. Department of Energy (DOE) under Contract No. DE-AC36-08GO28308. Funding provided by U.S. Department of Energy Office of Electricity and Xcel Energy through a Cooperative Research and Development Agreement (CRD-05-167). The views expressed in the article do not necessarily represent the views of the DOE or the U.S. Government. The U.S. Government retains and the publisher, by accepting the article for publication, acknowledges that the U.S. Government retains a nonexclusive, paid-up, irrevocable, worldwide license to publish or reproduce the published form of this work, or allow others to do so, for U.S. Government purposes.

NREL is a national laboratory of the U.S. Department of Energy, Office of Energy Efficiency and Renewable Energy, operated by the Alliance for Sustainable Energy, LLC.