

# DCFC + Hydrogen Station Design Optimization

Josh Eichman, Dylan Cutler,  
Michael Peters, and Cory Kreutzer

September 3, 2020

# Agenda

- Project motivation and background
- Scenarios
- Assumptions
- Summary of Results
  - DCFC + Hydrogen station
  - Benefit of installing PV
  - Value of co-location with site load
  - 15-min versus 1-hr resolution
- Recommendations
- Future work

# Motivation and background


- Both DCFC and Hydrogen stations are working to create successful long-term business models; however, analyses for DCFC and H<sub>2</sub> fueling infrastructure are almost always performed separately.
- Early work at UC Davis by Burke, et al. to integrate DCFC and H<sub>2</sub> stations shows that there is **potential to reduce the combined fueling/charging system costs**
  - <https://ncst.ucdavis.edu/project/deployment-sustainable-fuelingcharging-systems-california-highway-safety-roadside-rest>
- Building on the previous findings, this work provides a detailed exploration of the **benefit of integrating DCFC and hydrogen stations to lower the total system cost from load balancing and equipment cost sharing**.
- To achieve this we have adapted the REopt optimization framework<sup>†</sup> to simultaneously optimize the design and operation of integrated DCFC and H<sub>2</sub> fueling station.

<sup>†</sup> See the next slide for more information.

# System configuration

- REopt is a techno-economic decision support platform used to optimize the sizing, siting and operation of energy systems. (more details can be found at <https://reopt.nrel.gov/>)

## REopt: Station optimization flowchart



# Scenarios

- We examine different configurations of DCFC and hydrogen stations.
- We allow batteries to be installed for each scenario (if cost-effective).
- The model is run for an entire year.
- Additionally, we perform several sensitivities:
  - Benefit of installing PV
  - Co-location with site load reflecting a supermarket
  - 15-min versus 1-hr resolution

Fueling station	Fueling details	
DCFC Only †	4 plug low utilization (150kW each w/ 2.36% load factor)	
	4 plug (150kW each with 13.7% load factor)	
	20 plug (150kW each with 20.7% load factor)	
Hydrogen Only ‡	1 position, low use (100kg/day, 54% load factor, 20-30 vehicles per day)	
	2 position, high use (400kg/day, 54% load factor, 80-115 vehicles per day)	
Combined DCFC + Hydrogen	4 plug DCFC (low utilization)	1 position, low use (H <sub>2</sub> )
	4 plug DCFC	1 position, low use (H <sub>2</sub> )
	20 plug DCFC	1 position, low use (H <sub>2</sub> )
	4 plug DCFC (low utilization)	2 position, high use (H <sub>2</sub> )
	4 plug DCFC	2 position, high use (H <sub>2</sub> )
	20 plug DCFC	2 position, high use (H <sub>2</sub> )

† Based on 2017 EVgo data for 50kW charging

‡ Based on data from NREL's [National Fuel Cell Technology Evaluation Center](#)

# Assumptions

- Sites receive retail electricity service on [Southern California Edison GS-TOU-1 option B](#) (high energy charge, low demand charge) or [Consolidated Edison SC-9](#) (low energy charge, high demand charge)
- DCFC <sup>1</sup> : \$150,000/plug includes equipment and installation
- Hydrogen <sup>2,3,4,5,6</sup>
  - Electrolyzer: \$1,690/kW, \$94/kW-yr, 54.6 kWh/kg, 20-year life
  - Compressor: \$21,730-\$35,600/kg-hr, 5.9 kWh/kg, 10-year life
  - Low pressure storage: \$839/kg, 20-year life
  - High pressure storage: \$1,547/kg, 20-year life
  - Vehicle dispenser: \$50,000 (low scenario), \$200,000 (high)
- Lithium-ion Battery <sup>7</sup> : \$840/kW, \$420/kWh, 10-year life
- Solar photovoltaic <sup>7</sup> : \$1,600/kW, \$16/kW-yr, 20-year life
- Financial <sup>7</sup>: 8.3% discount rate, 2.3% electricity cost escalation, and 25-year project lifetime

Doesn't include land or permitting

Includes land and permitting for electrolyzer, and only equipment costs for compressor, storage and dispenser

Doesn't include grid interconnection cost



Sources:

1. forthcoming NREL-DOE report
2. H2A Current Forecourt Electrolyzer (<https://www.nrel.gov/hydrogen/h2a-production-case-studies.html>)
3. H2FIRST Reference Station Design Task (<https://www.nrel.gov/docs/fy15osti/64107.pdf>)
4. Hydrogen station technical status and costs (<https://www.nrel.gov/docs/fy14osti/58564.pdf>)
5. Hydrogen component validation ([https://www.hydrogen.energy.gov/pdfs/review17/tv019\\_terlip\\_2017\\_p.pdf](https://www.hydrogen.energy.gov/pdfs/review17/tv019_terlip_2017_p.pdf))
6. Estimate from NFCTEC data
7. REopt Defaults (<https://reopt.nrel.gov/tool/REopt%20Lite%20Web%20Tool%20User%20Manual.pdf>), leveraging NREL's 2019 Annual Technology Baseline, Lazard, and U.S. Energy Storage Monitor

# Standalone DCFC



- Cost components are broken down for each scenario.
- The California rate has higher energy charges and lower demand charges, while the New York rate is the opposite.
- The cost of electricity is much greater than the capital cost.
- Because of the demand charge, larger battery storage is installed at the New York sites.

4\_lu = 4 plugs, low utilization



# Standalone Hydrogen

- Capital cost plays a more significant role for hydrogen fueling stations.
- Electrolyzer flexibility reduces the ratio of demand charges to energy charges.
- Because of the existing electrolyzer flexibility, batteries are not cost effective.






# Comparison Methodology

## Separated systems


(forms baseline by adding results for separate station optimizations)



**vs.**


## Optimized system

(Combine DCFC and hydrogen stations at the same site and optimize their operation)



# Value of combining fueling/charging stations

- Combining DCFC and hydrogen stations results in a **savings of up to 8.7%** of the total life cycle costs.
- Combining hydrogen with DCFC **reduces the need for a battery**
- The savings is highly dependent on the fueling/charging needs; however, it appears that matching consumption between fueling and charging results in the greatest benefit (e.g., 4 plug DCFC and low hydrogen use; 20 plug and high hydrogen use).




4\_lu = 4 plugs, low utilization

# Value of Adding PV

- While all sites benefit from adding PV (reduced LCC), its relative % savings impact varies across sites
  - Note that CA sites always benefit from PV and more substantially so
- We recognize that land is not available at all fueling/charging stations; however, PV integration should be considered when possible.

4\_lu = 4 plugs, low utilization



# Comparison Methodology: Site load

## Separated Systems


(forms baseline by adding results for separate stations and site load only optimizations)



**VS.**

## DCFC + Site


(this scenario adds site load to the DCFC system to understand the impact of co-location with site load)



**VS.**

## DCFC + H2

(this scenario considers a combined DCFC and H2 station and standalone site load to complete the scenarios necessary to analyze the impact of site load)




# Impact of Co-location: NY

- Co-location with a supermarket load in NY can reduce DCFC system costs by 0.5-3.3%
- However, DCFC + hydrogen can reduce costs by 1.9-7.7%.
- Both battery and hydrogen system size decrease in the DCFC + H2 case, delivering larger savings and reduced upfront costs

Electrolyzer (kg/hr)	7.2	7.2	6.6
Low Pressure Storage (kg)	177.0	177.0	141.7
Compressor (kg/hr)	4.4	4.4	4.4
High Pressure Storage (kg)	70.5	70.5	75.6
Battery (kWh)	233.6	183.1	60.3
Inverter (kW)	103.4	89.2	28.5
Solar PV (kW)	0.0	0.0	0.0



4\_lu = 4 plugs, low utilization






# Evaluating 15-min Impacts

- Comparing % savings moving from 1-hour to 15-min resolution
- Greater savings with 15min analysis



# A closer look: DCFC only


New York Rate with 4 plug high utilization DCFC and no hydrogen consumption







# A closer look: Hydrogen only

New York Rate without DCFC and low hydrogen consumption



# A closer look: Combined

New York Rate with 4 plug high utilization DCFC and low hydrogen consumption



# Caveats

What this study does:

- Compares the benefits for combining fueling/charging technologies with a variety of sensitivities.

What this study does not do:

- Predicts changes in fueling/charging demand over the lifetime of the equipment.
- Estimates site installation and utility interconnection upgrade costs.
- Considers flexibility opportunities in the DCFC demand.

# Summary of findings

- **Combining hydrogen fueling and DCFC stations can significantly reduce lifetime costs** compared to separated stations.
- **Co-location** with additional site load **reduces DCFC costs**, however, **integration of DCFC with hydrogen provides an even greater cost reduction.**
- **Adding PV** to combined stations **further reduces the lifetime station cost.**
- **Capital investments** in station combination today **can help reduce the cost of operating** DCFC tomorrow.
- **Product diversification** acts as a **hedge against variability** and enables a **more dynamic response to market changes.**

# Future work

- Expand concept to include heavy-duty BEV charging and FCEV fueling.
- Perform a hardware-in-the-loop evaluation of DCFC + Hydrogen station designs based on the results of this work
  - Funded by DOE Hydrogen and Fuel Cell Technology Office
  - To be completed this year
  - We are interested in stakeholder feedback so please contact us to learn how you can get involved.

# Thank you

---

[www.nrel.gov](http://www.nrel.gov)

NREL/PR-5400-77799

This work was authored by the National Renewable Energy Laboratory, operated by Alliance for Sustainable Energy, LLC, for the U.S. Department of Energy (DOE) under Contract No. DE-AC36-08GO28308. Funding provided by the U.S. Department of Energy Office of Energy Efficiency and Renewable Energy Hydrogen and Fuel Cell Technologies Office. The views expressed in the article do not necessarily represent the views of the DOE or the U.S. Government. The U.S. Government retains and the publisher, by accepting the article for publication, acknowledges that the U.S. Government retains a nonexclusive, paid-up, irrevocable, worldwide license to publish or reproduce the published form of this work, or allow others to do so, for U.S. Government purposes.




# CA Graphics

---

# Value of combining fueling/charging stations: CA

- Combining DCFC and hydrogen stations results in a **savings of up to 4.2%** of the total life cycle costs for CA sites.
- The savings is highly dependent on the fueling/charging needs; however, it appears that matching consumption between fueling and charging results in the greatest benefit (e.g., 4 plug DCFC and low hydrogen use; 20 plug and high hydrogen use).




4\_lu = 4 plugs, low utilization




# Value of Adding PV: CA

- While all sites benefit from adding PV, CA sites benefit the most.
- We recognize that land is not available at all fueling/charging stations; however, PV integration should be considered when possible.





# Impact of Co-location: CA

- Co-location with a supermarket load can slightly reduce DCFC system costs
- However, DCFC + hydrogen stations have the potential to reduce cost significantly beyond DCFC + co-location.



# Evaluating 15-min Impacts

- Comparing % savings moving from 1-hour to 15-min resolution
- Greater savings with 15min analysis



# System Sizes - NY

Location	NY	NY	NY	NY	NY	NY
H2 Load	Low	Low	Low	High	High	High
DCFC (plugs)	4	4 Low	20	4	4 Low	20

	1	1	2	2	3	3	4	4	5	5	6	6
Electrolyzer (kg/hr)	7.2	6.6	7.2	5.8	7.2	5.8	28.6	28.7	28.6	27.8	28.6	26.3
Low Pressure Storage (kg)	177.0	141.7	177.0	95.3	177.0	53.0	707.4	702.0	707.4	664.5	707.4	369.1
Compressor (kg/hr)	4.4	4.4	4.4	4.4	4.4	4.3	17.5	17.9	17.5	18.2	17.5	17.8
High Pressure Storage (kg)	70.5	75.6	70.5	72.2	70.5	71.0	277.9	309.7	277.9	297.9	277.9	287.0
Battery (kWh)	200.2	26.9	596.5	47.4	2,000.6	744.6	214.6	78.0	610.9	163.9	2,014.9	58.3
Inverter (kW)	95.3	20.4	169.7	36.0	461.7	310.1	96.0	38.1	170.4	59.0	462.4	44.2
Solar PV (kW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

# System Sizes - CA

Location	CA	CA	CA	CA	CA	CA
H2 Load	Low	Low	Low	High	High	High
DCFC (plugs)	4	4 Low	20	4	4 Low	20

	1	1	2	2	3	3	4	4	5	5	6	6
Electrolyzer (kg/hr)	4.3	4.4	4.3	4.9	4.3	4.6	17.1	17.1	17.1	17.4	17.1	19.9
Low Pressure Storage (kg)	7.7	14.8	7.7	31.3	7.7	22.3	30.2	30.9	30.2	46.8	30.2	117.9
Compressor (kg/hr)	4.3	4.4	4.3	4.3	4.3	4.4	17.1	17.2	17.1	17.3	17.1	17.7
High Pressure Storage (kg)	68.9	68.6	68.9	71.3	68.9	70.4	274.8	273.1	274.8	269.0	274.8	274.5
Battery (kWh)	51.9	0.0	69.2	0.0	188.3	0.0	51.9	0.0	69.2	0.0	188.3	0.0
Inverter (kW)	39.3	0.0	52.4	0.0	142.8	0.0	39.3	0.0	52.4	0.0	142.8	0.0
Solar PV (kW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

# Snapshot of consumption profiles

- Hydrogen consumption profile for 1 example week out of the year
- DCFC electricity consumption for 1 example week out of the year
- Site load for 1 example week out of the year

