



## OPEN ACCESS

EDITED AND REVIEWED BY  
ZhaoYang Dong,  
Nanyang Technological University,  
Singapore

\*CORRESPONDENCE  
Haoran Ji,  
✉ jihaoran@tju.edu.cn

SPECIALTY SECTION  
This article was submitted  
to Smart Grids,  
a section of the journal  
Frontiers in Energy Research

RECEIVED 26 November 2022  
ACCEPTED 06 December 2022  
PUBLISHED 06 January 2023

CITATION  
Li P, Peng Y, Ji H, Ding F and Xi W (2023),  
Editorial: Edge computation and digital  
distribution networks.  
*Front. Energy Res.* 10:1108698.  
doi: 10.3389/fenrg.2022.1108698

COPYRIGHT  
© 2023 Li, Peng, Ji, Ding and Xi. This is  
an open-access article distributed  
under the terms of the [Creative  
Commons Attribution License \(CC BY\)](#).  
The use, distribution or reproduction in  
other forums is permitted, provided the  
original author(s) and the copyright  
owner(s) are credited and that the  
original publication in this journal is  
cited, in accordance with accepted  
academic practice. No use, distribution  
or reproduction is permitted which does  
not comply with these terms.

# Editorial: Edge computation and digital distribution networks

Peng Li<sup>1</sup>, Yonggang Peng<sup>2</sup>, Haoran Ji<sup>1\*</sup>, Fei Ding<sup>3</sup> and Wei Xi<sup>4</sup>

<sup>1</sup>Key Laboratory of the Ministry of Education on Smart Power Grids, Tianjin University, Tianjin, China, <sup>2</sup>College of Electrical Engineering, Zhejiang University, Hangzhou, China, <sup>3</sup>National Renewable Energy Laboratory (DOE), Golden City, MO, United States, <sup>4</sup>China Southern Power Grid, Guangzhou, China

## KEYWORDS

editorial, digital distribution networks, edge computation, operation control, simulation

## Editorial on the Research Topic

### Edge Computation and Digital Distribution Networks

## Introduction

The development of digital technologies is penetrating all areas of energy revolution. Based on the in-depth integration of advanced digital technologies, distribution networks are gradually transforming into digital distribution networks (DDNs) with tremendous changes from the structure to the operation mode. DDNs is the digitalized appearance of the physical distribution network, in which ubiquitous connections and massive data are the basic characteristics (Huo et al., 2022). It is an important task to utilize the massive data and propose novel operation modes to construct more efficient and intelligent distribution networks (Jian et al., 2022). Among the advanced digital technologies in DDNs, edge computing has received wide attention (Zhao et al., 2022). It has superior performance in local sensing and intelligent computation, which can effectively relieve huge communication pressure. However, the limited computing resources and the complex computing tasks at the edge side significantly challenge the collaboration of distribution network regulation and advanced digital technologies (Hu et al., 2022). It is necessary to find out proper methods to utilize advanced digital technology to construct DDNs.

This Research Topic is organized to introduce the recent progress in the construction, operation and advanced computational methods for DDNs. Finally, seven papers have been accepted, which can be sorted into the following three categories: 1) Evolution and technical features of DDNs, 2) Intelligent operation control of DDNs, 3) Advanced simulation for large-scale DDNs. The three sections below respectively introduce the major research and contributions of the papers covered in each category.

## Evolution and technical features of DDNs

The development of digital technology and power electronic technology can support fully flexible interconnection of distribution networks. Research on the evolution and technical features of physical distribution networks is the foundation of operation control of DDNs.

Wang et al. present a honeycomb grid structure for the multi-station integrated system with soft open points (SOP) as flexible nodes. The hydrogen-electricity coupling structure and the conversion strategy of hydrogen and electricity are proposed for the deep application of hydrogen energy.

## Intelligent operation control of DDNs

The increasing integration of novel devices with customized user demands will challenge system operation due to high randomness and complexity. The intelligent operation control is desired to comprehensively facilitate the secure, economical, and efficient operation of DDNs.

Cao et al. design a distributed resilient enhancement method in cyber-physical microgrids to cope with control failure by false data injection attack (FDIA). Based on the synchronous mitigation framework, the consensus communication coupling gain is corrected to delete the attack signal. It can reduce the complexity of the conventional controller design.

Wang et al. propose an adaptive forecasting method for community integrated energy system (CIES) based on deep transfer learning. The hour-level local features and day-level coarse-grained features of CIES are extracted with a focus on critical loads. The coupling relationship and uncertainty differences of loads are considered. It has adaptiveness to multiple forecasting scenarios.

Lu et al. develop a dual-timescale energy management method for distribution system. To confront load surging and renewable energy fluctuations, exp-function is used to improve droop control. The reference power and parameters of improved droop control are optimized in different timescales to improve the operational economy and power quality.

Yang et al. present an adaptive model predictive scheduling method for flexible interconnected distribution networks considering preferences of electric vehicles (EVs). Through the dynamic update of scheduling window, energy loss and load fluctuation can be further reduced under real-time scheduling of controllable EVs.

## Advanced simulation for large-scale DDNs

The real-time simulation of distribution networks can facilitate the decision-making of operation control strategies.

However, the explosion of operation data and system scale challenges the rapid operation simulation in the digital twin environment. It is necessary to develop advanced simulation methods for large-scale DDNs.

Liu et al. build a micro electric field measurement sensor model based on piezoelectric-piezoresistive coupling. It is aimed at solving problems of large size, high energy consumption, and difficult operation and maintenance of the existing electric field measurement sensors in power distribution systems.

Luo et al. establish an ontology modeling method for time-series operation simulation of distribution networks. The simulation expression and modeling efficiency are verified. It provides a reference for the technical realization of power grid modeling in digital twin environments.

## Conclusion

The papers on this Research Topic cover various technical solutions for *Edge computation and digital distribution networks*, such as the evolution of future distribution networks, novel operation methods, and advanced simulation methods for DDNs. The research will facilitate high-quality intelligent electricity services under complex environments.

## Author contributions

All authors listed have made a substantial, direct, and intellectual contribution to the work and approved it for publication.

## Acknowledgments

Authors would like to acknowledge the National Natural Science Foundation of China (U22B20114, 51907139, and 52007131), and National Key Research and Development of China (2020YFB0906000 and 2020YFB0906002), which made this Frontiers Research Topic possible.

## Conflict of interest

WX was employed by the company China Southern Power Grid.

The remaining authors declare that the research was conducted in the absence of any commercial or financial relationships that could be construed as a potential conflict of interest.

## Publisher's note

All claims expressed in this article are solely those of the authors and do not necessarily represent those of their affiliated

organizations, or those of the publisher, the editors and the reviewers. Any product that may be evaluated in this article, or claim that may be made by its manufacturer, is not guaranteed or endorsed by the publisher.

## References

Hu, D., Ye, Z., Gao, Y., Peng, Y., and Yu, N. (2022). Multi-agent deep reinforcement learning for voltage control with coordinated active and reactive power optimization. *IEEE Trans. Smart Grid* 13 (6), 4873–4886. doi:10.1109/TSG.2022.3185975

Huo, Y., Li, P., Ji, H., Yu, H., Yan, J., Wu, J., et al. (2022). Data-driven coordinated voltage control method of distribution networks with high DG penetration. *IEEE Trans. Power Syst.*, 1. doi:10.1109/TPWRS.2022.3172667

Jian, J., Li, P., Ji, H., Bai, L., Yu, H., Xi, W., et al. (2022). DLMP-based quantification and analysis method of operational flexibility in flexible distribution networks. *IEEE Trans. Sustain. Energy* 13 (4), 2353–2369. doi:10.1109/TSTE.2022.3197175

Zhao, J., Zhang, Z., Yu, H., Ji, H., Li, P., Xi, W., et al. (2022). Cloud-edge collaboration-based local voltage control for DGs with privacy preservation. *IEEE Trans. Ind. Inf.* 19 (1), 98–108. doi:10.1109/TII.2022.3172901