

# End-Use Savings Shapes

Public Dataset Release: Commercial 2023 Release 1

Chris CaraDonna

Lauren Adams, Janghyun Kim, Lauren Klun, Amy LeBar,  
Andrew Parker, Korbaga Woldekidan

NREL Webinar

*March 30, 2023*

# Logistics

- We are recording the webinar.
- Because of the large number of participants, everyone is **muted**.
- Please use the Q&A box to send us questions at any time during the presentation.
- The webinar slides, webinar recording, and full dataset will be available next week. This will be announced by email.

# Acknowledgment

**This work is the culmination of several years of research efforts.**

**We would like to thank the following for helping make this possible:**

- ComStock™ and ResStock™ teams
- OpenStudio® and EnergyPlus® teams
- Lawrence Berkeley National Laboratory
- Argonne National Laboratory
- U.S. Department of Energy.

# Agenda

**1** Our Approach to Building Stock Energy Modeling

---

**2** Changes Since End-Use Load Profiles Release

---

**3** End-Use Savings Shapes: 2023 Release 1

---

**4** Accessing the Dataset

---

**5** Next Steps

---

**6** Q&A

---

# EULP and EUSS

- The **End-Use Load Profiles** (EULP) project:
  - Created a public dataset for calibrated energy models of the U.S. commercial and residential building stock.
  
- The **End-Use Savings Shapes** (EUSS) follow-on project:
  - Adds the impact of several energy efficiency and electrification scenarios (“measures”) to the baseline stock models
  - [Residential EUSS Release 1](#) was presented September 2022
  - This presentation is for the **Commercial EUSS 2023 Release 1**.

# Problem Statement

**A lack of credible and relevant information results in inaction** by cities, states, utilities, and other major stakeholders.

## **Will electrification of buildings...**

- Reduce carbon emissions in my city?
- Be feasible in my building stock?
- Overload the grid?

# Alignment and Impact

## **We are putting information in the hands of decision makers**

In support of DOE goals to increase building energy efficiency, accelerate building electrification, and do so in ways that prioritize equity, affordability, and resilience

### **What the Datasets Provide**

- Building stock characterization
- When and how buildings use energy
- Potential impacts of energy efficiency
- Information on time-sensitive value of energy resources
- Potential impacts of building electrification

### **How the Information Is Used**

- Electrification planning
- Emissions analysis
- Decarbonization
- Utility-integrated resource plans and load forecasts
- Policy and rate design

# Our Approach to Stock Modeling

---






# ComStock Workflow


## The Making of the Datasets:

- Describe the U.S. building stock quantitatively using best-available public data
- Sample the description
- Model the samples
- Model changes to the samples – energy efficiency, electrification, etc. [EUSS only]
- Publish description, samples, models, results, aggregations, visualizations, and documentation



### Building stock characteristics database

- Variation in building type, size, location, vintage, HVAC system, etc.
- **Over 80** probability distributions of various attributes



### Physics-based computer modeling

- Representative set of 350k OpenStudio energy models




### High-performance computing

- Simulate models
- Process and publish data
- Apply scaling factors

# ComStock Workflow

Create distributions of building characteristics from available data sources →

- CoStar
- EIA CBECS
- ASHRAE
- HIFLD
- NFRC
- Analysis of AMI
- LightBox
- CPUC DEER
- Code Adoption



(see [ComStock Reference Documentation](#) for full list & acronyms)

## Example of Select ComStock Building Characteristic Inputs


Location and Envelope Basics		Heating and Cooling		Energy Code Followed During Last Replacement	
<b>Building ID</b>	810	<b>Heating</b>	Central Single-zone RTU Furnace	<b>HVAC</b>	DOE Ref 1980-2004
<b>City</b>	St. Clair County Alabama	<b>Heating Fuel</b>	Natural Gas	<b>Service Water Heating</b>	DOE Ref 1980-2004
<b>IECC Climate Zone</b>	3A	<b>Cooling</b>	PSZ-AC with gas coil DX	<b>Interior Equipment</b>	DOE Ref 1980-2004
<b>Building type</b>	Stand Alone Retail	<b>Setpoints and offsets</b>	Heating: 67°F / 7°F	<b>Exterior Lighting</b>	90.1-2013
<b>Year Built</b>	1977		Cooling: 70°F / 8°F	<b>Roof</b>	DOE Ref Pre-1980
<b>Floor area</b>	3,000 sq ft	<b>Service Water Htg Fuel</b>	Electricity	<b>Walls</b>	DOE Ref Pre-1980
<b>Stories</b>	1	Occupancy Schedule		<b>During Original Building Construction</b>	DOE Ref Pre-1980
<b>Windows</b>	Double - No LowE - Clear – Aluminum	<b>Weekday Operating Hours</b>	9.25	Interior Equipment	
<b>Average U Value</b>	0.225 (Btu/ft2)	<b>Weekday Opening Time</b>	7.75	<b>Interior Lighting Generation</b>	Gen2 T8 Halogen
<b>Window to Wall Ratio</b>	0.18	<b>Weekend Operating Hours</b>	16.5	<b>Lighting base to peak ratio</b>	0.5
<b>Wall type</b>	Metal	<b>Weekend Opening Time</b>	6.25	<b>Equipment base to peak ratio</b>	0.1

# What Does ComStock Model?


ComStock models ~64% of commercial building energy in the United States (CBECS 2012)

- Building Type
- Other (not modeled in ComStock)
  - RetailStripmall
  - Hospital
  - LargeOffice
  - FullServiceRestaurant
  - MediumOffice
  - Warehouse
  - PrimarySchool
  - RetailStandalone
  - LargeHotel
  - SmallOffice
  - SecondarySchool
  - Outpatient
  - QuickServiceRestaurant
  - SmallHotel

**All Buildings Types in CBECS**



**Not in ComStock**




The "stock" in this presentation describes the commercial building types modeled by ComStock

# Public datasets are intended to serve a broad set of use cases and audiences



## National Datasets




# Please Note

- The ComStock model is **continuously updated** with new information, methods, and improved quality assurance/quality control procedures. Datasets are released in 6-month increments.
- Measures are **not intended to be comprehensive** of a given technology. As additional data becomes available, measure results can be updated.
- The measure result summaries in this presentation are intended to be **high-level observations** to introduce the dataset. For more detailed conclusions, please watch for updates on the publications section of our website.

# Please Note Continued

- Compared to the disaggregated end-use energy data presented in CBECS 2012, in general ComStock is:
  - **Higher** on stock **electric heating** energy,
  - **lower** on stock **gas heating** energy, and
- Comparisons vary by building type.
- Measure results are relative to the ComStock baseline. Stock total savings and impact are sensitive to the baseline building assumptions.

## ComStock Site Energy by Fuel and End Use



# ComStock Documentation Released

## ComStock Documentation is now public!

This document serves as a guide and resource to the methodology and assumptions behind ComStock.

### Link

<https://www.nrel.gov/docs/fy23osti/83819.pdf>



### ComStock Reference Documentation Version 1

Andrew Parker, Henry Horsey, Matthew Dahlhausen,  
Marlena Praprost, Christopher CaraDonna, Amy LeBar  
and Lauren Klun

*National Renewable Energy Laboratory*

NREL is a national laboratory of the U.S. Department of Energy  
Office of Energy Efficiency & Renewable Energy  
Operated by the Alliance for Sustainable Energy, LLC  
This report is available at no cost from the National Renewable Energy  
Laboratory (NREL) at [www.nrel.gov/publications](http://www.nrel.gov/publications).

Contract No. DE-AC36-08GO28308

**Technical Report**  
NREL/TP-5500-83819  
March 2023



# Changes Since EULP

---



# Baseline Building Stock Representation


Major, 3-year calibration & validation process concluded fall 2021

- Technical report
- Published baseline dataset
- See project website for more information

Continuous improvements since then, including:

- Updated HVAC System and Fuel Type Distributions
- Ground Heat Transfer
- Wall Construction Type
- Technology Baselines for Lighting and Windows
- Update OpenStudio 2.9 to 3.4

EULP Baseline vs EUSS Baseline



# End-Use Savings Shapes: Commercial 2023 Release 1

---


Measure methodology, results, and discussion

# Commercial EUSS Approach

## End-Use Load Profiles (EULP)

Describe how and when energy is used in buildings **today**.

*Public database of 350,000 individual building models and their energy end-use load profiles.*



## End-Use Savings Shapes (EUSS)

Describe how and when energy is used in **“what if” scenarios**.

*Adds measure impact profiles for energy efficiency and electrification packages versus the ComStock baseline.*

EUSS 2023 commercial release 1 dataset represents the building stock circa 2018 using 2018 AMY weather

# Measure Summary

Measure Name	Description	% of Stock Floor Area
Roof Top Unit (RTU) Heat Pump (HP)	Replace gas and electric RTUs with HP-RTU.	45%
Rooftop Ventilator + HP Split System	Replace gas and electric RTUs with Rooftop Ventilator + HP Split System in small commercial buildings (<20,000sf).	11%
Air to Water HP Boiler Retrofit	Replace gas boilers with heat pump boilers.	18%
LED Lighting	Upgrade all lighting to LED.	65%
Exterior Wall Insulation	Add exterior wall insulation panels.	98%
Secondary Windows	Add secondary windows.	>99%
Window Replacement	Replace windows.	>99%
Window Film	Add window film to windows.	>99%
Roof Insulation	Add roof insulation.	>99%

# Greenhouse Gas Emissions

## Electricity

- 3 grid electricity scenarios compared today; more included in published dataset
- This work does not imply a preference for any grid emission scenario

Electricity Grid Scenario	Start Year	Levelization Period (3% discount rate)	Data Source
LRMER HighRECost	2022	15 years	NREL Cambium [1]
LRMER LowRECost	2022	15 years	NREL Cambium [1]
eGRID	2021	N/A	EPA eGRID [2]

Greenhouse gas emissions in dataset represent equivalent CO<sub>2</sub> emissions.

## On-Site Combustion Fuels

- Values from Table 7.1.2(1) of draft ANSI/RESNET/ICCC 301 [3]

<b>Natural Gas</b>	147.3 lb/mmBtu (228.0 kg/MWh)
<b>Propane</b>	177.8 lb/mmBtu (182.3 kg/MWh)
<b>Fuel Oil</b>	195.9 lb/mmBtu (303.2 kg/MWh)

\* LRMER = Long Run Marginal Emissions Rate


# Note on Heat Pump Modeling

- **Limited comprehensive heat pump performance maps exist** which are required for detailed energy modeling. This creates limitations of the understanding of heat pump performance and operation in this work.
- **Heat pump modeling is sensitive** to performance assumptions due to the strong relationship between efficiency and capacity with outdoor air temperature. This impacts both annual energy consumption and peak demand.
- This work attempts to use the most informative data available and makes documented assumptions about heat pump operation and performance. These will notably impact results. **Please consider these assumptions.**
- The assumptions used for the measures **represent one of multiple possible approaches.** They are intended to be reasonable but not necessarily optimal. Assumptions can be modified as our understanding of the technologies improves.

# ComStock Measure Documentation Website

**Comprehensive documentation available for each measure.**

Describes the modeling methodology, assumptions, relevant ComStock baseline features, and observations from results.



The screenshot displays the ComStock website interface. On the left is a sidebar navigation menu with the following items: Getting Started, Documentation, ComStock, Measures (highlighted with an orange rounded rectangle), Data, Publications, Citation and Data Attribution, and Contact. The 'Measures' menu is expanded to show a list of seven items: Air-Source Heat Pump Boiler, DOAS with Mini Split Heat Pumps, Exterior Wall Insulation, LED Lighting, Roof Insulation, Window Film, and Window Replacement. The main content area on the right features a search bar, the text 'ComStock on GitHub', and a breadcrumb trail 'Documentation / Measures'. The main heading is 'Energy Efficiency and Electrification Measure Documentation'. Below the heading is a paragraph: 'All measures detailed below have been developed through the End Use Savings Shape project, specifically the 2023 Release 1 effort.' A 'CONTENTS' section follows, listing the same seven measure categories as bullet points. At the bottom of the page, a copyright notice reads: 'ComStock, Copyright (c) 2019-2022, Alliance for Sustainable Energy, LLC, and other contributors. All rights reserved.'

7 documents available now, remaining 2 available next week.

Access at: <https://nrel.github.io/ComStock.github.io/docs/documentation/measures/measures.html>



# Note on Energy Savings

## Stock Energy Savings

Represents energy-weighted savings across the stock, not just applicable buildings.

*Does not represent the average savings that a building would experience for a measure.*

*For individual building savings, use the raw data to perform your analysis on specific building samples.*

## Site Energy Savings

Represents energy savings for resources used on site.

*Does not necessarily translate proportionally to savings for source energy, operational cost, or avoided greenhouse gas emissions. These factors should also be considered where appropriate, especially for electrification measures that change the heating fuel type of buildings.*

# Heat Pump Rooftop Units (HP-RTU)

---

# Heat Pump Rooftop Units (HP-RTU)

## Measure Concept

- Replace gas and electric RTUs with HP-RTU
- Variable speed, high efficiency (>17 IEER)


## HP-RTU Performance

- **Type:** Variable speed compressor and fan
- **Sizing:** Compressor sized to design cooling load; backup heat sized for remainder
- **Backup Heat:** Electric resistance
- **Compressor Lockout:** 0°F
- **Defrost:** Reverse cycle
- **Performance Data Source:** Mix of lab testing and manufacturer performance data

## Applicability

- Buildings w/ gas or electric resistance RTUs
- **~45%** of stock floor area


## ComStock RTU Energy Code Followed



# Heat Pump Rooftop Units (HP-RTU)


- **42%** stock heating gas savings (190 TBtu)
- **-3%** stock heating electricity savings (-6 TBtu)
- **16%** stock cooling electricity savings (109 TBtu)
- **24%** stock fan electricity savings (144 TBtu)
- Cooling and fan savings could also be attributed to high-performance non-HP-RTUs
- Savings associated with premium units

## Non-Coincident Winter Peak for Buildings With Gas RTUs




**22%** winter electric peak intensity increase for median HP-RTU model compared to ComStock baseline gas RTUs

## Stock Site Energy by Fuel and End Use



# Heat Pump Rooftop Units (HP-RTU)



- Emissions avoided across all grid scenarios
- Electricity emissions avoided are from cooling and fan end uses; also from replacing electric resistance RTUs with HP-RTUs

# Dedicated Outdoor Air Units (DOAS) With Mini Split Heat Pumps

---

# DOAS HP Mini Splits

## Measure Concept


- Replace gas and electric RTUs with DOAS and HP mini splits (decoupled) in small commercial
- Premium efficiency (>25 SEER, >14 HSPF) & suitable for cold climates
- ERV or HRV added to DOAS based on climate

## Mini Split HP Performance

- **Type:** Variable speed compressor and fan
- **Sizing:** Up to 135% design cooling load
- **Backup Heat:** Electric resistance
- **Compressor Lockout:** -15°F
- **Defrost:** Reverse cycle
- **Performance Data Source:** Previous lab testing

## Applicability

- Buildings <20,000sf w/ applicable RTUs
- Applicable to **11%** of stock floor area




Source: R. C. Analytics 2021 [6]


# DOAS HP Mini Splits

- **2%** stock heating electricity savings (6 TBtu)
- **18%** stock heating gas savings (81 TBtu)
- **6%** stock cooling electricity savings (39 TBtu)

## Annual Average Model Effective Heating COP by State



## Stock Site Energy by Fuel and End Use




Savings across HVAC end uses.

Includes electricity due to supplemental heating and defrost. Does not include supply fan.



# DOAS HP Mini Splits



- Emissions avoided across all grid scenarios
- Electricity emissions avoided are from cooling and fan end uses; also from replacing electric resistance RTUs with DOAS HP mini splits

# Heat Pump Boiler

---

# Heat Pump Boiler

## Measure Concept

- Replace natural gas boilers for space heating with air source heat pump boiler
- 140°F supply temperature
- Electric resistance boiler added for backup


## Heat Pump Boiler Performance

- **Sizing:** Meet loads down to 17°F
- **Backup Heat:** Electric resistance boiler
- **Compressor Lockout:** -5°F
- **Defrost:** Integrated into performance curves
- **Performance Data Source:** Manufacturer data

## Applicability

- Buildings with natural gas boiler for space heating
- Applicable to **17.8%** of stock floor area


## Gas Boiler Floor Area and Heating Energy (%)




# Heat Pump Boiler

- 49% stock heating natural gas savings (223 TBtu)
- -40% stock heating electricity savings (-81 TBtu)


## Where are the natural gas heating savings coming from?



## Stock Site Energy by Fuel and End Use



# Heat Pump Boiler



- Net emissions avoided despite increased electricity emissions
- Increased electricity emissions from electrifying gas boilers

# LED Lighting

---

# LED Lighting

## Measure Concept

- Replace all interior lighting in a building with LEDs

## Applicability

- Buildings without LED interior lighting
- Applicable to **65%** of stock floor area

## Baseline


- Baseline lighting power density and technology distribution data from:
  - ASHRAE 90.1 Lighting Subcommittee space type lighting assumptions
  - *2015 U.S. Lighting Market Characterization* [4]
  - *Energy Savings Forecast of Solid-State Lighting in General Illumination Applications* [5]

## % Stock Floor Area per Lighting Type


ComStock Building Type	t12_incandescent	t8_halogen	t5_cfl	Gen 4 LED	Gen 5 LED
Full-Service Restaurant	0.5%	1.2%	0.1%	0.7%	0.2%
Hospital	0.7%	2.0%	0.3%	1.1%	0.4%
Large Hotel	0.7%	2.4%	0.2%	1.3%	0.3%
Large Office	1.3%	4.2%	0.4%	2.2%	0.7%
Medium Office	1.1%	3.7%	0.4%	2.2%	0.6%
Outpatient	0.6%	1.4%	0.2%	2.2%	0.2%
Primary School	1.8%	5.0%	0.6%	3.3%	0.7%
Quick-Service Restaurant	0.1%	0.2%	0.0%	0.2%	0.0%
Retail Stand Alone	1.4%	3.9%	0.4%	2.6%	0.6%
Retail Strip Mall	1.3%	4.4%	0.4%	2.8%	0.6%
Secondary School	1.0%	2.6%	0.3%	1.6%	0.3%
Small Hotel	0.2%	0.5%	0.1%	0.3%	0.1%
Small Office	1.2%	3.5%	0.4%	2.2%	0.5%
Warehouse	3.1%	11.1%	1.0%	6.6%	1.6%

# LED Lighting

- **48% (157.7 TBtu) electricity interior lighting savings**
- Small changes to cooling, heating, and fan energy from internal load reduction
- Higher site EUI savings for models with earlier generation interior lighting (T12/incandescent)




## Stock Site Energy by Fuel and End Use





# LED Lighting



- Emissions avoided for all grid scenarios from reduced lighting energy and cooling loads
- Additional heating load from reduced internal loads causes slight increase in combustion fuel emissions

# Exterior Wall Insulation

---

# Exterior Wall Insulation

## Measure Concept

Add rigid insulation under exterior cladding outside structural elements


- Not applicable to metal building walls
- Round to nearest 1" of insulation
- If < 0.5" required, NA
- Target total performance ~R-13 to 29

## Wall Insulation Performance

AEDG Target Values	Climate Zone	R-Value (hr*ft <sup>2</sup> *F/Btu)
Opaque Wall Assembly Thermal Performance	1	13
	2	13
	3	16
	4	16
	5	19
	6	21
	7	21
	8	29

## Applicability


- Buildings with mass, steel-framed, or wood-framed walls
- Applicable to **98%** of stock floor area




# Exterior Wall Insulation

- **12%** stock heating electricity savings (79 TBtu)
- **10%** stock heating gas savings (46 TBtu)
- **3%** stock cooling electricity savings (20 TBtu)
- **1%** stock fan electricity savings (6 Tbtu)
- Generally decreases heating and cooling loads
- Sometime causes increased cooling loads


## Stock Site Energy Savings by Building Type



## Stock Site Energy by Fuel and End Use



# Exterior Wall Insulation



Emissions avoided across all grid scenarios and combustion fuels from HVAC load reductions

# Window Films

---


# Window Films

## Measure Concept

- Add window film to existing windows
- Film properties vary by climate and existing window
- Adds low-e coatings and/or reduced solar heat gain coefficient (SHGC) to existing window

## Applicability


- Added to all non-triple pane windows in ComStock baseline
- Applicable to over **99%** of ComStock floor area




# Window Films

There can be a seasonal trade-off

## Electricity used for space cooling



## Electricity used for space heating







# Window Films

- **7% stock cooling electricity savings** (46 Tbtu)
- **5% stock site district cooling savings** (8 Tbtu)
- **2% stock fan electricity savings** (10 Tbtu)
- **-7% stock heating (gas and electric) savings** (-45 TBtu)
- Variation in savings by building type, baseline window type, and climate zone

## Stock Site Energy by Fuel and End Use



# Window Films




- Emissions avoided across all grid scenarios
- Heating increase from reduced SHGC causes slight increase in combustion fuel emissions

# Secondary Windows

---

# Secondary Windows

**Measure Concept:** Install a second window within the frame or reveal an existing window




Cross Section

- Total performance ~R-1.6 to R-2.7
- Assumed frame-within-frame install
- Assumed no impact on infiltration

Some qualitative evidence against this assumption

## Baseline Windows


**Applicability:** Applies to most of existing stock




# Secondary Windows

- **3%** stock site **heating electricity** savings (8 TBtu)
- **3%** stock site **heating gas** savings (12 TBtu)
- **3%** stock site **electricity cooling** energy savings (19 TBtu)
- **1%** stock site **electricity fan** energy (5 TBtu)
- Reduced loads from increased window insulation and decreased SHGC
- Complex relationship, savings per building vary by climate, building type, baseline window type, and other design factors

## Stock Site Energy by Fuel and End Use



# Secondary Windows



Emissions avoided across all grid scenarios and combustion fuels due to HVAC load reductions

# Window Replacement

---

# Window Replacement

## Measure Concept


- Replace existing windows with those that align with *Advanced Energy Design Guide* (AEDG) properties

## Measure Applicability

- Applies to all non-triple pane windows
- **>99%** of stock floor area

## AEDG Target Values:

Climate Zone	1	2	3	4	5	6	7	8
Maximum Assembly U-Factor	0.48	0.43	0.40	0.34	0.34	0.32	0.28	0.25
Maximum SHGC	0.22	0.22	0.24	0.34	0.36	0.36	0.38	0.38







# Window Replacement

- **5% stock heating electricity** energy savings (12 TBtu)
- **4% stock heating gas** energy savings (18 TBtu)
- **4% stock cooling electricity** savings (37 TBtu)
- Reduced loads from increased window insulation and reduced SHGC
- Increased cooling energy in some buildings

## Stock Site Energy by Fuel and End Use



# Window Replacement



Emissions avoided across all grid scenarios and combustion fuel sources due to HVAC load reductions

# Roof Insulation

---

# Roof Insulation

## Measure Concept

- Increase roof insulation to align with AEDG R-values
- Rounded to nearest 1" of XPS (R-5/in.) insulation


## Applicability

- All buildings not already meeting R-value targets
- >99% of stock floor area

## AEDG Target R-Values:



Climate Zone	1	2 & 3	4, 5, & 6	7 & 8
R-Value	21	26	33	37

## Stock Roof R-Value Distribution Change




# Roof Insulation

- **11%** stock site **heating** energy savings (82 TBtu)
- **3%** stock site **cooling** energy savings (25 TBtu)
- Reduced heating and cooling loads from increased roof insulation
- Variation in savings by building type, baseline R-value, and climate zone



# Roof Insulation








Emissions avoided across all grid scenarios and combustion fuel sources due to HVAC load reductions

# Accessing the Dataset

---

# Accessing the Data

	 Metadata	 Individual Load Profiles	 Aggregate Load Profiles	 Data Viewer	 Full Database
<b>Data Format</b>	.csv and .parquet files	.csv and .parquet files	.csv and .parquet files	Dashboard with .csv exports	Amazon S3 bucket
<b>Time scale</b>	Annual	15-min intervals	15-min intervals	Customizable	Annual or 15-min intervals
<b>Grouped by</b>	Individual Building ID	Individual Building ID	Geographies: climate zone, ISO/RTO region, state	Customizable	Customizable
<b>Fields by</b>	Building Input Characteristics	-	-	-	Building Input Characteristics
	Energy Consumption	Energy Consumption	Energy Consumption	Energy Consumption	Energy Consumption
	Energy Savings	Energy Savings	Energy Savings	Energy Savings	Energy Savings
	Emissions	-	-	-	Emissions
	Calculated fields	-	-	-	Calculated fields
<b>Accessed via</b>	<a href="#">OpenEI Data Lake</a>	<a href="#">OpenEI Data Lake</a>	<a href="#">Open EI Data Lake</a>	<a href="#">ComStock.nrel.gov</a>	Scripting Languages



# Field Naming Convention

Prefix or Name	Count	Description	Example
in.	64	Inputs of building characteristics and geospatial codes	in.window_type
out.	352	Simulation outputs	out.electricity.refrigeration.energy_consumption
calc.	159	Calculated values such as totals and % savings	calc.weighted.electricity.cooling.energy_consumption..tbtu
weight	1	Value for scaling single model results to national scale	4.8960474
bldg_id	1	Unique id of the building model	3324
upgrade	1	Unique id number for upgrade	5
model_count	1	Number of models aggregated (timeseries files)	5334
applicability	12	Upgrade names	FALSE
<b>Second Level</b>			
out.[fuel type]	6	Fuel type - electricity, natural gas, etc.	out.natural_gas.water_systems.energy_consumption
out.emissions	20	Emission values	out.emissions.electricity.egrid..co2e_kg
out.params	197	Model parameters and summary statistics	out.params.dx_cooling_average_cop..cop
out.qoi	15	Quantities of interest such as peak demand	out.qoi.maximum_daily_use_summer_kw..kw
out.site_energy	4	total of all end uses, site energy	out.site_energy.total.energy_consumption
<b>Third Level</b>			
out.[fuel type]. [end use]	136	End uses – heating, cooling, lighting, water systems, etc.	out.electricity.heating.energy_consumption
<b>Units</b>			
..foo	-	".." denotes the start of the unit name	..kWh_per_ft2

Data dictionary available at [OpenEI Data Lake](#)

# Example Metadata File

Building ID

County

Building Type

Building Area  
(unweighted)

Annual Electricity Peak  
kW (unweighted)

Annual Natural  
Gas Consumption  
(unweighted)

	P	Q	R	S	T	U	V	W	X	Y	Z	AA	AB	AP	AQ	AR		
	in.window_type	in.building_subtype	in.county	in.comstock_building_type	in.rotation_degrees	in.number_of_stories	in.sqft	in.hvac_system_type	in.wall_construction_type	in.weekday_operating_hours..hr	in.weekday_operating_time..s..hr	in.weekend_operating_hours..hr	in.weekend_operating_time..s..hr	out.electricity_total.peak_demand..kW	cooling.energy_consumption	heating.energy_consumption	out.natural_gas_total.energy_consumption	
1	in.building_id	in.window_type	in.building_subtype	in.county	in.comstock_building_type	in.rotation_degrees	in.number_of_stories	in.sqft	in.hvac_system_type	in.wall_construction_type	in.weekday_operating_hours..hr	in.weekday_operating_time..s..hr	in.weekend_operating_hours..hr	in.weekend_operating_time..s..hr	out.electricity_total.peak_demand..kW	cooling.energy_consumption	heating.energy_consumption	out.natural_gas_total.energy_consumption
2	55	Double - No LowE - NA	NA	G0100030	Outpatient	225	3	37500	PSZ-AC with ele	Mass	8	8.75	8.75	6.75	288.54417	0	0	41180.55556
3	324	Single - No LowE - NA	NA	G0101250	Hospital	270	3	350000	VAV air-cooled	SteelFramed	8.5	8.5	12	4.75	2537.623	0	0	2049280.556
4	457	Double - LowE - CI	NA	G0100830	Hospital	90	2	150000	VAV air-cooled	SteelFramed	8.75	8	14.75	7.75	1112.82938	0	966591.667	312955.5556
5	496	Double - No LowE - NA	NA	G0100350	Hospital	270	2	150000	VAV chiller with	Mass	13.75	6.25	6	11.5	1016.74873	0	0	1320636.111
6	758	Double - No LowE - NA	NA	G0100730	Outpatient	0	4	75000	PSZ-AC with gas	Mass	7.5	8.25	11.25	10.25	412.52324	0	0	176772.2222
7	766	Double - LowE - Ti	NA	G0100550	Hospital	0	7	37500	PVAV with gas b	SteelFramed	8.75	7	11	5.75	292.54247	0	0	426252.7778
8	1122	Single - No LowE - NA	NA	G0100950	Hospital	315	3	150000	PVAV with gas b	WoodFramed	9.5	7	6	11.5	1264.01005	0	0	3154086.111
9	1934	Double - LowE - Ti	NA	G0100730	Hospital	270	5	1000000	PVAV with gas b	SteelFramed	9	7.5	7.25	9.75	6813.14901	0	0	6029661.111
10	2357	Double - LowE - CI	NA	G0100730	Outpatient	180	2	75000	PSZ-AC with gas	WoodFramed	9.5	6.75	10.75	4.75	374.63398	0	0	179880.5556
11	3324	Single - No LowE - NA	NA	G0100950	Hospital	270	3	350000	VAV chiller with	Mass	9	7.5	8.25	7	2152.99659	0	0	2584791.667
12	3640	Double - LowE - CI	NA	G0100170	Hospital	90	3	350000	VAV air-cooled	SteelFramed	9.75	7	12	5.5	2544.36643	0	847533.333	334913.8889
13	3801	Single - No LowE - NA	NA	G0100730	Outpatient	180	3	75000	PSZ-AC with gas	Mass	8.5	7.5	10.75	11	489.49215	0	0	170322.2222
14	5764	Single - No LowE - NA	NA	G0200500	Hospital	270	1	75000	VAV chiller with	WoodFramed	9	8	10	6.75	329.3614	0	0	2559697.222
15	6058	Double - No LowE - NA	NA	G0400190	Outpatient	45	1	37500	PSZ-AC with gas	SteelFramed	8.25	5.5	8.75	9.25	294.87621	0	0	65736.11111
16	6194	Single - No LowE - NA	NA	G0400130	Outpatient	225	1	75000	PSZ-AC with ele	SteelFramed	7.75	6.5	11.25	6.75	600.52446	0	0	83033.33333
17	6447	Double - No LowE - NA	NA	G0400190	Outpatient	180	2	17500	PSZ-AC with ele	WoodFramed	6.5	6.5	10.5	8.5	99.54627	0	0	18208.33333
18	6752	Double - LowE - Ti	NA	G0400130	Outpatient	180	1	37500	PSZ-AC with ele	SteelFramed	7	7	17.5	5.25	209.44043	0	0	42166.66667
19	7153	Double - LowE - CI	NA	G0400130	Outpatient	315	1	37500	PSZ-AC with ele	SteelFramed	7.75	9.5	7.25	10	310.28772	0	0	40255.55556
20	7500	Single - No LowE - NA	NA	G0400190	Outpatient	225	1	37500	PSZ-AC with ele	Mass	7.25	8.75	15.5	4.5	331.52824	0	0	41991.66667
21	7516	Double - No LowE - NA	NA	G0400130	Outpatient	0	1	37500	PSZ-AC with ele	Mass	7	6.5	10.75	9.75	283.39981	0	0	40002.77778
22	7535	Double - No LowE - NA	NA	G0400190	Outpatient	0	1	17500	PSZ-AC with gas	SteelFramed	9	8.5	10	10.75	122.88107	0	0	32330.55556
23	7662	Single - No LowE - NA	NA	G0400130	Outpatient	135	2	75000	PSZ-AC with ele	SteelFramed	10.25	6.5	11	12	592.7709	0	0	91941.66667

# Example Time Series File

Building ID

Timestamp

Exterior Lighting  
Consumption (kWh)

Interior Lighting  
Consumption (kWh)

Gas Heating  
Consumption (kWh)

	B	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	
	bldg_id	timestamp	out.electricity. cooling.energy_ consumption	out.electricity. exterior_lighti ng.energy_con sumption	out.electricity. fans.energy_c onsumption	out.electricity. heat_recovery .energy_consu mption	out.electricity. heat_rejection .energy_consu mption	out.electricity. heating.energy_ consumption	out.electricity. interior equip ment.energy_c onsumption	out.electricity. interior_lighti ng.energy_cons umption	out.electricity. pumps.energy_ consumption	out.electricity. refrigeration.e nergy_consum ption	out.electricity. water_system s.energy_cons umption	out.natural_ga s.heating.ener gy_consumpti on	out.natural_ga s.interior_equi pment.energy_ consumption	out.natural_ga s.water_syste ms.energy_co nsumption
2	5324	1/1/2018 0:15	0	1.2107	3.4499	0	0	0	2.3114	0.3319	0.0003	0	0	0	0	0.278477731
3	5324	1/1/2018 0:30	0	1.2107	3.4499	0	0	0	2.1577	0.2885	0.0003	0	0	0	0	0.763094899
4	5324	1/1/2018 0:45	0	1.2107	3.4499	0	0	0	1.8502	0.2017	0.0003	0	0	0	0	0.678523028
5	5324	1/1/2018 1:00	0	1.2107	3.4499	0	0	0	1.6965	0.1583	0.0003	0	0	0	0	0.262133379
6	5324	1/1/2018 1:15	0	1.2107	3.4499	0	0	0	1.2485	0.1461	0.0003	0	0	0	0	0.801860046
7	5324	1/1/2018 1:30	0	1.2107	3.4499	0	0	0	1.0245	0.1399	0.0003	0	0	0	0	0.608005027
8	5324	1/1/2018 1:45	0	1.2107	3.4499	0	0	0	0.5764	0.1277	0.0003	0	0	0	0	0.242852543
9	5324	1/1/2018 2:00	0	1.2107	3.4499	0	0	0	0.3524	0.1216	0.0003	0	0	0	0	0.834873996
10	5324	1/1/2018 2:15	0	1.2107	3.4499	0	0	0	0.5835	0.0811	0.0003	0	0	0	0	0.524560196
11	5324	1/1/2018 2:30	0	1.2107	3.4499	0	0	0	0.6991	0.0608	0.0003	0	0	0	0	0.298359756
12	5324	1/1/2018 2:45	0	1.2107	3.4499	0	0	0	0.9302	0.0203	0	0	0	0	0	0.420222982
13	5324	1/1/2018 3:00	0	1.2107	3.4499	0	0	0	1.0457	0	0	0	0	0	0	0.053723496
14	5324	1/1/2018 3:15	0	1.2107	3.4499	0	0	0	1.0449	0.0026	0	0	0	0	0	0
15	5324	1/1/2018 3:30	0	1.2107	3.4499	0	0	0	1.0445	0.0039	0	0	0	0	0	0
16	5324	1/1/2018 3:45	0	1.2107	3.4499	0	0	0	1.0437	0.0065	0	0	0	0	0	0
17	5324	1/1/2018 4:00	0	1.2107	3.4499	0	0	0	1.0433	0.0078	0	0	0	0	0	0
18	5324	1/1/2018 4:15	0	1.2107	3.4499	0	0	0	1.0424	0.0104	0	0	0	0.438	0	0
19	5324	1/1/2018 4:30	0	1.2107	3.4499	0	0	0	1.042	0.0117	0	0	0	0.3853	0	0
20	5324	1/1/2018 4:45	0	1.2107	3.4499	0	0	0	1.0412	0.0143	0	0	0	0.2948	0	0
21	5324	1/1/2018 5:00	0	1.2107	3.4499	0	0	0	1.0408	0.0156	0	0	0	0.16	0	0
22	5324	1/1/2018 5:15	0	1.2107	3.4499	0	0	0	1.04	0.0183	0	0	0	0.1943	0	0
23	5324	1/1/2018 5:30	0	1.2107	3.4499	0	0	0	1.0396	0.0196	0	0	0	0.2245	0	0
24	5324	1/1/2018 5:45	0	1.2107	3.4499	0	0	0	1.039	0.0215	0	0	0	0.2503	0	0.474015352
25	5324	1/1/2018 6:00	0	1.2107	3.4499	0	0	0	0.9423	0.0579	0	0	0	0.278	0	0

# Summary of Dataset Links

ComStock

External Documentation FAQ Log In

## ComStock

Highly granular modeling of the U.S. commercial building stock

Commercial stock characteristics database + Physics-based computer modeling + High-performance computing

The ComStock and ResStock analysis tools are helping states, municipalities, utilities, and manufacturers identify which building stock improvements save the most energy and money. ComStock is a U.S. Department of Energy model of the commercial building stock, developed and maintained by NREL. [Learn more.](#)

[Data Viewer](#)  
Explore existing analysis results on ComStock's interactive website. State-level results can be filtered to identify the savings potential in various segments of the commercial building stock, whether that is buildings of a certain vintage, specific heating fuel type, or in a specific state and climate zone.

[Available Datasets →](#)

[ComStock Documentation](#)  
Learn about how and why ComStock represents the U.S. commercial building stock including how ComStock works, how to use ComStock, some behind the scenes details, and recommendations from the ComStock team on if and when ComStock is the right tool for your use case on the external documentation website.

[ComStock Documentation →](#)

ComStock

- Getting Started
- Documentation
- Data
  - Accessing Data
  - Published Datasets**
- Publications
- Citation and Data Attribution
- Contact


## Published Datasets

ComStock dataset releases are summarized in the following table with links for accessing the aggregate results.

Publication Date	Oct-21	Oct-21
Release #	1	1
Building Stock Represented	U.S. commercial sector circa 2018	U.S. commercial sector circa 2018
Upgrades Applied	None	None
Weather Year	amy2018	tmy3
Data Viewer Links Annual and Timeseries Energy	by_state, by_puma_northeast, by_puma_midwest, by_puma_south, by_puma_west	by_state, by_puma_northeast, by_puma_midwest, by_puma_south, by_puma_west
Data Table with Characteristics and Annual Energy Use	metadata	metadata
OEDI Data and Dictionaries	suppl_data_dict	suppl_data_dict

Access at: [ComStock.nrel.gov](https://comstock.nrel.gov) and [ComStock Documentation Site](#)

# OEDI Folder Structure

 AWS S3 Explorer for the Open Energy Data Initiative [oedi-data-lake](#) / [nrel-pds-building-stock](#) / [end-use-load-profiles-for-us-building-stock](#) / 2021 / comstock\_amy2018\_release\_1

Show  entries


Object	Timestamp	Size
<a href="#">building_energy_models/</a>		
<a href="#">geographic_information/</a>		
<a href="#">metadata/</a>		
<a href="#">timeseries_aggregates/</a>		
<a href="#">timeseries_aggregates_metadata/</a>		
<a href="#">timeseries_individual_buildings/</a>		
<a href="#">weather/</a>		
<a href="#">citation.txt</a>	2022-03-30 08:00:45	5.4 kB
<a href="#">data_dictionary.tsv</a>	2022-03-07 13:30:36	30.9 kB
<a href="#">enumeration_dictionary.tsv</a>	2021-10-21 16:09:34	12.5 kB
<a href="#">upgrade_dictionary.tsv</a>	2021-10-21 16:34:24	90 B
<a href="#">upgrades_lookup.json</a>	2023-03-29 13:31:05	21 B

Showing 1 to 12 of 12 entries

Folder structure: year/comstock\_weather file\_release\_#[/metadata, timeseries - aggregate, indiv, etc]

Access at: [Open EI Data Lake](#)

# ComStock Documentation Website




The screenshot displays the ComStock website interface. On the left is a navigation menu with the ComStock logo and links for Getting Started, Documentation, Data, Publications, Citation and Data Attribution, and Contact. The main content area features a search bar, a link to 'ComStock on GitHub', and a section titled 'Getting Started with ComStock'. This section includes a cityscape image and introductory text about the ComStock model, its purpose, and the key questions it addresses.

ComStock

Search ComStock

ComStock on GitHub

## Getting Started with ComStock



The commercial building sector stock model, or ComStock™, is a highly granular, bottom-up model that uses multiple data sources, statistical sampling methods, and advanced building energy simulations to estimate the annual subhourly energy consumption of the commercial building stock across the United States.

ComStock asks and answers two questions: **(1) How is energy used in the U.S. building stock?** and **(2) What are the impact of energy saving technologies?**

The ComStock data sets identify where energy is being consumed geographically, in what building types and end uses, and at what times of day. Simultaneously, it identifies the impact of efficiency measures:

Access at: <https://nrel.github.io/ComStock.github.io/>

# Where to find it...

## ComStock Documentation Website

<https://nrel.github.io/ComStock.github.io/>

Getting Started • Publications • Technical Documentation

## AWS OEDI Repository

<https://data.openei.org/submissions/4520>

Metadata & annual results • Aggregate load profile results • Individual model results & input files including weather  
Data dictionary and enumeration dictionary • Geospatial information

## Web Data Viewer

<https://comstock.nrel.gov>

Graphical in-browser data visualizations • Custom aggregation tool

*Requires free account*

# A Few Reminders

- All time stamps time-period-ending and are in EST.
- Annual metadata files provide weighting factors for national scaling. Columns with “weighted” in the title already have this factor applied.
- Check your sample sizes on custom aggregations – too few samples can increase uncertainty.
- All “out.” columns without units denoted are in kWh.  
*(This driven by current limitations with the data viewer.)*



# Next Steps

---

# Commercial EUSS Round 2

## Proposed List For Commercial EUSS 2023 Release 2; Expected September 2023

Measure Name	Description
Demand Control Ventilation (DCV)	Add demand control ventilation to air handling units.
DOAS with VRF retrofit	Replaces VAV systems with DOAS/VRF system.
Airside Economizers	Add economizers controls to air handling units (non-DOAS) that do not already have them.
Heat/Energy Recovery	Add heat or energy recovery to air handling units where not already included.
HP-RTU with Gas Backup	Apply gas backup to HP-RTUs to understand carbon, energy, and peak demand trade-offs of the backup heating fuel source.
HP Boiler with Gas Backup	Apply gas backup to HP-boilers to understand carbon, energy, and peak demand tradeoffs of the backup heating fuel source.
Package 1: High Efficiency Envelope	Apply package with upgraded wall insulation, roof insulation, and windows to align with target values per climate zone.
Package 2: Lighting + HP-RTU + HP-Boiler	Apply package with LED lighting, HP-RTU, and HP-boiler.
Package 3: High Efficiency Case (7+8)	Combine packages 1 and 2



Q&A  
[comstock@nrel.gov](mailto:comstock@nrel.gov)

[www.nrel.gov](http://www.nrel.gov)

NREL/PR-5500-85853

This work was authored in part by the National Renewable Energy Laboratory, operated by Alliance for Sustainable Energy, LLC, for the U.S. Department of Energy (DOE) under Contract No. DE-AC36-08GO28308. Funding provided by the U.S. Department of Energy Office of Energy Efficiency and Renewable Energy Building Technologies Office. The views expressed in the article do not necessarily represent the views of the DOE or the U.S. Government. The U.S. Government retains and the publisher, by accepting the article for publication, acknowledges that the U.S. Government retains a nonexclusive, paid-up, irrevocable, worldwide license to publish or reproduce the published form of this work, or allow others to do so, for U.S. Government purposes.

*Photo from iStock-627281636*



# Citation and Attribution Guidance

- [1] Gagnon, Pieter. “Cambium | Energy Analysis | NREL.” National Renewable Energy Laboratory. <https://www.nrel.gov/analysis/cambium.html>.
- [2] United States Environmental Protection Agency. 2023. “Emissions & Generation Resource Integrated Database (eGRID).” September 2, 2022. <https://www.epa.gov/egrid>.
- [3] G. Vijayakumar et al., “ANSI/RESNET/ICC 301-2022 - Standard for the Calculation and Labeling of the Energy Performance of Dwelling and Sleeping Units using an Energy Rating Index,” Oceanside, CA, 2022.
- [4] Buccitelli, Nicole, Clay Elliott, Seth Schober, and Mary Yamada. 2017. *2015 U.S. Lighting Market Characterization*. Washington, DC: Navigant Consulting for the United States Department of Energy. <https://doi.org/10.2172/1413883>.
- [5] Yamada, Mary, Julie Penning, Seth Schober, Kyung Lee, and Clay Elliott. 2019. *Energy Savings Forecast of Solid-State Lighting in General Illumination Applications*. Washington, DC: Navigant Consulting for the United States Department of Energy. <https://doi.org/10.2172/1607661>.
- [6] R. C. Analytics. 2021. *Energy Efficiency Analysis of DX-DOAS in the Pacific Northwest*. [https://betterbricks.com/uploads/resources/DX-DOAS\\_Technology-Assessment\\_op.pdf](https://betterbricks.com/uploads/resources/DX-DOAS_Technology-Assessment_op.pdf)