

Cost of Wind Energy Review: 2024 Edition

Tyler Stehly, Patrick Duffy, and Daniel Mulas Hernando National Renewable Energy Laboratory November 2024

New Report Naming Convention

- This year's report uses a new naming convention—"2024 Edition"—to align with the Wind Energy Technologies Office's naming convention for the wind energy market reports (<u>https://www.energy.gov/eere/wind/wind-market-reports-2024-edition</u>).
- The data and results in this analysis are derived from the prior year's 2023 commissioned plants, representative industry data, and state-of-the-art modeling capabilities used to inform Fiscal Year 2024 values in the report.

Acknowledgments

The authors would like to thank Patrick Gilman (U.S. Department of Energy Office of Energy Efficiency and Renewable Energy Wind Energy Technologies Office [WETO]) for supporting this research. Thanks also to Gage Reber (contractor to WETO) of Boston Government Services and Daniel Beals (contractor to WETO) of Lindahl Reed Inc. for reviewing prior versions of this presentation. Thank you to Ryan Wiser and Dev Millstein (Lawrence Berkeley National Laboratory) and Lindsay Sheridan (Pacific Northwest National Laboratory) for their analysis of wind project market data that informed this analysis. Thanks also to Amy Brice (National Renewable Energy Laboratory) for editing the presentation. Any remaining errors or omissions are the sole responsibility of the authors.

List of Acronyms and Abbreviations

| AEP | annual energy production | MW | megawatt |
|-----------|---|---------------------|--------------------------------------|
| APC | Applicable Project Components | MWh | megawatt-hour |
| ATB | Annual Technology Baseline | NPV | net present value |
| BOS | balance of system | NREL | National Renewable Energy |
| CapEx | capital expenditures | | Laboratory |
| COD | commercial operations date | 0&M | operations and maintenance |
| CRF | capital recovery factor | OpEx | operational expenditures |
| DOE | U.S. Department of Energy | ORBIT | Offshore Renewables Balance of |
| FCR | fixed charge rate | | System and Installation Tool |
| FY | fiscal year | ORCA | Offshore Wind Regional Cost Analyzer |
| GPRA | Government Performance and Results Act | RD | rotor diameter |
| НН | hub height | USD | U.S. dollars |
| IEC | International Electrotechnical Commission | W | watt |
| kW | kilowatt | WACC | weighted average cost of capital |
| LandBOSSE | Land-based Balance of System Systems | WETO | Wind Energy Technologies Office |
| | Engineering | WISDEM [®] | Wind Plant Integrated Systems Design |
| LCOE | levelized cost of energy | | and Engineering Model |
| m | meter | WOMBAT | Windfarm Operations & Maintenance |
| m/s | meters per second | | cost-Benefit Analysis Tool |
| MACRS | Modified Accelerated Cost Recovery System | yr | year |

Executive Summary

Executive Summary

- The 13th annual *Cost of Wind Energy Review* uses representative utility-scale and distributed wind energy projects to estimate the levelized cost of energy (LCOE) for land-based and offshore wind power plants in the United States.
 - Data and results are derived from 2023 commissioned plants, representative industry data, and state-of-the-art modeling capabilities.
 - The goals of this analysis are to provide insight into current component-level costs and give a basis for understanding the impacts of market variability on wind energy LCOE in the United States.
 - Recent U.S. offshore wind industry strike prices exceed the LCOE estimates in this publication. Slide 43, titled
 "2023 Offshore Wind Reference Plant LCOE Estimates," outlines several factors contributing to these disparities.
- The primary elements of this 2023 analysis include:
 - Estimated LCOE for (1) a representative land-based wind energy project installed in a moderate wind resource in the United States, (2) a representative fixed-bottom offshore wind energy project installed in the U.S. North Atlantic, and (3) a representative floating offshore wind energy project installed off the U.S. Pacific coast
 - Updated LCOE estimates for representative residential-scale, commercial-scale, and large-scale distributed wind projects installed in a moderate wind resource in the United States
 - Sensitivity analyses showing the range of effects that basic LCOE variables could have on the cost of wind energy for land-based and offshore wind projects
 - Updated Fiscal Year 2024 values for land-based and offshore wind energy used for Government Performance and Results Act (GPRA) reporting and illustrated progress toward established GPRA targets.

Key Inputs and Levelized Cost of Energy Results

| | | Land-Based | Offshore | | Distributed | | |
|------------------------------------|-----------|---------------|---------------------------------|-----------------------------|------------------------------------|-----------------------------------|------------------------------|
| Parameter | Units | Utility Scale | Utility Scale (Fixed Bottom) | Utility Scale (Floating) | Single Turbine (Residential) | Single Turbine (Commercial) | Single Turbine (Large) |
| Wind turbine rating | MW | 3.3 | 12 | 12 | 20 (kW) | 100 (kW) | 1.5 |
| Capital expenditures (CapEx) | \$/kW | 1,968 | 5,411 | 7,349 | 8,665 | 6,800 | 3,362 |
| Fixed charge rate (FCR) (real) | % | 6.5 | 6.76 | 6.76 | 6.68 | 6.68 | 6.68 |
| Operational expenditures (OpEx) | \$/kW/yr | 43 | 135 | 108 | 41 | 41 | 41 |
| Net annual energy production | MWh/MW/yr | 4,104 | 4,295 | 3,346 | 2,580 | 2,846 | 3,326 |
| Levelized cost of energy (LCOE) | \$/MWh | 42 | 117 | 181 | 240 | 174 | 80 |

Note: Additional information on the sources of data are presented in the Appendix. Unless specifically stated, all cost data presented in this document are reported in 2023 U.S. dollars (USD).

kW = kilowatt; MW = megawatt; MWh = megawatt-hour

Levelized Cost Breakdown for Reference Land-Based Wind Plant



Note: The "Contingency" cost category also includes insurance, permitting, bonding, and markup estimates. The "Operational Expenditure" category includes maintenance cost. Eng. = Engineering.

Levelized Cost Breakdown for Reference Fixed-Bottom Offshore Wind Plant



Note: The "Array System" cost includes costs associated with the procurement of the inter-array system cables of an offshore wind farm. Install. = Installation.

Levelized Cost Breakdown for Reference Floating Offshore Wind Plant



Note: The "Array System" cost includes costs associated with the procurement of the inter-array system cables of an offshore wind farm. Install. = Installation.

Levelized Cost Breakdown for **Reference Distributed Wind Projects**





80

Key Conclusions

- The reference project LCOE for **land-based installations is \$42/MWh**, with a range of landbased estimates from the single-variable sensitivity analysis covering \$30–\$61/MWh (see Slide 33).
- The **fixed-bottom offshore wind estimate is \$117/MWh**, and the **floating substructure reference project estimate is \$181/MWh**. These two reference projects give a single-variable sensitivity range of \$76–\$234/MWh (see Slides 46 and 47). This range is primarily caused by the large variation in CapEx (\$3,000–\$9,187/kW) and project design life.
- The **residential and commercial reference distributed wind** system LCOE are estimated at **\$240/MWh and \$174/MWh**, respectively. Single-variable sensitivity analysis for the representative systems is presented in the *2019 Cost of Wind Energy Review* (Stehly, Beiter, and Duffy 2020). Analysts included the LCOE estimate for a **large distributed wind energy** project in this year's analysis, estimated at **\$80/MWh**.



1 Background

- **2** U.S. Department of Energy Goals and Reporting Requirements
- **3** Land-Based Wind Energy
- **4** Offshore Wind Energy
- 5 Distributed Wind Energy

6 References

7 Appendix

1. Background

Background

- The Cost of Wind Energy Review: 2024 Edition estimates the levelized cost of energy (LCOE) for land-based, offshore, and distributed wind energy projects in the United States.
 - LCOE is a metric used to assess the cost of electricity generation and the total power-plant-level impact from technology design changes. It can be used to compare costs of all types of generation.
 - The specific LCOE method applied in this analysis is described in *A Manual for the Economic Evaluation of Energy Efficiency and Renewable Energy Technologies* (Short, Packey, and Holt 1995):

$$LCOE = \frac{(CapEx * FCR) + OpEx}{\left(\frac{AEP_{net}}{1,000}\right)}$$

- LCOE = levelized cost of energy (dollars per megawatt-hour [\$/MWh])
- FCR = fixed charge rate (%)
- CapEx = capital expenditures (dollars per kilowatt [\$/kW])
- AEP_{net} = net average annual energy production (megawatt-hours per megawatt per year [MWh/MW/yr])
- OpEx = operational expenditures (\$/kW/yr)

Background

- This review also provides an update to the 2022 Cost of Wind Energy Review (Stehly, Duffy, and Mulas Hernando 2023) and examines wind turbine costs, financing, and market conditions. The analysis includes:
 - Estimated LCOE for a representative land-based wind energy project installed in a moderate wind resource (i.e., International Electrotechnical Commission [IEC] wind class IIb [IEC 2020]) in the United States
 - Estimated LCOE for representative offshore (fixed-bottom and floating) wind energy projects using National Renewable Energy Laboratory (NREL) models and databases of globally installed projects; the authors assessed representative sites on the U.S. North Atlantic coast (fixed bottom) and Pacific coast (floating) using current lease and call information, nominations data from the Bureau of Ocean Energy Management, and various geospatial datasets
 - LCOE estimates for representative residential, commercial, and large distributed wind energy projects in the United States
 - Sensitivity analyses showing the range of effects that basic LCOE variables could have on the cost of wind energy for land-based and offshore wind power plants
 - Updates to the national supply curves for land-based and offshore wind energy based on geographically specific wind resource conditions paired with approximate wind turbine size characteristics
 - Projected land-based and offshore wind cost trajectories from 2022 through 2035 used for U.S. Department of Energy (DOE) annual wind power LCOE reporting as required by the Government Performance and Results Act (GPRA).

2. U.S. Department of Energy Goals and Reporting Requirements

DOE Goals and Reporting Requirements

- Every year, the Wind Energy Technologies Office (WETO) reports the LCOE for landbased wind and fixed-bottom offshore wind to satisfy GPRA reporting requirements.
- This report provides the underlying market and cost data for WETO to fulfill the annual GPRA reporting requirements.
- Updates to the LCOE targets are periodically implemented to keep performance measures current with developments in the market, incorporate improved cost and performance estimating tools, and reset the dollar year to minimize inflationary pressures on LCOE.
- In Fiscal Year (FY) 2023, new GPRA LCOE baseline values, cost reduction trajectories, and end-point targets were established for land-based wind and fixedbottom offshore wind.

GPRA Re-Baseline Efforts Then and Now

- The new baseline plant characteristics are a refinement of the previous values and were established using updated bottomup engineering cost and performance tools, expert wind industry feedback, and analysis from the Annual Technology Baseline (ATB).
- The new GPRA end-point targets are based on cost reduction trajectories for land-based and fixed-bottom offshore wind projects that span FY 2023 to FY 2035, whereas the previous re-baseline analyses had a target year in FY 2030.
- The need for future re-baseline efforts will be assessed periodically, and re-baselining will be implemented as needed.
- The table summarizes the methods and assumptions of prior GPRA targets and the updated methods and assumptions for FY 2023 GPRA targets.

| | Land-Based Wind | | Fixed-Bottom Offshore Wind | | |
|------------------------------|--|--|---|---|--|
| Effort | Prior GPRA Baseline (Former) | Re-Baseline (Current) | Prior GPRA Baseline (Former) | Re-Baseline (Current) | |
| Commercial Operation Date | 2015 | 2022 | 2018 | 2022 | |
| Technology | Market average turbine parameters | ATB Wind Turbine Technology 3 (3.3 MW, 148 m rotor diameter [RD], 100 m hub height [HH]) (<u>atb.nrel.gov</u>) | Market average turbine parameters | ATB Conservative Scenario (12 MW, 214 m RD, 136 m HH) (<u>atb.nrel.gov</u>) | |
| Cost | Market capacity-weighted average (2015 USD) | ATB Conservative Scenario (<u>atb.nrel.gov</u>) | Bottom-up cost modeling + BVG Assoc. innovations reductions (Beiter et al. 2016; Valpy et al. 2017) | CapEx estimated using technology learning similar to ATB (<u>atb.nrel.gov</u>); OpEx and AEP trajectories informed by Wiser et al. (2021) | |
| Finance | Finance model and market data | ATB finance assumptions in R&D case (atb.nrel.gov) | Fixed charge rate method with financing assumptions based on European conditions in 2018 | Fixed charge rate method with financing assumptions based on North American conditions in 2022 | |
| Resource | 7.25 m/s @ 50 m above the ground | 7.25 m/s @ 50 m above the ground | 8.43 m/s @ 50 m above the surface | 8.43 m/s @ 50 m above the surface | |
| Capacity Factor | 40% (16.7% total losses) | 46.8% (18.9% total losses) | 48.6% (16.2% total losses) | 48.7% (16.0% total losses) | |

GPRA Cost Reduction Pathway From 2023 to 2035 for Land-Based Wind



• The FY 2023 baseline assumes a representative wind turbine of 3.3 MW, 148 m (RD), 100 m (HH), and the FY 2035 target assumes a turbine of 6 MW, 170 m (RD), 115 m (HH).

• The land-based wind GPRA baseline value starts at \$39/MWh (in 2022 USD) set in FY 2023, using the 2022 reference project data.

• The land-based wind GPRA target is \$27/MWh by FY 2035 (in 2022 USD) and is derived from the analysis conducted in the 2023 Annual Technology Baseline: atb.nrel.gov.

GPRA Cost Reduction Pathway From 2023 to 2035 for Fixed-Bottom Offshore Wind



• The GPRA baseline value starts at \$95/MWh (in 2022 USD) set in FY 2023 using 2022 reference project data.

• The GPRA target is \$61/MWh by FY 2035 (commercial operations date [COD] 2034) (in 2022 USD) and is derived for a fixed-bottom wind plant at the reference site based on cost reductions informed by industry learning (Shields et al. 2022) and expert elicitation (Wiser et al. 2021). Note that values are rounded to the nearest dollar.

Modeled Cost Reduction Pathway From 2023 to 2035 for Floating Offshore Wind Energy



- DOE has no official GPRA reporting requirement for floating offshore wind energy costs.
- Projected floating offshore wind cost reductions are mapped to \$74/MWh in FY 2035 using similar methodology as fixed-bottom offshore wind.
- DOE established a Floating Offshore Wind Shot goal of \$45/MWh (2020 USD) by 2035 for a different reference site using a different set of assumptions.
- Note that values are rounded to the nearest dollar.

Baseline and GPRA Cost Reduction Pathway From 2023 to 2035 for Land-Based Wind Energy



- Fiscal year estimates informed by projects with COD the prior year (FY = COD + 1).
- The FY 2023 baseline assumes a representative wind turbine of 3.3 MW, 148 m (RD), 100 m (HH), and the FY 2035 target assumes a turbine of 6 MW, 170 m (RD), 115 m (HH).
- For GPRA reporting, the FY 2024 \$42/MWh LCOE was deflated from 2023 USD to 2022 USD using the Consumer Price Index from the Bureau of Labor and Statistics (undated).
- For comparison, the FY 2030 GPRA set in 2015 inflated from 2015 USD to 2022 USD using the Consumer Price Index from the Bureau of Labor and Statistics (undated).
- The FY 2023 and FY 2035 LCOE estimates are informed by the analysis conducted in the 2023 Annual Technology Baseline: atb.nrel.gov.

GPRA Cost Reduction Pathway From 2023 to 2035 for Fixed-Bottom Offshore Wind Energy



- The FY 2023 (COD 2022) LCOE is \$95/MWh with an FY 2035 (COD 2034) GPRA target of \$61/MWh.
- The FY 2035 target is informed by industry learning (Shields et al. 2022) and expert elicitation (Wiser et al. 2021).
- For GPRA reporting, the FY 2024 \$117/MWh LCOE estimate was deflated from 2023 USD to 2022 USD using the Consumer Price Index from the Bureau of Labor and Statistics (undated).
- For comparison, the FY 2030 GPRA set in 2019 and inflated from 2018 USD to 2022 USD using the Consumer Price Index from the Bureau of Labor and Statistics (undated).

3. Land-Based Wind Energy

Land-Based Wind Turbine Average Nameplate Capacity, Hub Height, Rotor Diameter, and Assumed Representative Wind Plant



Assumed wind turbine characteristics for project operating in 2023. <u>atb.nrel.gov</u>

| Parameter | Value |
|---------------------|--------|
| Wind turbine rating | 3.3 MW |
| Rotor diameter | 148 m |
| Hub height | 100 m |
| Wind plant capacity | 200 MW |
| Number of turbines | 61 |

Power curve data available on <u>https://github.com/NREL/turbine-models</u>.

Average turbine nameplate capacity, hub height, and rotor diameter for land-based wind projects. Graphic is based on new installations each year.

Source: Wiser and Millstein (2024)

Reference Land-Based Wind Site Characteristics and Performance



| Parameter | Value |
|---|--------------------|
| Annual average wind speed at 50 m above surface level | 7.25 m/s |
| Annual average wind speed at hub height | 8.01 m/s |
| Weibull k | 2.0 (factor) |
| Shear exponent | 0.14 |
| Gross energy capture | 5,055 MWh/MW/yr |
| Gross capacity factor | 57.7% |
| Total losses | 18.8% |
| Net energy capture | 4,14 MWh/MW/yr |
| Net capacity factor | 46.9% |

Wind resource of the United States, annual average wind speed at 100 m above surface level.

Map by Billy J. Roberts, NREL; more information at https://windexchange.energy.gov/maps-data/324

Land-Based Wind Project Component Cost Breakdown



 Turbine component cost estimates are derived from recent updates to NREL's Wind Plant Integrated Systems Design and Engineering Model (WISDEM®) <u>https://github.com/WISDEM/WISDEM</u>.

BOS component cost estimates are obtained from the Land-based Balance of System Systems Engineering (LandBOSSE) model (Eberle et al. 2019).

· Construction financing assumptions are from the 2024 Annual Technology Baseline atb.nrel.gov.

| Parameter | Value (2023\$/kW) |
|--------------------------------------|-------------------|
| Wind Turbine CapEx | 1,091 |
| Rotor | 337 |
| Nacelle | 477 |
| Tower | 276 |
| BOS CapEx | 582 |
| Engineering and development | 36 |
| Project management | 14 |
| Foundation | 120 |
| Site access, staging, and facilities | 47 |
| Assembly and installation | 100 |
| Electrical infrastructure | 72 |
| Wind turbine transport | 194 |
| Soft Cost | 295 |
| Construction finance | 111 |
| Contingency* | 54 |
| Wind turbine warranty | 130 |
| Total CapEx | 1,968 |

* Contingency category also includes insurance, permitting, bonding, NREL | 28 and markup estimates

Land-Based Wind Plant Operational Expenditures Estimate and Historical Data

Average Annual O&M Cost, 2000-2023 (2023 \$/kW-yr)



| Parameter | Value |
|----------------|------------|
| Estimated OpEx | \$43/kW-yr |

All-in project OpEx estimates informed by updated analysis conducted in the 2024 Annual Technology Baseline (<u>atb.nrel.gov</u>).

Average O&M costs for available data years from 2000 to 2023, by commercial operation date.

Source: Wiser and Millstein (2024)

Note: O&M data reported in the chart do not include all operating costs.

Land-Based Wind Project Financial Assumptions

| Parameter | Nominal Value | Real Value |
|----------------------------------|---------------|------------|
| Weighted average cost of capital | 6.25% | 3.66% |
| Capital recovery factor | 8.01% | 6.17% |
| Fixed charge rate (FCR) | 8.43% | 6.5% |

- The economic evaluation of wind energy investments in this analysis uses the FCR method from NREL's Annual Technology Baseline and Standard Scenarios web page: <u>atb.nrel.gov</u>.
- The FCR represents the amount of annual revenue required to pay the carrying charge as applied to the CapEx on that investment during the expected project economic life and is based on the capital recovery factor (CRF) but also reflects corporate income taxes and depreciation.
- The analysis assumes the reference project operates for 25 years, a 5-year Modified Accelerated Cost Recovery System (MACRS) depreciation schedule, and an inflation rate of 2.5%.
- Additional financial assumption details are displayed in the Appendix.

LCOE for Representative Land-Based Wind Plant and Historical Data

Installed Project LCOE (2023\$/MWh)



Estimated levelized cost of wind energy for actual wind projects by commercial operation date.

| Parameter | Value |
|-------------------------------------|--------------------|
| Wind turbine rating | 3.3 MW |
| Capital expenditures | \$1,968/kW |
| Fixed charge rate (real) | 6.5% |
| Operational expenditures | \$43/kW/yr |
| Net annual energy production | 4,104 MWh/MW/yr |
| Calculated levelized cost of energy | \$42/MWh |

Modeled cost and performance data using the methods presented in the 2024 Annual Technology Baseline (<u>atb.nrel.gov</u>) to calculate LCOE.

Source: Wiser and Millstein (2024)

LCOE Breakdown for Reference Land-Based Wind Plant



Note: The "Contingency" cost category also includes insurance, permitting, bonding, and markup estimates. "Operational Expenditure" includes maintenance cost. Eng. = Engineering

Range of LCOE Parameters for Land-Based Wind



Note: The reference LCOE reflects a representative industry LCOE. Changes in LCOE for a single variable can be understood by moving to the left or right along a specific variable. NREL | 33 Values on the *x*-axis indicate how the LCOE will change as a given variable is altered and all others are assumed constant (i.e., remain reflective of the reference project).

4. Offshore Wind Energy

2023 Market Average Offshore Wind Turbine and Representative Wind Plant



Global capacity-weighted average turbine rating, hub height, and rotor diameter for offshore wind projects in 2023.

Source: Offshore Wind Market Report: 2024 Edition (McCoy et al. 2024)

| Parameter | Value |
|---------------------|----------------------|
| Wind turbine rating | 12.0 MW |
| Rotor diameter | 216 m |
| Hub height | 137 m |
| Specific power | 327 W/m ² |
| Wind plant capacity | 600 MW |
| Number of turbines | 50 |

Representative turbine parameters and power curves available on <u>GitHub</u>

- Global capacity-weighted average turbine rating in 2023 was 9.7 MW as the global market has begun adopting machines in the range of 12–15 MW (McCoy et al. 2024).
- The first commercial-scale offshore wind projects installed in the United States selected 11-MW (South Fork Wind and Revolution Wind) and 13-MW (Vineyard Wind I) turbines.

Offshore Wind Reference Wind Sites and Wind Plant Performance

- The fixed-bottom offshore wind reference project represents near-term development in the U.S. Northeast.
- The floating offshore wind reference site represents the first leases in California.



Wind resource of the United States, annual average wind speed at 100 m above surface level.

Map by Billy J. Roberts, NREL; more information at https://windexchange.energy.gov/maps-data/324

| Parameter | Fixed- Bottom | Floating | Units |
|---|------------------|----------|---------------|
| Water depth | 34 | 739 | m |
| Export cable length | 50 | 36 | km |
| Annual average wind speed at 50 m | 8.43 | 7.67 | m/s |
| Annual average wind speed at hub height | 9.05 | 8.24 | m/s |
| Weibull k | 2.1 | 2.1 | factor |
| Shear exponent | 0.1 | 0.1 | # |
| Gross energy capture | 5,081 | 4,205 | MWh/MW /yr |
| Gross capacity factor | 58.0 | 48.0 | % |
| Total losses | 15.5 | 20.7 | % |
| Net energy capture | 4,295 | 3,346 | MWh/MW /yr |
| Net capacity factor | 49.0 | 38.2 | % |
Fixed-Bottom Offshore Wind System CapEx Component Cost Breakdown



NREL | 37

5.411

Total CapEx

Relative Value of Manufactured Components for an Offshore Wind Project

- The U.S. Department of the Treasury (2023) issued guidance listing the Applicable Project Components (APC) for an offshore wind facility. The table on the next slide estimates the percent cost contribution of each APC for a representative offshore wind project. It also provides a more detailed list of major components under each APC and estimates the percent cost contribution of each major component in the representative offshore wind project.
- These relative costs are based on empirical data, NREL's Wind Plant Integrated Systems Design and Engineering Model (WISDEM®) (<u>https://github.com/WISDEM/WISDEM</u>) and the Offshore Renewables Balance of System and Installation Tool (ORBIT) (<u>https://github.com/WISDEM/ORBIT</u>).

Relative Value of Manufactured Components for an Offshore Wind Project

¹ The list of offshore wind APCs is provided in U.S. Department of the Treasury (2023).

² The relative cost contributions and list of major components were developed by NREL.

³ Monopiles and transition pieces comprise several tubular steel sections that are welded together, integrated, and then finished. Transition pieces are further outfitted with personnel access systems prior to installation. Some transition pieces may be integrated with a monopile in a single facility.

⁴ A personnel access system includes internal platforms, external platforms, and boat landings.

⁵ The electrical system includes transformers, switchgear, shunt reactors (high-voltage alternating current substations only), and converters (highvoltage direct current substations only).

| Applicable Project Component (APC) ¹ | Percent Cost Contribution From Each APC (%) ² | Major APC Components ² | Percent Cost Contribution From Each Major Component (%) ² |
|--|---|---|---|
| Turbine | 51.4% | Nacelle | 28.5% |
| | | Blades | 13.1% |
| | | Hub | 4.8% |
| | | Power converter | 2.4% |
| | | Production | 2.6% |
| Monopile | 16.0% | Tubular monopile sections ³ | 14.1% |
| | | Production | 1.9% |
| Transition piece | 11.9% | Tubular transition piece section ³ | 4.3% |
| | | Personnel access system ⁴ | 7.1% |
| | | Production | 0.5% |
| Export cable | 7.9% | Armor | 1.3% |
| | | Insulated conductor | 4.4% |
| | | Sheathing | 1.3% |
| | | Production | 0.9% |
| Array cable | 2.6% | Armor | 0.4% |
| | | Insulated conductor | 1.5% |
| | | Sheathing | 0.4% |
| | | Production | 0.3% |
| Offshore substation | 9.4% | Electrical system ⁵ | 3.3% |
| | | Topside | 5.6% |
| | | Production | 0.5% |
| Wind tower flange | 0.8% | Preform | 0.6% |
| | | Production | 0.2% |
| | | | NREL 39 |

Floating Offshore Wind System Component Cost Breakdown



Commissioning

Total CapEx

74

7.349

NREL

40

https://github.com/WISDEM/ORBIT.

Note: Values rounded to the nearest dollar, and "Install." indicates installation.

Fixed-Bottom and Floating Offshore Wind OpEx Estimates

- Fixed-bottom and floating offshore wind plant OpEx estimates are calculated with NREL's Windfarm Operations & Maintenance cost-Benefit Analysis Tool (WOMBAT) (Hammond and Cooperman 2022).
- WOMBAT is a scenario-based tool* that uses a discrete event simulation framework to calculate the costs associated with component failures, scheduled maintenance tasks, and mobilization of equipment to carry out repairs.
- OpEx modeling assumptions:
 - 30 full-time technicians assumed per project in both sites
 - Three crew transfer vessels, one cable lay vessel, and one diving support vessel per project
 - Fixed-bottom site employs an in situ repair strategy
 - Floating case executes replacements through a tow-to-port strategy, which is assumed to be less expensive than in situ repairs
 - Failure rates and costs associated with repairs and replacements informed by COREWIND (2021).

| Parameter | Fixed Value (\$/kW-yr) | Floating Value (\$/kW-yr) |
|---------------------------|---------------------------|------------------------------|
| Maintenance | 113 | 69 |
| Labor (technicians) | 5 | 5 |
| Materials | 2 | 4 |
| Equipment (vessels) | 105 | 61 |
| Operations | 22 | 38 |
| Management administration | 2 | 2 |
| Port fees | 1 | 17 |
| Insurance | 19 | 19 |
| Total OpEx | 135 | 108 |

Values rounded to the nearest dollar.

Fixed-Bottom and Floating Offshore Wind Project Financial Assumptions

| Parameter | Nominal Value | Real Value |
|----------------------------------|---------------|------------|
| Weighted average cost of capital | 6.61% | 4.01% |
| Capital recovery factor | 8.28% | 6.41% |
| Fixed charge rate | 8.74% | 6.76% |

- The data used to calculate the weighted average cost of capital (WACC) are collected by NREL based on conversations with project developers and industry financiers and provides a basis for WACC assumptions for the representative wind project in 2022.
- The WACC, CRF, and FCR are given in nominal and real terms using the after-tax WACC discount rate of 6.61% and 4.01%, respectively, a project design lifetime of 25 years, and a net present value depreciation factor of 84.0% (assuming a 5-year MACRS depreciation schedule).
- Detailed financial assumptions are displayed in the Appendix.

Note: The WACC for land-based wind is higher than for offshore wind because it considers the influences of the production tax credit and assumes a lower debt fraction.

2023 Offshore Wind Reference Plant LCOE Estimates

- The LCOE values for the 2023 representative fixed-bottom and floating offshore wind plants are estimated at \$117/MWh and \$181/MWh, respectively.*
- LCOE is calculated with the formulation presented in NREL's Annual Technology Baseline and presented on Slide 15.

| Parameter | Fixed-Bottom 12.0- MW Offshore Wind Turbine | Floating 12.0-MW Offshore Wind Turbine | Units |
|------------------------------|---|--|-----------|
| Capital expenditures | 5,441 | 7,349 | \$/kW |
| Fixed charge rate (real) | 6.76 | 6.76 | % |
| Operational expenditures | 135 | 108 | \$/kW/yr |
| Net annual energy production | 4,295 | 3,346 | MWh/MW/yr |
| Total LCOE | 117 | 181 | \$/MWh |

* The LCOE estimates given above rely on bottom-up cost modeling and assume mature supply chains for 600-MW projects with a 2023 COD. In 2023, several U.S. projects were under construction, but none of them were fully commissioned in that year (McCoy et al. 2024). Readers should be cautious when comparing the above LCOE estimates with recent U.S. strike prices for the following reasons:

- LCOE and strike price are not the same thing. Developer profits and differences in the underlying technology, infrastructure, project structure, cost, performance, subsidy, and financing terms must be accounted when comparing LCOE and strike prices (Smart 2016; Beiter et al. 2021).
- Projects with different procurement timelines have varying levels of exposure to risks and inflationary pressures (DOE 2024). Expected CODs for recent solicitations range from 2026 to the early 2030s while the representative projects modeled in this report have an assumed COD in 2023.

Levelized Cost Breakdown for Reference Fixed-Bottom Offshore Wind Plant



Note: The "Array System" cost includes costs associated with the procurement of the inter-array system cables of an offshore wind farm.

Levelized Cost Breakdown for Reference Floating Offshore Wind Plant



Note: The "Array System" cost includes costs associated with the procurement of the inter-array system cables of an offshore wind farm.

Range of LCOE Parameters for Fixed-Bottom Offshore Wind Platform



Note: The reference LCOE reflects a representative industry LCOE. Changes in LCOE for a single variable can be understood by moving to the left or right along a specific variable. Values on the *x*-axis indicate how the LCOE will change as a given variable is altered and all others are assumed constant (i.e., remain reflective of the reference project).

Range of LCOE Parameters for Floating Offshore Wind Platform



Note: The reference LCOE reflects a representative industry LCOE. Changes in LCOE for a single variable can be understood by moving to the left or right along a specific variable. Values on the *x*-axis indicate how the LCOE will change as a given variable is altered and all others are assumed constant (i.e., remain reflective of the reference project).

5. Distributed Wind Energy

Distributed Wind Turbine Characteristics for Residential, Commercial, and Large-Scale Projects

| | V | | | |
|-------------------------|-------------|------------|-------|------------------|
| Parameter | Residential | Commercial | Large | Units |
| Wind turbine rating | 20 | 100 | 1,500 | kW |
| Rotor diameter | 12.4 | 27.6 | 77 | m |
| Hub height | 30 | 40 | 80 | m |
| Specific power | 166 | 167 | 322 | W/m ² |
| Number of wind turbines | 1 | 1 | 1 | - |

Wind turbine classes are aligned with the Distributed Wind Energy Futures Study (McCabe et al. 2022).

Distributed Wind Site Characteristics and Performance

| | Wind Turbine Class | | | |
|---|--------------------|------------|-------|-----------|
| Parameter | Residential | Commercial | Large | Units |
| Annual average wind speed at 50 m above surface level | 6 | 6 | 6 | m/s |
| Annual average wind speed at hub height | 5.58 | 5.81 | 6.42 | m/s |
| Weibull k | 2 | 2 | 2 | factor |
| Shear exponent | 0.14 | 0.14 | 0.14 | # |
| Gross energy capture | 2,916 | 3,217 | 3,759 | MWh/MW/yr |
| Gross capacity factor | 33.3 | 36.7 | 42.9 | % |
| Losses | 6.86 | 6.86 | 6.86 | % |
| Availability | 95 | 95 | 95 | % |
| Total losses | 11.5 | 11.5 | 11.5 | % |
| Net energy capture | 2,580 | 2,846 | 3,326 | MWh/MW/yr |
| Net capacity factor | 29.5 | 32.5 | 38 | % |

Residential and commercial wind turbines assume stall-regulated power curves; the large wind turbine assumes pitch-regulated power curve. Power curve data available on https://github.com/NREL/turbine-models.

Distributed Wind Project Component Cost Breakdown and Estimated Operational Expenditures



- BOS component cost estimates are obtained from the LandBOSSE model (Eberle et al. 2019).
- Because CapEx data are scarce for distributed wind projects, further cost details on the individual system components are not presented.
- OpEx market data are not widely available for distributed wind projects; therefore, \$41/kW/yr is assumed for each wind class and is aligned with the 2024 ATB <u>atb.nrel.gov</u>.

Distributed Wind Project Financial Assumptions

| Parameter | Nominal | Real |
|--------------------------------------|---------|------|
| Weighted average cost of capital (%) | 6.5 | 3.9 |
| Capital recovery factor (%) | 8.2 | 6.33 |
| Fixed charge rate (%) | 8.64 | 6.68 |

- The economic evaluation of wind energy investments in this analysis uses the FCR method used in NREL's Annual Technology Baseline and Standard Scenarios web page: <u>atb.nrel.gov</u>.
- The FCR represents the amount of annual revenue required to pay the carrying charge as applied to the CapEx on that investment during the expected project economic life and is based on the CRF but also reflects corporate income taxes and depreciation.
- The analysis assumes the reference projects operate for 25 years and a 5-year MACRS depreciation schedule; for simplicity, financial assumptions are assumed to be the same for each wind class and are aligned with the assumptions in the 2024 Annual Technology Baseline <u>atb.nrel.gov</u>.
- Additional financial assumption details are displayed in the Appendix.

LCOE Breakdown for Reference Distributed Wind Projects







References

Beiter, P., W. Musial, A. Smith, L. Kilcher, R. Damiani, M. Maness, et al. 2016. *A Spatial-Economic Cost Reduction Pathway Analysis for U.S. Offshore Wind Energy Development from 2015-2030*. Golden, CO: National Renewable Energy Laboratory. NREL/TP6A20-66579. https://www.nrel.gov/docs/fy16osti/66579.pdf.

Beiter, Philipp, Lena Kitzing, Paul Spitsen, Miriam Noonan, Volker Berkhout, Yuka Kikuchi. 2021. "Toward global comparability in renewable energy procurement." Joule 5 (6): 1485-1500. <u>https://doi.org/10.1016/j.joule.2021.04.017</u>.

Bureau of Labor and Statistics. Undated. "CPI Inflation Calculator." Accessed September 2022. https://www.bls.gov/data/#calculators.

COREWIND. 2021. *Floating Wind O&M Strategies Assessment*. COREWIND. August 2021. <u>https://corewind.eu/wp-content/uploads/files/publications/COREWIND-D4.2-Floating-Wind-O-and-M-Strategies-Assessment.pdf</u>.

Eberle, A., O. Roberts, A. Key, P. Bhaskar, and K. Dykes. 2019. *NREL's Balance-of-System Cost Model for Land-Based Wind*. Golden, CO: National Renewable Energy Laboratory. NREL/TP-6A20-72201. <u>https://www.nrel.gov/docs/fy19osti/72201.pdf</u>.

Hammond, R. and A. Cooperman. 2022. *Windfarm Operations and Maintenance cost-Benefit Analysis Tool (WOMBAT).* Golden, CO: National Renewable Energy Laboratory. NREL/TP-5000-83712. <u>https://www.nrel.gov/docs/fy23osti/83712.pdf</u>.

International Electrotechnical Commission. 2020. Accessed September 2020. https://www.iec.ch/.

Lantz, E., B. Sigrin, M. Gleason, R. Preus, and I. Baring-Gould. 2016. *Assessing the Future of Distributed Wind: Opportunities for Behind-the-Meter Projects.* Golden, CO: National Renewable Energy Laboratory. NREL/TP-6A20-67337.

McCabe, K., A. Prasanna, J. Lockshin, P. Bhaskar, T. Bowen, R. Baranowski, B. Sigrin, and E. Lantz. 2022. *Distributed Wind Energy Futures Study*. Golden, CO: National Renewable Energy Laboratory. NREL/TP-7A40-82519. <u>https://www.nrel.gov/docs/fy22osti/82519.pdf</u>.

References

McCoy, A., W. Musial, R. Hammond, D. Mulas Hernando, P. Duffy, P. Beiter, P. Pérez, R. Baranowski, and P. Spitsen. 2024. *Offshore Wind Market Report:* 2024 Edition. Golden, CO: National Renewable Energy Laboratory. NREL/TP-5000-90525. <u>https://www.nrel.gov/docs/fy24osti/90525.pdf</u>.

National Renewable Energy Laboratory (NREL). Undated. "Annual Technology Baseline." Accessed September 2024. https://atb.nrel.gov/.

Nunemaker, J., M. Shields, R. Hammond, and P. Duffy. 2020. ORBIT: Offshore Renewables Balance-of-System and Installation Tool. Golden, CO: National Renewable Energy Laboratory. NREL/TP-5000-77081. <u>https://www.nrel.gov/docs/fy20osti/77081.pdf</u>.

Short, W., D. J. Packey, and T. Holt. 1995. A Manual for the Economic Evaluation of Energy Efficiency and Renewable Energy Technologies. Golden, CO: National Renewable Energy Laboratory. NREL/TP-462-5176. <u>http://www.nrel.gov/docs/legosti/old/5173.pdf</u>.

Shields, M., P. Beiter, and J. Nunemaker. 2022. A Systematic Framework for Projecting the Future Cost of Offshore Wind Energy. Golden, CO: National Renewable Energy Laboratory. NREL/TP-5000-81819. <u>https://www.nrel.gov/docs/fy23osti/81819.pdf</u>.

Smart, Gavin. 2016. *Offshore Wind Cost Reduction - Recent and future trends in the UK and Europe*. Offshore Renewable Energy Catapult. TLI-SP-00007. <u>https://cms.ore.catapult.org.uk/wp-content/uploads/2017/12/SP00007-Offshore-Wind-Cost-Reduction.pdf</u>.

Stehly, T., P. Duffy, and D. Mulas Hernando. 2023. 2022 Cost of Wind Energy Review. Golden, CO: National Renewable Energy Laboratory. NREL/PR-5000-88335. https://www.nrel.gov/docs/fy24osti/88335.pdf.

Stehly, T., P. Beiter, P. Duffy. 2020. 2019 Cost of Wind Energy Review. Golden, CO: National Renewable Energy Laboratory. NREL/TP-5000-78471. https://www.nrel.gov/docs/fy21osti/78471.pdf.

UL Solutions. Undated. "Wind Farm Design Software Developed on More Than 30 Years of Expertise." https://aws-dewi.ul.com/software/openwind/.

References

U.S. Department of Energy (DOE). 2024. "The Pathway to: Offshore Wind Commercial Liftoff." Accessed May 14, 2024. <u>https://liftoff.energy.gov/offshore-wind-liftoff/</u>.

U.S. Department of the Treasury. 2023. "Domestic Content Bonus Credit Guidance Under Sections 45, 45Y, 48, and 48E." Accessed September 2024. https://www.irs.gov/pub/irs-drop/n-23-38.pdf.

Valpy, B. G. Hundleby, K. Freeman, A. Roberts, A. Logan. 2017. Future renewable energy costs: Offshore wind; 57 technology innovations that will have greater impact on reducing the cost of electricity from European offshore wind farms. InnoEnergy and BVG Associates. <u>https://bvgassociates.com/wp-content/uploads/2017/11/InnoEnergy-Offshore-Wind-anticipated-innovations-impact-2017_A4.pdf</u>.

Wiser, R. and D. Millstein. 2024. *Land-Based Wind Market Report: 2024 Edition*. Washington, D.C.: U.S. Department of Energy DOE/GO-102023-6055. <u>https://www.energy.gov/eere/wind/articles/land-based-wind-market-report-2023-edition</u>.

Wiser, R., J. Rand, J. Seel, P. Beiter, E. Baker, E. Lantz, and P. Gilman. 2021. "Expert Elicitation Survey Predicts 37% to 49% Declines in Wind Energy Costs by 2050." *Nature Energy* 6: 555–565. <u>https://doi.org/10.1038/s41560-021-00810-z</u>.

7. Appendix

Methodology for Estimating the Percent Cost Contribution of Major Components in a Fixed-Bottom Offshore Wind Facility

- The U.S. Department of Treasury (2023) provides a list of Applicable Project Components (APCs) for an offshore wind facility.
- NREL developed what we believe to be a representative list of major components, including key subassemblies and systems, that contribute significantly to the cost of the APCs.
- We used NREL engineering and cost models (including WISDEM and ORBIT), coupled with empirical data, to estimate the cost of each major component for a range of turbine and plant configurations, and then reviewed these cost estimates with offshore wind manufacturers.
- Based on these results, we estimated the relative (or percentage) cost contribution of each manufactured component for the following reference offshore wind project. Note that this project definition differs from the project used in the majority of the report so that it can be more representative of upcoming offshore wind projects in the United States.

| Parameter | Value |
|----------------------------|------------------------------------|
| Plant capacity | 1,200 MW |
| Turbine rating | 15 MW |
| Water depth | 40 m |
| Cable distance to landfall | 70 km |
| Export cable voltage | 220 kV (HVAC), OR 320 kV (HVDC) |
| Array cable voltage | 66 kV |

kV = kilovolt; HVAC = high-voltage alternating current; HVDC = high-voltage direct current

Land-Based Wind Reference Project Details

| Parameter | Units | Value | Notes | | | |
|---|------------------|-------|--|--|--|--|
| Wind Plant and Reference Site Characteristics | | | | | | |
| Wind plant capacity | MW | 200 | | | | |
| Number of turbines | - | 61 | | | | |
| Turbine rating | MW | 3.3 | Representative of current commercial-scale projects atb.nrel.gov | | | |
| Rotor diameter | m | 148 | | | | |
| Hub height | m | 100 | | | | |
| Specific power | W/m ² | 192 | Calculation | | | |
| Annual average wind speed at 50 m | m/s | 7.25 | Reference site wind speed | | | |
| Annual average wind speed at hub height | m/s | 8.01 | Between IEC class III (7.5 m/s) and IEC class II (8.5 m/s) | | | |
| Weibull k factor | - | 2 | | | | |
| Shear exponent | - | 0.143 | Shear for neutral stability conditions | | | |
| Total system losses | % | 18.8 | atb.nrel.gov | | | |
| Net energy capture | MWh/MW/yr | 4,104 | Sustain Advisor Mandall (CANA) as substain | | | |
| Net capacity factor | % | 46.9 | - System Advisor Model [®] (SAM) calculation | | | |

Land-Based Wind System CapEx Breakdown

| Parameter | Value (\$/kW) | Notes |
|-----------------------------|---------------|--|
| | | СарЕх |
| Total CapEx | 1,968 | Calculation |
| Turbine | 1,091 | |
| Rotor module | 337 | |
| Blades | 282 | |
| Pitch assembly | 13 | |
| Hub assembly | 42 | |
| Nacelle module | 477 | Wind Plant Integrated Systems Design and Engineering Model (WISDEM, https://github.com/WISDEM/WISDEM) |
| Nacelle structural assembly | 76 | |
| Drivetrain assembly | 236 | |
| Nacelle electrical assembly | 137 | |
| Yaw assembly | 28 | |
| Tower module | 276 | |

(Continued on next slide)

Land-Based Wind System CapEx Breakdown (continued)

| Parameter Value (\$/kW) | | Notes |
|------------------------------------|-----|--|
| | | СарЕх |
| Balance of system | 582 | |
| Development | 36 | |
| Engineering and project management | 14 | |
| Foundation | 120 | Land based Pelance of Sustaine Sustaine Engineering (LandPOSSE) (Sharle et al. 2010) |
| Site access and staging | 47 | - Land-based Balance of System Systems Engineering [LandBOSSE] (Eberie et al. 2019) |
| Assembly and installation | 100 | |
| Electrical infrastructure | 72 | |
| Wind turbine transport | 194 | |
| Soft costs | 295 | |
| Construction finance | 111 | atb.nrel.gov |
| Contingency | 54 | Includes insurance, permitting, bonding, and markup estimates |
| Wind turbine warranty | 130 | Assumes 2-year warranty |

Land-Based Wind OpEx and Financing Terms

| Parameter | U | Jnits Valu | Notes | | | | |
|---|------------|--------------|---|--|--|--|--|
| | OpEx | | | | | | |
| Total OpEx | \$/kW/year | 43 | atb.nrel.gov | | | | |
| Financials | | | | | | | |
| Project design life | Years | 25 | Project life assumption for Government Performance and Reporting Act (GPRA) reporting | | | | |
| Tax rate (combined state and federal) | % | 25.7 | | | | | |
| Inflation rate | % | 2.5 | atb.nrel.gov | | | | |
| Interest during construction (nominal) | % | 7.0 | | | | | |
| Construction finance factor | % | 106.0 | Calculation | | | | |
| Debt fraction | % | 72.4 | | | | | |
| Debt interest rate (nominal) | % | 7 | atb.nrel.gov | | | | |
| Return on equity (nominal) | % | 9 | | | | | |
| WACC (nominal; after-tax) | % | 6.25 | | | | | |
| WACC (real; after-tax) | % | 3.66 | | | | | |
| Capital recovery factor (nominal; after-tax) | % | 8.01 | | | | | |
| Capital recovery factor (real; after-tax) | % | 6.17 | | | | | |
| Depreciable basis | % | 100 | Simplified depreciation schedule | | | | |
| Depreciation schedule | - | 5-year MACRS | Modified Accelerated Cost Recovery System (MACRS) is standard for U.S. wind projects | | | | |
| Depreciation adjustment (net present value [NPV]) | % | 84.7 | | | | | |
| Project finance factor | % | 105 | Calculation | | | | |
| FCR (nominal) | % | 8.43 | | | | | |
| FCR (real) | % | 6.50 | | | | | |
| Levelized cost of energy | \$/MWh | 42 | Calculation | | | | |

Fixed-Bottom Offshore Wind Reference Project Details

| Assumption | Units | Value | Notes |
|---|------------------|--------------------|--|
| | | it characteristics | |
| Wind plant capacity | MW | 600 | Representative of commercial-scale projects |
| Number of turbines | - | 50 | Calculation |
| Turbine rating | MW | 12 | |
| Rotor diameter | m | 216 | Informed by <i>Offshore Wind Market Report: 2024 Edition</i> (McCoy et al. 2024) and early |
| Hub height | m | 137.0 | |
| Specific power | W/m ² | 327 | Calculation |
| Water depth | m | 34 | |
| Substructure type | - | Monopile | |
| Distance from shore | km | 50 | |
| Cut-in wind speed | m/s | 3 | |
| Cut-out wind speed | m/s | 25 | Representative fixed-bottom offshore site for COE Review |
| Average annual wind speed at 50 m | m/s | 8.4 | |
| Average annual wind speed at hub height | m/s | 9.0 | |
| Shear exponent | - | 0.10 | |
| Weibull k | - | 2.1 | |
| Total system losses | % | 15.5 | Offshore Regional Cost Analyzer (ORCA) (based on Beiter et al. 2016) |
| Gross energy capture | MWh/MW/year | 5,081 | Calculation |
| Net energy capture | MWh/MW/year | 4,295 | |
| Gross capacity factor | % | 58.0 | |
| Net capacity factor | % | 49.0 | |

Fixed-Bottom Offshore Wind System CapEx Breakdown

| Assumption | Value (\$/kW) | Notes | |
|--|---------------|---|--|
| | | CapEx | |
| Total CapEx | 5,411 | | |
| Turbine | 1,770 | | |
| Rotor-nacelle assembly | 1,487 | Informed by collaborations with industry partners | |
| Tower | 283 | | |
| Balance of system | 2,629 | | |
| Development | 121 | | |
| Project management | 2 | | |
| Substructure and foundation | 788 | | |
| Substructure | 232 | | |
| Foundation | 556 | | |
| Electrical infrastructure | 1,267 | BOS Costs computed with ORBIT (Nunemaker et al. 2020) | |
| Array cable system | 477 | | |
| Export cable system | 532 | | |
| Grid connection | 258 | | |
| Assembly and installation | 284 | | |
| Turbine installation | 112 | | |
| Substructure and foundation installation | 172 | | |
| Soft Costs | 1,012 | | |
| Insurance during construction | 55 | | |
| Decommissioning bond | 145 | | |
| Construction finance | 240 | Cafe Casta as we used using some mathedalam, as OBCA (Baitan at al. 2010) | |
| Sponsor contingency | 517 | Son Costs computed using same methodology as ORCA (Beiter et al. 2016) | |
| Procurement contingency | 228 | | |
| Installation contingency | 289 | | |
| Project completion / commissioning | 55 | | |

Fixed-Bottom Offshore Wind OpEx and Financing Terms

| Assumption | Units | Value | Notes |
|--|------------|--------------|---|
| | | | OpEx |
| Total OpEx | \$/kW/year | 135 | |
| Operations (pretax) | \$/kW/year | 22 | Calculated with WOMBAT |
| Maintenance | \$/kW/year | 113 | |
| | | Fir | nancials |
| Project design life | Years | 25 | Offshore wind project life for GPRA reporting |
| Tax Rate (combined state and federal) | % | 26 | |
| Inflation rate | % | 2.5 | |
| Debt fraction | % | 73 | Updated based on conversations with industry partners |
| Debt interest rate (nominal) | % | 7.0 | |
| Return on equity (nominal) | % | 10.5 | |
| WACC (nominal; after-tax) | % | 6.61 | |
| WACC (real; after-tax) | % | 4.01 | |
| Capital recovery factor (nominal; after-tax) | % | 8.28 | |
| Capital recovery factor (real; after-tax) | % | 6.41 | |
| Depreciable basis | % | 100 | Simplified depreciation schedule |
| Depreciation schedule | - | 5-year MACRS | Standard for U.S. wind projects |
| Depreciation adjustment (NPV) | % | 84.0 | |
| Project finance factor | % | 106 | |
| FCR (nominal) | % | 8.74 | |
| FCR (real) | % | 6.76 | |
| Levelized cost of energy | \$/MWh | 117 | Calculation |

Floating Offshore Wind Reference Project Details

| Assumption | Units | Value | Notes | | | | |
|---|------------------|-----------------|--|--|--|--|--|
| Wind plant characteristics | | | | | | | |
| Wind plant capacity | MW | 600 | Representative of commercial-scale projects | | | | |
| Number of turbines | - | 50 | Calculation | | | | |
| Turbine rating | MW | 12 | | | | | |
| Rotor diameter | m | 216 | Informed by <i>Uffshore Wind Market Report: 2024 Edition</i> (McCoy et al. 2024) and ear | | | | |
| Hub height | m | 137.0 | | | | | |
| Specific power | W/m ² | 327 | Calculation | | | | |
| Water depth | m | 739 | | | | | |
| Substructure type | - | Semisubmersible | | | | | |
| Distance from shore | km 36 | | | | | | |
| Cut-in wind speed | m/s | 3 | Representative floating site for Cost of Wind Energy Review | | | | |
| Cut-out wind speed | m/s | 25 | | | | | |
| Average annual wind speed at 50 m | m/s | 7.7 | | | | | |
| Average annual wind speed at hub height | m/s 8.5 | | | | | | |
| Shear exponent | - | 0.10 | | | | | |
| Weibull k | - | 2.1 | | | | | |
| Total system losses | % | 20.7 | Offshore Regional Cost Analyzer (ORCA) (based on Beiter et al. 2016) | | | | |
| Gross energy capture | MWh/MW/year | 4,205 | Calculation | | | | |
| Net energy capture | MWh/MW/year | 3,346 | | | | | |
| Gross capacity factor | % | 48.0 | | | | | |
| Net capacity factor | % | 38.2 | | | | | |

Floating Offshore Wind System CapEx Breakdown

| Assumption Value (\$/kW) | | Notes | | |
|--|-------|---|--|--|
| | | СарЕх | | |
| Total CapEx | 7,349 | | | |
| Turbine | 1,770 | | | |
| Rotor-nacelle assembly | 1,487 | Informed by collaborations with industry partners | | |
| Tower | 283 | | | |
| Balance of system | 4,254 | | | |
| Development | 121 | | | |
| Project management | 2 | | | |
| Substructure and foundation | 2,192 | | | |
| Substructure | 1,541 | | | |
| Foundation | 651 | | | |
| Electrical infrastructure | 1,428 | BOS Costs computed with ORBIT (Nunemaker et al. 2020) | | |
| Array cable system | 654 | | | |
| Export cable system | 500 | | | |
| Grid connection | 274 | | | |
| Assembly and installation | 345 | | | |
| Turbine installation | 0 | | | |
| Substructure and foundation installation | 345 | | | |
| Lease price | 167 | | | |
| Soft Costs | 1,325 | | | |
| Insurance during construction | 74 | | | |
| Decommissioning bond | 184 | | | |
| Construction finance | 319 | | | |
| Sponsor contingency 675 | | Soft Costs computed using same methodology as OKCA (Beiter et al. 2016) | | |
| Procurement contingency | 307 | | | |
| Installation contingency | 368 | | | |
| Project completion / commissioning | 74 | | | |

Note: Floating turbine installation costs are included in the "Substructure and foundation installation" line item since the turbine is integrated with the substructure at the quayside before the assembly is towed out and installed at the project site.

Floating Offshore Wind OpEx and Financing Terms

| Assumption | Units | Value | Notes | | | | | |
|--|------------|--------------|---|--|--|--|--|--|
| | | 0 | pEx | | | | | |
| Total OpEx | \$/kW/year | 108 | | | | | | |
| Operations (pretax) | \$/kW/year | 38 | Calculated with WOMBAT | | | | | |
| Maintenance | \$/kW/year | 69 | | | | | | |
| Financials | | | | | | | | |
| Project design life | Years | 25 | Offshore wind project life for GPRA reporting | | | | | |
| Tax rate (combined state and federal) | % | 26 | | | | | | |
| Federal | % | 21 | | | | | | |
| State | % | 4.7 | | | | | | |
| Inflation rate | % | 2.5 | Updated based on conversations with industry partners | | | | | |
| Debt fraction | % | 73 | | | | | | |
| Debt interest rate (nominal) | % | 7.0 | | | | | | |
| Return on equity (nominal) | % | 10.5 | | | | | | |
| WACC (nominal; after-tax) | % | 6.61 | | | | | | |
| WACC (real; after-tax) | % | 4.01 | Coloridation | | | | | |
| Capital recovery factor (nominal; after-tax) | % | 8.28 | | | | | | |
| Capital recovery factor (real; after-tax) | % | 6.41 | | | | | | |
| Depreciable basis | % | 100 | Simplified depreciation schedule | | | | | |
| Depreciation schedule | - | 5-year MACRS | Standard for U.S. wind projects | | | | | |
| Depreciation adjustment (NPV) | % | 84.0 | | | | | | |
| Project finance factor | % | 106 | | | | | | |
| FCR (nominal) | % | 8.74 | | | | | | |
| FCR (real) | % | 6.76 | | | | | | |
| Levelized cost of energy | \$/MWh | 181 | Calculation | | | | | |

Distributed Wind Reference Project Details

| Parameter | Units | 20-kW Value | 100-kW Value | 1,500-kW Value | Notes | | | |
|---|------------------|----------------|-----------------|-------------------|--|--|--|--|
| Wind Plant Characteristics | | | | | | | | |
| Wind plant capacity | kW | 20 | 100 | 1,500 | Poprocontative of recidential distributed wind project | | | |
| Number of turbines | - | 1 | 1 | 1 | Representative of residential distributed wind project | | | |
| Turbine rating | kW | 20 | 100 | 1,500 | Accessing the Future of Distributed Wind, Opportunities for Debind the Mater Brainets (Lente | | | |
| Rotor diameter | m | 12.4 | 27.6 | 77 | Assessing the Future of Distributed Wind: Opportunities for Benind-the Weter Projects (Lanz | | | |
| Hub height | m | 30 | 40 | 80 | et al. 2010) | | | |
| Specific power | W/m ² | 166 | 167 | 322 | Calculation | | | |
| Cut-in wind speed | m/s | 3 | 3 | 3 | Tunical turbing characteristics | | | |
| Cut-out wind speed | m/s | 20 | 25 | 25 | | | | |
| Annual average wind speed at 50 m | m/s | 6.00 | 6.00 | 6.00 | Reference site wind speed | | | |
| Annual average wind speed at hub height | m/s | 5.58 | 5.81 | 6.42 | IEC class IV | | | |
| Weibull k factor | - | 2.0 | 2.0 | 2.0 | | | | |
| Shear exponent | - | 0.143 | 0.143 | 0.143 | Shear for neutral stability conditions | | | |
| Altitude above mean sea level | m | 0 | 0 | 0 | Altitude at turbine foundation | | | |
| Losses | % | 7 | 7 | 7 | Informed by "Competitiveness Improvement Project" | | | |
| Availability | % | 95 | 95 | 95 | (https://www.nrel.gov/wind/competitiveness-improvement-project.html) | | | |
| Net energy capture | kWh/kW/yr | 2,580 | 2,846 | 3,326 | | | | |
| Net capacity factor | % | 29.5 | 32.5 | 38.0 | Calculation in Openwind (UL website: https://aws-dewi.ul.com/software/openwind/) | | | |

Distributed Wind System CapEx, OpEx, and Financials Breakdown

| Parameter | Units | 20-kW Value | 100-kW Value | 1,500-kW Value | Notes | | |
|--|------------|--------------|--------------|-------------------|---|--|--|
| CapEx | | | | | | | |
| Total CapEx | \$/kW | 8,665 | 6,800 | 3,362 | | | |
| Turbine | \$/kW | 3,932 | 4,001 | 2,459 | atb.nrel.gov | | |
| Balance of system | \$/kW | 4,733 | 2,799 | 903 | NREL's Balance-of-System Cost Model for Land-Based Wind (Eberle et. al., 2019) | | |
| OpEx | | | | | | | |
| Total OpEx | \$/kW/year | 41 | 41 | 41 | Assessing the Future of Distributed Wind: Opportunities for Behind-the Meter Projects (Lantz et al. 2016) | | |
| | | | | | Financials | | |
| Project design life | Years | 25 | 25 | 25 | Project life for Government Performance and Reporting Act (GPRA) reporting | | |
| Tax Rate (combined state and federal) | % | 25.7 | 25.7 | 25.7 | ath avail any | | |
| Inflation rate | % | 2.5 | 2.5 | 2.5 | | | |
| Debt fraction | % | 73 | 73 | 73 | Assessing the Future of Distributed Wind: Opportunities for Behind-the Meter Projects (Lantz et al. 2016) | | |
| Debt interest rate (nominal) | % | 7 | 7 | 7 | Lawrence Barkelay National Laboratory 2021 financial analyzic | | |
| Return on equity (nominal) | % | 10 | 10 | 10 | | | |
| WACC (nominal; after-tax) | % | 6.5 | 6.5 | 6.5 | | | |
| WACC (real; after-tax) | % | 3.9 | 3.9 | 3.9 | Calculation | | |
| Capital recovery factor (nominal; after-tax) | % | 8.2 | 8.2 | 8.2 | | | |
| Capital recovery factor (real; after-tax) | % | 6.33 | 6.33 | 6.33 | | | |
| Depreciable basis | % | 100 | 100 | 100 | Simplified depreciation schedule | | |
| Depreciation schedule | - | 5-year MACRS | 5-year MACRS | 5-year MACRS | | | |
| Depreciation adjustment (NPV) | % | 84.2 | 84.2 | 84.2 | | | |
| Project finance factor | % | 105 | 105 | 105 | | | |
| FCR (nominal) | % | 8.64 | 8.64 | 8.64 | | | |
| FCR (real) | % | 6.68 | 6.68 | 6.68 | | | |
| Levelized cost of energy | \$/MWh | 240 | 174 | 80 | Calculation | | |

Thank You

www.nrel.gov

NREL/PR-5000-91775

This work was authored by the National Renewable Energy Laboratory, operated by Alliance for Sustainable Energy, LLC, for the U.S. Department of Energy (DOE) under Contract No. DE-AC36-08GO28308. Funding provided by U.S. Department of Energy Office of Energy Efficiency and Renewable Energy Wind Energy Technologies Office. The views expressed in the article do not necessarily represent the views of the DOE or the U.S. Government. The U.S. Government retains and the publisher, by accepting the article for publication, acknowledges that the U.S. Government retains a nonexclusive, paid-up, irrevocable, worldwide license to publish or reproduce the published form of this work, or allow others to do so, for U.S. Government purposes.

Transforming ENERGY

Photo from iStock-627281636