

**Request for Information: Stakeholder Priorities for IEEE Std 1547-2018 Training and Education
Results to Date (5/16/19)**

											Total Respondents to Date		8	
Requirements Topic Areas	Fluency with IEEE Std 1547-2018 Requirements					Importance					Urgency			
	Not at all fluent	A little fluent	Somewhat fluent	Fluent	Extremely Fluent	Not important	A little important	Somewhat important	Important	Extremely Important	Immediate (0 - 12 Months)	Soon (12 - 24 Months)	Future (> 24 Months)	Not urgent (no plans)
Overall scope and intent of the standard		38%	50%	13%					88%		13%	25%	63%	
DER requirements during enter and exit service, including synchronism	50%	38%		13%				50%	50%	13%		25%	75%	
Exemptions from requirements for emergency and standby systems	38%	50%	13%				13%		88%			25%	63%	13%
Reactive power capabilities, voltage and reactive/active power control modes	13%	50%	38%						50%	50%		25%	75%	
Abnormal voltage and frequency response (ride-through)	13%	38%	50%						50%	50%		38%	63%	
Coordination of protective devices	25%	63%	13%					13%	63%	25%		25%	63%	13%
Power quality requirements	13%	38%	13%	25%				13%	38%	38%		13%	75%	13%
Safety requirements (including those for unintentional islanding)		75%	13%	13%					25%	75%		50%	38%	13%
Requirements for intentional islanding	25%	63%		13%				13%	63%	25%		13%	63%	25%
Using DER on secondary networks	25%	50%		25%		13%	13%	25%	38%	13%		13%	75%	13%
Requirements for communications and control (interoperability) requirements	25%	38%	25%	13%				13%	75%	13%		25%	63%	13%
Requirements for testing and verification (including type testing and commissioning)	75%	13%		13%			13%	25%	50%	13%		25%	63%	13%
Considerations for coordinating with bulk power system operations	25%	50%	13%	13%				13%	50%	38%		25%	63%	13%