Strategies for Improving Interconnection Prospecting Tools

Why grid transparency is necessary to enabling an efficient interconnection process.

SHAY BANTON

Pronouns: They/Them

Regulatory Program Engineer & Energy Justice Advocate



Interstate Renewable Energy Council (IREC)



IREC builds the foundation for rapid adoption of clean energy and energy efficiency to benefit people, the economy, and our planet.









What Is Grid Transparency?





((





Who Uses Grid Data?





Who Uses Grid Data?

Regulators

- Monitor DER deployment trends
- Distribution system planning

Local governments

- Design incentives and other programs

- Stakeholders and NGOs
- Today's DER customers and developers
 - DER siting and design
- Tomorrow's innovative entrepreneurs



improving process efficiency for all stakeholders



IREC















Prospecting Tools as a method of Grid Transparency



15 **Prospecting Tools** O (0 **Pre-Application Public Queue Hosting Capacity** Reporting Reports Analysis **Distribution System Basic Distribution Data Portals System Maps**

Overview

- Customer requests data for specific Point of Interconnection
- Typically cost ~\$300 per report
- Utilities typically respond with data in 10 business days





Requested Data

- Approximate circuit distance between proposed site and substation
- Number and rating of protective devices and number and type of voltage regulating devices, between proposed site and substation



- Whether or not three-phase power is available at the site and/or distance from three-phase service
- Limiting conductor rating from proposed Point of Interconnection to distribution substation



Requested Data Continued...

Typically includes the following info about the area of the grid (substation/area bus or bank and circuit) likely to serve the site:

- Total capacity of substation
- Aggregate existing generating capacity
- Aggregate queued generating capacity
- Available capacity of substation
- Is it an area, spot, or radial network?
- Substation (or transmission) nominal distribution voltage
- Nominal distribution circuit voltage at site
- Distance between site and substation
- Load profile (8760 hours)
- peak and minimum load data of line sections
- Limiting conductor rating

- Number and rating of protective devices and voltage regulating devices between the site and substation
- Availability of three-phase power and/or distance from three-phase service
- Existing or known constraints (e.g., electrical dependencies, short circuit interrupting capacity issues, power quality or stability issues, capacity constraints, or secondary networks
- Any other information relevant to the applicant



What sorts of questions do these reports help answer?

- Developers What are my project's risks for requiring major grid upgrades before submitting into the queue?
 - Is there a circuit nearby my proposed site?
 - How many projects are already interconnected or in the queue on the circuit or substation ahead of my project?
- Utilities How can we optimize the engineering resources we spend on evaluating queued projects?
- Regulators How can we increase project retention rates throughout the interconnection process?



Overview

Website with downloadable data sets and reports about distribution grid conditions and constraints

Typically includes:

- load profiles
- distribution system asset information
- distribution system planning assumptions
 & studies
- other relevant data



Example from National Grid





Example load profile obtained from a system data portal





What sorts of questions do data portals help answer?

Developers – Are there any additional identifiable constraints that could increase my project's risk of requiring expensive upgrades?

- What are the load conditions of the circuit and substation?
- Can I design my system to avoid exceeding any implied constraints?
- Can energy storage provide the operational flexibility needed to avoid exceeding certain thresholds?
- **Utilities** Can we reduce our resources spent studying projects attempting to connect to already severely constrained systems?
 - How can we fairly inform applicants of grid sections to avoid?
- **Regulators** How widespread are major grid constraints and would proactive planning efforts help to avoid bottlenecks?



Overview

 Regularly published queue reports detailing the status of all projects within the interconnection queue



- Can provide additional details such as:
 - Time within each stage of the review process
 - Interconnection costs assigned after evaluation
- Requires both a high-frequency update schedule and robust validation process to be useful



Example spreadsheet from New York Utility

								1					1	I	APPLICATI	ON REVIEW		PREL	JMINARY REV	IEW
											Met	ering			10 busin	ess days		15	business day	
C o m p Developer a n v	Application / Job #	Division	City/Town	County	Zip Code	NYISO Load Zone	Circuit ID	Substation	PV (kWAC)	ESS (kWAC)	Metering (NA / NM / RNM / CDG)	Value Stack (Y/N)	Protective Equipment	Start Date	End Date	Calculated Duration	Application Approved Date (Utility)	Start Date (Must Match Application Approved Date)	End Date	Calcul Dura
CE CE	Service Se	CELERIS	Bathlati	Site Alartin	29934	1	19W06	Grasslands	0.00	5000.00	CDG	Y	Inverter	3/2/23	3/8/23	4	3/8/23	3/8/23	3/15/23	
CE ST THE R. LEWIS	125-5912	2011 W	20.5.252	NorthAr	2.39	н	13W75	Buchanan	0.00	5000.00	CDG	Y	Inverter	3/2/23	3/8/23	4	3/8/23	3/8/23	3/16/23	
CE IN TAIL OF A	000-0605	10000-00	Stiristic	36台(18.49)	1002	1	7M31	Avenue_A	99.40	0.00	NM	N	Inverter	2/24/23	3/2/23	4	3/2/23	3/2/23	3/10/23	
CE CE	MONPORT.	2000/352	talil, kok	80-01d	- 6690°	4	1M17	Sherman_Creek	120.80	0.00	NM	N	Inverter	2/21/23	2/24/23	3	2/24/23	2/24/23	3/10/23	
CE make he is a	18420638GA	20年間	\$4670	36,00	10012	1	6852	Water_St	99.40	0.00	NM	N	Inverter	2/21/23	2/24/23	3	2/26/23	2/26/23	3/1/23	
CE JA BIOSINAGANIS.	Could Report	\$24×3	WhiteLastle	10,000	10.57		1205	Corona_1	724.50	0.00	CDG	Y	Inverter	2/20/23	2/23/23	2	2/23/23	2/23/23	3/1/23	
CE interdet.it-	SINGSPIEC	CERTIFIC	Carefolded (Side and	2005	2	12W92	Elmsford_No.2	0.00	1958.40	RC	Y	Inverter	2/17/23	2/25/23	4	2/25/23	2/25/23	3/9/23	
CE CHARGE HILL WE AVE.	107.45%	CEIIPH	Novalah	Particul Council of	1000	1	17W40	Harrison	0.00	4895.00	RC	Y	Inverter	2/17/23	2/22/23	2	2/28/23	2/28/23	3/13/23	
CE C	100 100	CE 🖌	Jack Offens	Sa New Sil	- 22.H	5	6981	Jamaica	0.00	5000.00	CDG	Y	Inverter	2/16/23	2/23/23	4	2/23/23	2/23/23	3/2/23	
CE C	Citize and a	10.3-36	わじめ	154	0.055	i i	3B86	Brownsville_1	12.00	4896.00	RC	Y	Inverter	2/15/23	2/24/23	6	2/24/23	2/24/23	2/24/23	
CE ITE million form	143-04286	610h/W	Mapping 199	200 C	1762		3B86	Brownsville_1	12.00	4896.00	RC	Y	Inverter	2/15/23	2/24/23	6	2/24/23	2/24/23	2/24/23	
CE CE	1204-04620	2204,622	(14) (c) (c)	17:52	0.097	5	3B86	Brownsville_1	12.00	4896.00	RC	Y	Inverter	2/15/23	2/24/23	6	2/24/23	2/24/23	2/24/23	
CE CE	12.04.07	1.899463	Déhalépkai	diam'n a state	1505	4	214	FRESH_KILLS	12.00	3916.80	RC	Y	Inverter	2/14/23	2/21/23	4	2/21/23	2/21/23	3/1/23	
CE THE MERITY OF	达的管理 的	IDW-X	Link/Links	Witchisal	10075		1R81	FRESH_KILLS	12.00	4896.00	RC	Y	Inverter	2/14/23	2/21/23	4	2/21/23	2/21/23	3/1/23	
CE THE PROPERTY OF	20年4月1日	CEINIAM	Kine MeX	1545.04	1022	5	33R37	FRESH_KILLS	12.00	4896.00	RC	Y	Inverter	2/14/23	2/21/23	4	2/21/23	2/21/23	3/1/23	
CE Part of American	675.39853	CEllerini	Detunit-Red	fill all the second	1914	5	33R37	FRESH_KILLS	12.00	4896.00	RC	Y	Inverter	2/14/23	2/21/23	4	2/21/23	2/21/23	3/1/23	
CE C	distantiation -	CEIM	Defensionid	talk form	1004	4	33R37	FRESH_KILLS	12.00	4896.00	RC	Y	Inverter	2/14/23	2/21/23	4	2/21/23	2/21/23	3/1/23	
CE INCLUSION AND AND AND AND AND AND AND AND AND AN	Mark Avenue	(EMR+16	25 and 16 and	新学校 (1997)	2,005	ă.	5R28	Woodrow	12.00	4896.00	RC	Y	Inverter	2/12/23	2/16/23	3	2/16/23	2/16/23	2/23/23	
CE STATE OF MALL	108 32680	108124	Section 44	Mail regard	10526	í.	5R28	Woodrow	12.00	4896.00	RC	Y	Inverter	2/12/23	2/16/23	3	2/16/23	2/16/23	2/23/23	
CE Mark P Intel 1	12010022-7	2010	Ethis fabric	(FLAD) (H)	0.80	6	5R28	Woodrow	12.00	4896.00	RC	Y	Inverter	2/12/23	2/16/23	3	2/16/23	2/16/23	2/23/23	
CE Indials into	2022/08-	2000 g	training (xd	Children (Children (Childr	5685	٥	6Q44	Glendale	240.00	0.00	CDG	Y	Inverter	2/10/23	2/13/23	1	2/18/23	2/18/23	2/21/23	
CE In the second se	LONG PROFESSION	384 B	14Par	(Stell)	25.00	8	4X48	Mott_Haven	12.00	4896.00	RC	Y	Inverter	2/10/23	2/13/23	1	2/17/23	2/17/23	3/2/23	
CE THE REPORT	386626383	CERTS	100x21	10.90	1000	a	4X48	Mott_Haven	12.00	4896.00	RC	Y	Inverter	2/10/23	2/13/23	1	2/17/23	2/17/23	3/2/23	
CE The Territory of C	Market Market	CE E	Seal-	Migori,	10.25	н	4X48	Mott_Haven	12.00	4896.00	RC	Y	Inverter	2/10/23	2/13/23	1	2/17/23	2/17/23	3/1/23	
CE INTERACIÓN CON	1207203280	CEARINE	194 aut	Sept.16	50475	6	4X48	Mott_Haven	12.00	4896.00	RC	Y	Inverter	2/10/23	2/13/23	1	2/17/23	2/17/23	3/1/23	
CE 1-10 Tent Ten City 115	20022	1007-014	tractions.	2010	2532	8	9B20	Brownsville_2	603.00	0.00	CDG	Y	Inverter	2/10/23	2/13/23	1	2/15/23	2/15/23	3/2/23	
CE I THE REPORT OF	157-5786	19.85185	IGAG.	2654th	10258	9	7X84	Parkchester_1	0.00	5000.00	CDG	Y	Inverter	2/10/23	2/16/23	4	2/16/23	2/16/23	2/28/23	
CE ANALY IN	120170613	256.4	(Bhrps) (and	No.971	17885		6882	Jamaica	225.00	0.00	CDG	Y	Inverter	2/10/23	2/13/23	1	2/13/23	2/13/23	2/27/23	
CE MARTINE AL MARTINE	2019918	196.45	(Rida)	399th	10452	2	7891	Parkchester_1	724.50	0.00	CDG	Y	Inverter	2/9/23	2/15/23	4	2/15/23	2/15/23	3/2/23	
CE CE	ALC: NOT	SIM W	Page 1	1/1/	2025	3	9B20	Brownsville_2	724.50	0.00	CDG	Y	Inverter	2/9/23	2/15/23	4	2/15/23	2/15/23	3/2/23	
CE	Automation of the	CE MIL MIL	Washs .	85.6	36385	2	9B12	Brownsville_2	724.50	0.00	CDG	Y	Inverter	2/9/23	2/14/23	3	2/14/23	2/14/23	3/1/23	
CE International and	454 6-535	CEMP W	In the	Star .	70.04	2	9B20	Brownsville_2	724.50	0.00	CDG	Y	Inverter	2/9/23	2/16/23	5	2/16/23	2/16/23	3/3/23	
CE CE	1000000	CENIA-[]+	Seffmen stoud	ilige spielter	LOGAR.	6	7Q84	Corona_1	724.50	0.00	CDG	Y	Inverter	2/9/23	2/13/23	2	2/13/23	2/13/23	2/27/23	
CE International data and the	1000	1000-2	4 Marine	(Sec.)	10.21	8	7Q84	Corona_1	483.00	0.00	CDG	Y	Inverter	2/9/23	2/13/23	2	2/13/23	2/13/23	2/27/23	
CE	10.015/10	101111-01	(Autor	Mary .	All factors	4	2X28	Bruckner	724.50	0.00	CDG	Y	Inverter	2/9/23	2/15/23	4	2/15/23	2/15/23	3/2/23	
CE Information of the second second	10.000	675.26	(Rush)	(4) (4)	1280		2X28	Bruckner	724.50	0.00	CDG	Y	Inverter	2/9/23	2/15/23	4	2/15/23	2/15/23	3/2/23	
CE CE	IN-APROX	6999.46	1000	63Mrd	2018	4	6Q84	Glendale	12.00	4896.00	RC	Y	Inverter	2/9/23	2/14/23	3	2/14/23	2/14/23	2/21/23	
CE	0.00 million (1996)	100.00	IN MARK	1/14	6.0%	1	1895	Plymouth_St	724.50	0.00	CDG	Y	Inverter	2/8/23	2/9/23	1	2/24/23	2/24/23	2/24/23	
CE	Long-pricely	CETT C	Page	'//www.	1,533	6	9B02	Brownsville_2	166.50	0.00	NM	N	Inverter	2/8/23	2/12/23	2	2/12/23	2/12/23	2/15/23	
CE NineDot Energy, LLC	LDG-04042	CENY-BK	Brooklyn	Kings	11203	J	7808	Bensonhurst 2	12.00	4896.00	RC	Y	Inverter	2/7/23	2/10/23	3	2/10/23	2/10/23	2/15/23	



Simplified queue reporting spreadsheet

Project Details	Circuit & Substation	Data of Submittal	Current Step in The Process	Study & App. Costs	Upgrade Costs
Project A – 10 kW	Cir. 18-223 Hawking Sub.	1/20/2023	Complete - PTO	\$300	\$0.00
Project B – 500 kW	Cir. 55-323 Curie Sub.	1/21/2023	Facility Study	\$5,000	\$15,000
Project C – 5 kW	Cir. 55-323 Curie Sub.	3/2/2023	Complete - PTO	\$300	\$0.00
Project D – 3 MW	Cir. 18-223 Hawking Sub.	3/2/2023	Withdrawn	\$25,000	\$4,215,000
Project E – 100 kW	Cir. 18-223 Hawking Sub.	6/15/2023	Application Review	\$5,000	N/A



What sorts of questions do queue reports help answer?

Developers – How many projects are queued before mine and do they tell me anything about the costs that my project may incur?

- Have any of these projects triggered expensive upgrades?
- Could these upgrades be required for my project if they withdrew?
- Utilities Where can queue processing improvements be made or other prospecting tools be improved to better direct projects?

Regulators – Is the interconnection process working as intended and are rule revisions needed to improve it?

- Are utilities fulfilling their processing timeline obligations?
- What is the average process duration of 10-500 kW projects?
- What are the average upgrade costs for 2+ MW projects?



Basic Distribution System Maps

Overview

Map of distribution system assets and feeder lines

Typically includes popup boxes that display grid data





Basic Distribution System Maps

Examples of Requested Data

Substation Data

- Name or identification number
- Voltages
- Substation transformers nameplate rating
- Existing Generation (weekly refresh rate)
- Queued Generation (weekly refresh rate)
- Total Generation (weekly refresh rate)
- 8760 Load profile by substation and transformer
- Percentage of residential, commercial, industrial customers
- Currently scheduled upgrades
- Has protection and/or regulation been upgraded for reverse flow (yes/no)
- Number of substation transformers and whether a bus-tie exists
- Notes (include any other relevant information to help guide interconnection applicants, including electrical restrictions, known constraints, etc.)

Feeder Data

- Name or identification number
- Which substation the feeder connects to
- Feeder voltage
- Number of phases
- Which substation transformer the feeder connects to
- Feeder type: radial, network, spot, mesh etc.
- Feeder length
- Feeder conductor size and impedance
- Service Transformer rating
- Service Transformer daytime minimum load
- Existing Generation (weekly refresh rate)
- Queued Generation (weekly refresh rate)
- Total Generation (weekly refresh rate)
- 8760 Load profile
- Percentage of residential, commercial, industrial customers
- Currently scheduled upgrades
- Federal or state jurisdiction
- Known transmission constraint requires study
- Notes (other relevant information to help guide interconnection applicants)



Basic Distribution System Maps

What sorts of questions do these maps help answer?

Developers – Where else can I site my project to avoid high upgrade costs caused by major grid constraints?

- How far is my project from the substation?
- What other circuits are in the area that may be more suitable for interconnection?
- Can I find land nearby that would be better for interconnection?
- Utilities Can we inform applicants where exactly they should avoid submitting projects after determining constraints through studies?
- Regulators Can we better monitor interconnection rules or understand distribution planning needs with infrastructure maps?



Overview

A hosting capacity analysis (HCA) is a grid transparency tool that provides an assessment of the ability of a distribution grid to host additional distributed energy resources (DERs) at specific locations, without the need for costly upgrades or lengthy interconnection studies.

For more information, visit our hosting capacity webpage at...

https://irecusa.org/our-work/hosting-capacity-analysis/



Example from Southern California Edison





Example of early siting flexibility enabled by HCA





Source: Portland General Electric Distributed Generation Evaluation Map

Siting flexibility enabled with HCA from Portland General Electric

	_	13	DAYTON-EAST	
G Capacity In Oueue (MW)	0.00	10 51	Substation Name	DAYTON
eneration Limited (Y/N)	N	S DIM	Feeder Name	DAYTON- EAST
			Feeder Voltage (kV)	13.00
eder DG Ready (Y/N)	Y	2.	SCADA (Y/N)	Υ
ubstation Transformer DG	Y		Feeder Peak Load (MVA)	7.50
eadv (Y/N)		721	Net Daytime Minimum Load (MW)	2.70
		C 233	DG Capacity Connected (MW)	1.00
eder allowing baci	k-feeding		DG Capacity In Queue (MW)	1.80
nd no queued ger	eration		Generation Limited (Y/N)	N
na no queueu gen		Plea	Feeder DG Ready (Y/N)	N
		154	Substation Transformer DG Ready (Y/N) Zoom to	N



Source: Portland General Electric Distributed Generation Evaluation Map

Siting flexibility enabled with HCA from Portland General Electric

		and the second second	
	ACCREMENT OF LOT	and the second s	
DG Capacity In Queue (MW)	0.00	DG Capacity Connected (MW)	1.00
Generation Limited (Y/N)	N	DG Capacity In Queue (MW)	1.80
Feeder DG Ready (Y/N)	Y	Generation Limited (Y/N)	N
Substation Transformer DG	Y	Feeder DG Ready (Y/N)	N
Ready (Y/N)		Substation Transformer DG Ready (Y/N)	Ν

and no queued generation

Feeder **not** allowing backfeeding and has a large queue

OIREC

Source: Portland General Electric Distributed Generation Evaluation Map

What sorts of questions do HCA maps help answer?

Developers: What grid locations have the capacity for my project thus likely do not require long studies or major grid upgrades?

Utilities: What kinds of grid constraints are limiting hosting capacity?

- Are there system-wide constraints to future electrification or DER policies?
- Can we proactively address these insufficiencies with upgrades through our distribution planning process?

Regulators: Does the grid in our state have sufficient capacity to support our renewable energy adoption or electrification goals?



IREC Report: Key Decisions for Hosting Capacity Analysis

Outlines the key decisions that need to be made to adopt a grid mapping tool that can help utilities and states better integrate clean energy technologies on the electric grid—based on IREC's hosting capacity work around the nation

Download at: <u>https://irecusa.org/resources/key-</u> decisions-for-hosting-capacity-analyses/





Prospecting Tool Considerations



Comparing Prospecting Tools

Key considerations when developing or regulating for prospecting tools

ΤοοΙ	Availability Today	Customer Cost	Utility Effort	Ease of Access	
Pre-Application Reports	Widely available	Fee	Respond to requests	Request for each site	
Distribution System Data Portals	Numerous states	None	Develop datasets & post to website	System-wide datasets available for download	
Public Queue Reporting	Numerous states	None	Develop & regularly refresh datasets posted to website	System-wide datasets available for download	
Basic Distribution System Maps	Numerous states	None	Integrate datasets with GIS & publish map	Publicly accessible map	
Hosting Capacity Analyses	Several states	None	Extensive effort to analyze data and publish results	Detailed data available via map & data portal	



Enabling Energy Storage Development

Higher resolution prospecting tools and energy storage

- Usefulness depends on data resolution
- More granular data enables better energy storage system design



Left: HCA Map with Blurred Distribution Lines from Xcel Energy's HCA | *Source: Xcel Energy, Minnesota* Right: HCA Map Showing Precise Distribution Line Location | *Source: Pepco, Washington, DC*



Enabling Energy Storage Development

BATRIES: Building a Technically Reliable Interconnection Evolution for Storage

- Easy to integrate that includes recommended model regulatory language
- Builds off of **FERC SGIP**
- Toolkit adoption can help
 increase energy storage
 market penetration by
 preemptively addressing
 interconnection barriers



41

Importance of Data Validation

IREC/NREL Report: Data Validation for Hosting Capacity Analyses



Read the full report at https://bit.ly/HCAValidation

HCA Data Validation requires attention to five key areas:

42

- Business Processes
- Quality Control During the Model Development Process
- Validating Results Before Publication
- Feedback from Customers and Users
- Regulatory Oversight









Recognitional

Have we engaged with all relevant stakeholders?

Are we meeting stakeholders where they are at?

Who has been historically left out of these discussions?

Do communities feel that they have a voice at the table?





Procedural

How accessible are our available engagement methods?

How are we elevating the voices of the marginalized?

How are we lowering proceeding participatory barriers?

Are we monitoring progress toward procedural justice?





How do we ensure these benefits are equally distributed?

What prospecting challenges can we help overcome?

Are the cost and value created equally distributed?



Distributional

Thank You!



If you have any questions, contact:

Radina Valova

Regulatory Vice President | IREC radinav@irecusa.org

Shay Banton

Regulatory Program Engineer & Energy Justice Advocate | IREC <u>shayb@irecusa.org</u> 47

