

Reliability Evaluation of PV Power Plants:

Input Data for Warranty, Bankability and Energy Estimation Models



ARIZONA STATE UNIVERSITY

PHOTOVOLTAIC RELIABILITY LABORATORY

G. TamizhMani (Mani); manit@asu.edu

- Thanks to the hard work of ASU-PRL staff and students!
- Thanks to the SRP-R&D team and Bill Kazeta for the technical support!
- Thanks to SRP and DOE/SERIIUS for the funding support!
- This presentation material is based on two MS theses (available for free downloading at: repository.asu.edu)



ARIZONA STATE UNIVERSITY

Focus of this Presentation

Bankability of solar PV projects involves a 5-step process:



1. Site Assessment (SA)
2. Design Optimization (DO)
3. Component Procurement (CP)
4. Installation & Commissioning (IC)
5. **Operation & Maintenance (O&M)**

Focus of this Presentation

From PV module perspective:

Operation ~ **degradation rate**
Maintenance ~ **Failure rate**



Used to calculate production generation risk

Production generation risk can be calculated if **DEFINED METRICS** for the degradation and failure rates are available. The focus of this presentation is to define the metrics and apply these defined metrics on the field measured data so they **can be used for warranty insurance, bankability and energy estimation calculations.**

Presentation Outline

- Importance to stakeholders
 - Reliability evaluations in the field
- METRIC definitions (from users perspectives)
 - Safety failures, reliability failures and durability/degradation losses
- Application of definitions in field evaluation
 - Quantitative determination of safety failures, reliability failures and degradation rates of aged PV power plants
- Application of the defined metrics on data processing
 - Failure and degradation modes and rates
 - Distribution between safety failures, reliability failures and degradation rates
 - Soiling losses (*see the poster for details*)
- Conclusions


Presentation Outline

- Importance to stakeholders
 - Reliability evaluations in the field
- METRIC definitions (from users perspectives)
 - Safety failures, reliability failures and durability/degradation losses
- Application of definitions in field evaluation
 - Quantitative determination of safety failures, reliability failures and degradation rates of aged PV power plants
- Application of the defined metrics on data processing
 - Failure and degradation modes and rates
 - Distribution between safety failures, reliability failures and degradation rates
 - Soiling losses (*see the poster for details*)
- Conclusions

PV Power Plant Evaluation: O&M

Project Developer Perspective:

To secure low interest loan without risk premium adders. There are three risk premium adders.



*DR = Degradation Rate

Source: ASU Photovoltaic Reliability Laboratory (ASU-PRL)

Goal: Number of modules which will have safety and reliability risks needs to be determined

PV Power Plant Evaluation: Importance to Stakeholders

Repairing or Decommissioning Decision Perspective:

To decommission the power plant when annual kWh generation declines below an acceptable level. The kWh value is dictated by three factors: safety failures over time, reliability failures over time and degradation loss over time.

kWh
is dictated by



- **Safety failures (SF) over time**
(obsolete; qualifies for warranty returns)
- **Durability/Degradation loss (DL) over time**
(better-performance; <1%/year degradation; does not qualify for warranty claims)
- **Reliability failures (RF) over time**
(under-performance; >1%/year degradation; qualifies for warranty claims)


Goal: Number of modules which do not effectively contribute to kWh generation needs to be determined

Presentation Outline

- Importance to stakeholders
 - Reliability evaluations in the field
- METRIC definitions (from users perspectives)
 - Safety failures, reliability failures and durability/degradation losses
- Application of definitions in field evaluation
 - Quantitative determination of safety failures, reliability failures and degradation rates of aged PV power plants
- Application of the defined metrics on data processing
 - Failure and degradation modes and rates
 - Distribution between safety failures, reliability failures and degradation rates
 - Soiling losses (*see the poster for details*)
- Conclusions



ASU-PRL's METRIC Definition of Failures and Degradation



SF = Safety Failure (Qualifies for safety returns)

RF = Reliability Failure (Qualifies for warranty claims)


DL = Durability Loss with or without Cosmetic Defects (Does not qualify for warranty claims)

Presentation Outline

- Importance to stakeholders
 - Reliability evaluations in the field
- METRIC definitions (from users perspectives)
 - Safety failures, reliability failures and durability/degradation losses
- Application of definitions in field evaluation
 - Quantitative determination of safety failures, reliability failures and degradation rates of aged PV power plants
- Application of the defined metrics on data processing
 - Failure and degradation modes and rates
 - Distribution between safety failures, reliability failures and degradation rates
 - Soiling losses (*see the poster for details*)
- Conclusions

Field Evaluation of PV Modules:

Application of ASU-PRL's Definitions on Field Failures and Degradation Determinations




Presentation Outline

- Importance to stakeholders
 - Reliability evaluations in the field
- METRIC definitions (from users perspectives)
 - Safety failures, reliability failures and durability/degradation losses
- Application of definitions in field evaluation
 - Quantitative determination of safety failures, reliability failures and degradation rates of aged PV power plants
- Application of the defined metrics on data processing
 - Failure and degradation modes and rates
 - Distribution between safety failures, reliability failures and degradation rates
 - Soiling losses (*not presented here; see the poster for details*)
- Conclusions


Four PV Plants Evaluated
Hot-Dry Desert Climate

Four PV Power Plants Evaluated *(mono-Si; Glass/Polymer; 6656 modules)*







- **Due to time limitation, only one plant (Model G) data is presented here.**
- **Data for the other three plants is made available in the appendix of this presentation.**

Defects Including Safety Failures (*Model G – Site 3*)



Safety Failures (*Model G – Site 3*)


12 Years – 1-axis Tracker



Mapping of Safety Failures (*Model G – Site 3*)

Framed - 12 Years – 1-axis Tracker

Safety failure rate at the plant level = $162/2352 = 7\%$



Primary failure mode:


Ribbon-ribbon solder bond failure with backskin burning

- Hotspot issues leading to backsheet burn (37/2352)
- Ribbon-ribbon solder bond failure with backsheet burn (86/2352)
- Failed diode with no backsheet burn (26/2352)
- Hotspot issues with backsheet burn + Ribbon-ribbon solder bond with backsheet burn (1/2352)
- Backsheet Delamination (10/2352)
- Backsheet Delamination + Ribbon-ribbon solder bond failure (2/2352)

Distribution of Reliability Failures and Degradation Losses (*Model G – Site 3*)

12 Years – 1-axis Tracker

Histogram of Degradation of Power (%/year) of Model-G Modules
Normal



Total number of modules = 285 (safety failed modules excluded)

Mean degradation = 0.95%/year

Median degradation = 0.96%/year


Distribution of Reliability Failures and Degradation Losses (*Model G – Site 3*)

12 Years – 1-axis Tracker

Reliability Failures and Durability Loss

(Based on I-V of 285 modules)

(Safety failed modules excluded)




Distribution of Safety Failures, Reliability Failures and Degradation Losses (*Model G – Site 3*)

12 Years – 1-axis Tracker (combination of previous two slides)

Safety Failures, Reliability Failures and Durability Loss for the Power Plant

(SF based on entire power plant; RF and DL based on I-V of 285 modules)




Best Modules Experienced Only Durability Issues (*Model G – Site 3*)

1-axis Tracker

Field Age = 12 years
(Model-G)

Best, Median, Worst Strings- Best Modules (6 Strings; 18 Modules)



B = Best string; M = Median string; W = Worst string

Primary degradation mode:
Solder bond degradation

Pmax loss → FF loss → Rs increase


BEST modules = 18 (safety failed modules excluded)

Mean degradation = 0.5%/year

Median degradation = 0.5%/year

} Due to only intrinsic (materials) issues
contributing to real wear out mechanisms

Worst Modules Experienced Both Reliability and Durability Issues (*Model G – Site 3*)



Primary failure mode:


Ribbon-ribbon solder bond failure with backskin burning

WORST modules = 18 (safety failed modules included)

Mean degradation = 1.8-5.6%/year
Median degradation = 1.4-4%/year

Due to both intrinsic (materials) and extrinsic (design/manufacturing) issues

Hotspot modules degrade at higher rates (>3 times) (*Model G – Site 3*)



Summary: Model G (Site 3) – 1-axis Tracker – 12 years

- Average degradation rate = 0.5%/year for the BEST modules and 0.95%/year for ALL the modules (excluding the safety failed modules). On an average, the modules meet the typical 20/20 warranty expectations.
- Primary safety failure mode is the ribbon-ribbon solder bond failures/cracks leading to backskin burning.
- Primary degradation mode and reliability failure mode may potentially be attributed to thermo-mechanical solder bond fatigue (cell-ribbon and ribbon-ribbon) leading to series resistance increase.
- Average soiling loss of 1-axis tracker based Model G modules is 6.9%
- 7% of the modules qualify for the safety returns under the typical 20/20 warranty terms
- 42% of the modules qualify for the warranty claims under the typical 20/20 power warranty terms
- 51% of the modules are meeting the typical 20/20 power warranty terms

Presentation Outline

- Importance to stakeholders
 - Reliability evaluations in the field
- METRIC definitions (from users perspectives)
 - Safety failures, reliability failures and durability/degradation losses
- Application of definitions in field evaluation
 - Quantitative determination of safety failures, reliability failures and degradation rates of aged PV power plants
- Application of the defined metrics on data processing
 - Failure and degradation modes and rates
 - Distribution between safety failures, reliability failures and degradation rates
 - Soiling losses (*not presented here; see the poster for details*)
- Conclusions

Conclusion

(Hot-Dry Desert Climate)

- Primary degradation/failure modes & Degradation rates of the four power plants presented in this work
- Linking degradation and failure metric definitions with risk premium rate calculation

Primary degradation/failure modes & Degradation rates of the four power plants presented in this work

Average degradation rate - BEST modules:

- 0.41%/year (Model G; 12 years; 1-axis)
- 0.50%/year (Model H; 4 years; 1-axis)
- 0.85%/year (Models BRO1 & BRO2; 16 years; 1-axis and horizontal)

Average degradation rate - ALL modules:

- 0.95%/year (Model G; 1-axis)
- 1.00%/year (Model H)
- 1.1%/year (Models BRO1 & BRO2)

Primary safety failure modes:

- **Backsheet delamination** (frameless modules; Models BRO1 & BRO2, and Model G)
- **Backsheet burning** (only Model G) and none (Model H)

Primary degradation mode and reliability failure modes:

- Encapsulant **browning** leading to transmittance/current loss (only Models BRO1 & BRO2)
- Thermo-mechanical **solder bond fatigue** leading to series resistance increase (all models: G, BRO1, BRO2 & H).


Linking Failure and Durability Definitions with Risk Premium Rate Calculation

A Conceptual Representation

12 Years – 1-axis Tracker

Safety Failures, Reliability Failures and Durability Loss
for the Power Plant

(SF based on entire power plant; RF and DL based on I-V of 285 modules)



Interest Rate


=

Interest Rate @ Zero Risk

+

Risk Premium Rate

Histogram of Degradation of Power (%/year) of Model-G Modules
Normal



A wide-angle photograph of the Grand Canyon, showing the Colorado River winding through the deep, layered rock formations. The sky is blue with scattered white clouds. The text "Thank You!" is centered over the river.

Thank You!



ARIZONA STATE UNIVERSITY

PHOTOVOLTAIC RELIABILITY LABORATORY

G. TamizhMani (Mani); manit@asu.edu

Appendix

Model H

(Site 4C)


Mapping of Safety Failures (*Model H – Site 4C*) Framed - 4 Years – 1-axis Tracker



Distribution of Reliability Failures and Degradation Losses (*Model H – Site 4C*)

4 Years – 1-axis Tracker

Histogram of Degradation of Power (%/year) of Model-H Modules
Normal



Total number of modules = 94 (safety failed modules excluded)


Mean degradation = 0.96%/year

Median degradation = 1.00%/year

Degradation Distribution of Best Modules (*Model H – Site 4C*)

4 Years – 1-axis Tracker

**Histogram of Degradation of Power (%/year) of Model-H
30 Best Modules
Normal**



Total number of BEST modules = 30 (safety failed modules excluded)


Mean degradation = 0.41%/year

Median degradation = 0.41%/year

Distribution of Reliability Failures and Degradation Losses (*Model H – Site 4C*)


4 Years – 1-axis Tracker

Reliability Failures and Durability Loss (Model-H)
(Based on I-V of 94 modules)



Distribution of Safety Failures, Reliability Failures and Degradation Losses (*Model H – Site 4C*)

12 Years – 1-axis Tracker



Summary: Model H (Site 4C) – 1-axis Tracker

- Average degradation rate = 0.41%/year for the BEST modules and 1.00%/year for ALL the modules (excluding the safety failed modules). On an average, the modules meet the typical 20/20 warranty expectations.
- Practically, no safety failures have been detected.
- Primary degradation mode and reliability failure mode may potentially be attributed to thermo-mechanical solder bond fatigue (cell-ribbon and ribbon-ribbon) leading to series resistance increase.
- Average soiling loss of 1-axis tracker based model H modules is 5.5%
- 0% of the modules qualify for the safety returns under the typical 20/20 warranty terms
- 50% of the modules qualify for the warranty claims under the typical 20/20 power warranty terms
- 50% of the modules are meeting the typical 20/20 power warranty terms


Model BRO1 & BRO2

(Site 4A & 4B)

Defects Including Safety Failures (*Model BRO1 – Site 3*)


Plant level defect count on all BRO 1 modules

Total Modules = 1512



Defects Including Safety Failures (*Model BRO2 – Site 3*)


Plant level defect count on all modules BRO2 Modules
Total Modules = 1512





Safety Failures and Reliability Failures (*Models BRO1 & BRO2– Site 4A & 4B*)

16 Years (7 years – 1-axis; 9 years – horizontal tilt)

Safety Issues



Durability and Reliability Issues




Mapping of Safety Failures (*Models BRO1 & BRO2 – Site 4A & 4B*)




BRO1: Safety failure rate at the plant level = $8/1512 = 0.5\%$

Framed - 16 Years

(7 years 1- axis; 9 years horizontal)




BRO2: Safety failure rate at the plant level = 26/1512 = 1.7%



Distribution of Reliability Failures and Degradation Losses (*Model BRO1 – Site 4A*)

16 Years – 1-axis tracker for first 7 years and horizontal tilt for 9 years

Histogram of Degradation of Power (%/Year) For BRO-1 Modules
Normal




Total number of modules = 244 (safety failed modules excluded)

Mean degradation = 1.1%/year

Median degradation = 1.1%/year

Distribution of Reliability Failures and Degradation Losses (*Model BRO2 – Site 4B*)

16 Years – 1-axis tracker for first 7 years and horizontal tilt for 9 years





Total number of modules = 289 (safety failed modules excluded)

Mean degradation = 1.1%/year

Median degradation = 1.1%/year

Degradation Distribution of Best Modules (*Models BRO1 & BRO2 – Site 4A & 4B*)

16 Years – 1-axis Tracker for 7 years and horizontal tilt for 9 years



Total number of BEST modules = 20 (safety failed modules excluded)

Mean degradation = 0.8-0.9%/year

Median degradation = 0.8-0.9%/year

Distribution of Reliability Failures and Degradation Losses (*Model BRO1 – Site 4A*)

16 Years – 1-axis Tracker for 7 years and horizontal tilt for 9 years

Safety Failure, Reliability Failure, Durability Loss
(1512 modules) BRO 1

Durability Loss

23.8%

(<1%dr/year)

Safety Failure


0.5%

Reliability
Failure 75.6%
(>1%dr/year)

■ Durability Loss

■ Reliability Failure


■ Safety Failure




Distribution of Reliability Failures and Degradation Losses (*Model BRO1 – Site 4A*)

16 Years – 1-axis Tracker for 7 years and horizontal tilt for 9 years

**Safety Failure, Reliability Failure, Durability Loss
(1512 modules) BRO 2**



Best Modules Experienced Only Durability Issues (*Model BRO1*)



Pmax loss → Isc loss (encapsulant browning) & FF loss (solder bond degradation)

BEST modules = 9 (safety failed modules excluded)

Mean degradation = 0.85%/year

Summary: Models BRO1 & BRO2 (Sites 4A and 4B) – 16 years (7 years on 1-axis tracker and 9 years horizontal tilt)

- Average degradation rate = 0.85%/year for the BEST modules and 1.1%/year for ALL the modules (excluding the safety failed modules). On an average, the modules do **not** meet the typical 20/20 warranty expectations (due to two degradation modes: solder bonds and browning).
- Primary safety failure mode is the backsheet delamination though it is small (less than 1.7%)
- Primary degradation mode and reliability failure mode may potentially be attributed to encapsulant browning leading to transmittance/current loss and thermo-mechanical solder bond fatigue (cell-ribbon and ribbon-ribbon) leading to series resistance increase.
- Average soiling loss of horizontal tilt based modules is 11.1% (nearly double vs. 1-axis)
- 0.5-1.7% of the modules qualify for the safety returns under the typical 20/20 warranty terms
- 73-76% of the modules qualify for the warranty claims under the typical 20/20 power warranty terms
- 24-26% of the modules are meeting the typical 20/20 power warranty terms

Overall Conclusions

(for all four power plants)

Overall Conclusions for All the Modules – Hot Dry Desert Climates

- Metric definitions for safety failures, reliability failures and degradation rates are provided
- Metric definitions were applied on the power plant evaluations
- Metric results obtained in this work can be used to perform bankability calculations
- Degradation rate - BEST modules: Average Degradation = 0.41%/year (Model G; 12 years; 1-axis), 0.50%/year (Model H; 4 years; 1-axis) and 0.85%/year (Models BRO1 & BRO2; 16 years; 1-axis and horizontal)
- Degradation rate - ALL modules: Average Degradation = 0.95%/year (Model G), 1.00%/year (Model H) and 1.1%/year (Models BRO1 & BRO2)
- Safety failure modes: Primary modes are backsheet delamination (frameless modules; Models BRO1 & BRO2, and Model G), backsheet burning (only Model G) and none (Model H)
- Degradation mode and reliability failure modes: Primary modes are encapsulant browning leading to transmittance/current loss (only Models BRO1 & BRO2) and thermo-mechanical solder bond fatigue leading to series resistance increase (all models: G, BRO1, BRO2 & H).
- Soiling loss: Average soiling loss is 5.5% (Model H; 1-axis; urban surrounding), 6.9% (Model G; 1-axis; rural surrounding) and 11.1% (Models BRO1 & BRO2; horizontal; urban surrounding)