

Economics of Solar with Storage for Municipal Sites in the City of San Diego

Emma Elgqvist & Linda Parkhill, NREL
November 2019

NREL/PR-6A20-75270

Disclaimer

- This work was authored by the National Renewable Energy Laboratory, operated by Alliance for Sustainable Energy, LLC, for the U.S. Department of Energy (DOE) under Contract No. DE-AC36-08GO28308. Funding provided by the U.S. Department of Energy Office of Energy Efficiency and Renewable Energy Solar Energy Technologies Office. The views expressed in the article do not necessarily represent the views of the DOE or the U.S. Government. The U.S. Government retains and the publisher, by accepting the article for publication, acknowledges that the U.S. Government retains a nonexclusive, paid-up, irrevocable, worldwide license to publish or reproduce the published form of this work, or allow others to do so, for U.S. Government purposes.
- This analysis relies on site information provided to NREL by the San Diego SEIN team that has not been independently validated by NREL.
- The analysis results are not intended to be the sole basis of investment, policy, or regulatory decisions.
- This analysis was conducted using the NREL REopt Model (<http://www.reopt.nrel.gov>). REopt is a techno-economic decision support model that identifies the cost-optimal set of energy technologies and dispatch strategy to meet site energy requirements at minimum lifecycle cost, based on physical characteristics of the site and assumptions about energy technology costs and electricity and fuel prices.
- The data, results, conclusions, and interpretations presented in this document have not been reviewed by technical experts outside NREL or the City of San Diego.
- This analysis was an initial screening and was conducted for limited use to inform further analyses.

Background

- This analysis was conducted under the first round of the [Solar Energy Innovation Network](#) (SEIN); a program led by the [National Renewable Energy Laboratory](#) (NREL). The program assembles diverse teams of stakeholders to research solutions to real-world challenges associated with solar energy adoption.
- This analysis supported the efforts of the [San Diego SEIN team](#), which consists of the City of San Diego and the Clean Coalition.
- The City of San Diego aims to deploy solar and storage to support energy resiliency, environmental quality, and affordability of the electricity supply. The team has estimated the total potential for solar deployment across the city, designed a program proposal for utilizing the total solar potential, completed detailed economic analysis of solar options on municipal facilities, conducted stakeholder workshops to explore solar compensation options, and is exploring opportunities for solar-plus-storage to improve resiliency at critical facilities.
- This analysis supports the team's work by analyzing the techno-economic potential of solar photovoltaics (PV) and lithium-ion battery energy storage at municipal sites in the City of San Diego.

Solar Energy Innovation Network: <https://www.nrel.gov/solar/solar-energy-innovation-network.html>

Orlando: Renewable and Resilient: https://www.nrel.gov/solar/solar-energy-innovation-network-round-1.html#paneld10e186_1


Analysis Overview

- As part of the [Solar Energy Innovation Network](#), NREL is using a tool called [REopt](#) to evaluate the techno-economic potential of PV and storage at 10 municipal sites in the City of San Diego. In two cases, the loads from two buildings were combined into one site.
- This analysis considered the 15-minute electric load and complex utility rate structure of each site to recommend the size of PV and storage to minimize the cost of utility electric purchases to the site.
- This screening should be treated as an initial step to prioritize and focus additional, in-depth analysis of potential renewable energy projects.

REopt Model Overview

Formulated as a mixed-integer linear program, the REopt model optimizes the integration and operation of behind-the-meter energy assets.

REopt solves a deterministic optimization problem to determine the optimal selection, sizing, and dispatch strategy of technologies chosen from a candidate pool such that loads are met at every time step at the minimum lifecycle cost.



Overview of inputs and outputs of the REopt model

Sites Evaluated


| | Facility Name | Address | SDGE Meter Number | SDGE Account Number | Total (kWh) | Average (kW) | Max (kW) |
|----|---|-------------------------|-------------------|---------------------|-------------|--------------|----------|
| 1 | ROSE CANYON OPERATIONS STATION | 3775 Morena Blvd | 06696354 | 3980273955 | 358,004 | 41 | 106 |
| 2 | MIRAMAR OPERATIONS | 8323 Miramar Place | 06693419 | 2511252914 | 488,552 | 56 | 147 |
| 3 | COMMUNICATION BUILDING BLOCKHOUSE | 5851 College Grove Dr | 6692601 | 9177487052 | 1,604,535 | 183 | 397 |
| 4 | ALLIED GARDENS POOL ¹ | 6707 Glenroy St | 06580449 | 3191355640 | 212,037 | 183 | 60 |
| | ALLIED GARDENS RECREATION CENTER ¹ | 5515 Greenbrier Ave | 06561216 | 8816317421 | 102,467 | 12 | 31 |
| | BENJAMIN LIBRARY ¹ | 5188 Zion Ave | 06575657 | 7691323302 | 69,734 | 8 | 34 |
| 5 | NORTH UTC LIBRARY ² | 8820 Judicial Dr | 06686329 | 6171197618 | 169,948 | 19 | 92 |
| | NOBEL RECREATION CENTER ² | 8810 Judicial Dr | 06686327 | 3689127412 | 178,502 | 20 | 89 |
| 6 | CANYONSIDE RECREATION CENTER | 12350 Black Mountain Rd | 06704875 | 8096743607 | 237,030 | 27 | 376 |
| 7 | SOUTHEASTERN POLICE STATION | 7222 Skyline Dr | 06695239 | 2474198502 | 246,768 | 28 | 56 |
| 8 | POLICE GARAGE, NORTHEASTERN | 13396 Salmon River Rd | 06691354 | 3635169400 | 247,746 | 28 | 52 |
| 9 | RIDGEHAVEN COURT | 9601 Ridgehaven | 6697555 | 1341941054 | 934,615 | 107 | 10 |
| 10 | MID CITY POLICE STATION | 4310 Landis St | 6693524 | 6878295700 | 341,402 | 39 | 1 |

¹Loads from these buildings are combined

²Loads from these buildings are combined

Load Data


2017 15-Minute Interval Data



- | | |
|---|--|
| 1. ROSE CANYON OPERATIONS STATION | 2. MIRAMAR OPERATIONS |
| 3. COMMUNICATION BUILDING BLOCKHOUSE | 4. ALLIED GARDENS & REC CENTER, BENJAMIN LIBRARY |
| 5. NORTH UTC LIBRARY & NOBEL REC CENTER | 6. CANYONSIDE REC CENTER |
| 7. SOUTHEASTERN POLICE STATION | 8. POLICE GARAGE, NORTHEASTERN |
| 9. RIDGEHAVEN | 10. MIDCITY PD |

Note: 15-minute data was down-sampled to hourly data for analysis.

Estimate of Roof, Land, and Carport Space Available



- For each of the buildings, NREL used Google Earth to obtain an initial estimate of the total roof, land and carport space available for PV deployment (on left and in appendix).
- These estimates were then refined by the City of San Diego to finalize the inputs to REopt.

| ROSE CANYON OPERATIONS STATION (Estimate based on Google Earth) | Area (ft ²) |
|--|-------------------------|
| Carport | 131,560 |
| Roof Total | 35,200 |
| Ground Total | 161,550 |
| Site Total | 328,310 |

Areas Available for PV (inputs to REopt)

| Facility Name | Carport (ft ²) | Roof (ft ²) | Land (ft ²) | Carport Maximum PV size ¹ (kW) | Roof Maximum PV size ¹ (kW) | Land Maximum PV size ² (kW) | Total (kW) |
|---|-------------------------------|----------------------------|----------------------------|--|---|---|---------------|
| 1 ROSE CANYON OPERATIONS STATION | 26,700 | 0 | 0 | 267 | 0 | 0 | 267 |
| 2 MIRAMAR OPERATIONS | 33,800 | 44,000 | 0 | 338 | 440 | 0 | 778 |
| 3 COMMUNICATION BUILDING BLOCKHOUSE | 0 | 0 | 274,200 | 0 | 0 | 1,371 | 1,371 |
| 4 ALLIED GARDENS & REC CENTER, BENJAMIN LIBRARY | 28,700 | 0 | 0 | 287 | 0 | 0 | 287 |
| 5 NORTH UTC LIBRARY & NOBEL REC CENTER | 40,900 | 0 | 0 | 409 | 0 | 0 | 409 |
| 6 CANYONSIDE REC CENTER | 68,800 | 0 | 0 | 688 | 0 | 0 | 688 |
| 7 SOUTHEASTERN POLICE STATION | 17,000 | 0 | 0 | 170 | 0 | 0 | 170 |
| 8 POLICE GARAGE, NORTHEASTERN | 14,600 | 0 | 0 | 146 | 0 | 0 | 146 |
| 9 RIDGEHAVEN | 15,300 | 6,300 | 0 | 153 | 63 | 0 | 216 |
| 10 MIDCITY PD | 13,320 | 0 | 0 | 133 | 0 | 0 | 133 |

Notes:

¹Assumes use of PV panels with a capacity of 10 watts per square foot

²Assumes use of PV panels with a capacity of 5 watts per square foot

Electricity Rate

All buildings are billed under San Diego Gas & Electric Company (SDG&E) Schedule AL-TOU General Service Time Metered, Secondary Voltage, 0-500 kW.

| | | Summer | Winter | Units | Time |
|--------------------------------------|-----------------------|---------|---------|-------|-------------------------------|
| Energy Charges | on peak | \$0.139 | \$0.116 | /kWh | 4 pm - 9 pm |
| | off peak | \$0.117 | \$0.104 | /kWh | 6 am - 4 pm; 9 pm – 12 am |
| | super off peak | \$0.089 | \$0.090 | /kWh | 12 am – 6 am |
| Peak Demand Charges | | \$27.51 | \$16.61 | /kW | 4 pm - 9 pm |
| Non-Coincident Demand Charges | | \$21.09 | | /kW | Based on highest monthly peak |

Notes:

- Fixed charge of \$139.73/month was not included in analysis because PV and storage will not offset these
- Summer: June-October; Winter: November-May
- Summer Peak Demand Charges include \$16.63/kW transmission charge and \$10.88/kW commodity charge
- The Non-Coincident Demand Charge is based on the higher of the Maximum Monthly Demand or 50% of the Maximum Annual demand
- <http://www2.sdge.com/tariff/com-elec/ALTOUSecondary.pdf> ; https://openei.org/apps/USURDB/rate/view/5a4fc8075457a3db26fc3f67#3_Energy

Analysis Assumptions


| Input | Assumption |
|---------------------------|---|
| Technologies | Solar PV, storage |
| Objective | Minimize lifecycle cost (cost-effective projects) |
| Ownership model | 3 rd party financed |
| Analysis period | 20 years |
| Discount rate | 3% for site/8.1% for developer |
| Escalation rate | 2.60% per EIA utility cost escalation rates |
| Inflation rate | 2% per CBO forecast |
| Incentives | 30% ITC; 5 yr. MACRS for PV. None for battery |
| Net metering | No Net metering |
| Electricity sellback rate | \$0/kWh |
| Interconnection limit | None |
| Technology costs | PV: \$2.00/W (commercial size); \$15.50/kW/yr. O&M Storage: \$500/kWh and \$1000/kW; replacement costs in year 10: \$230/kWh and \$460/kW |
| Technology resource | TMY3 weather file SAN DIEGO LINDBERGH FIELD, CA |
| Area for PV | Estimated, see appendix |

Results

Base Case Cost of Electricity (calculated by REopt)

| Facility Name | Annual Electricity Use (kWh) | Annual Peak (kW) | Annual Energy Charges (\$) | Annual Peak Demand Charges (\$) | Annual Non-Coincident Demand Charges (\$) | Total Annual Energy Costs (\$) | 20-Year Cost of Electricity (\$) |
|---|------------------------------|------------------|----------------------------|---------------------------------|---|--------------------------------|----------------------------------|
| 1 ROSE CANYON OPERATIONS STATION | 358,004 | 100 | \$37,173 | \$17,420 | \$19,753 | \$76,247 | \$1,464,260 |
| 2 MIRAMAR OPERATIONS | 488,552 | 134 | \$53,651 | \$24,992 | \$28,659 | \$105,705 | \$2,029,980 |
| 3 COMMUNICATION BUILDING BLOCKHOUSE | 1,604,540 | 390 | \$171,758 | \$84,530 | \$87,229 | \$341,274 | \$6,553,880 |
| 4 ALLIED GARDENS & REC CENTER, BENJAMIN LIBRARY | 384,237 | 93 | \$37,581 | \$18,816 | \$18,765 | \$78,673 | \$1,510,850 |
| 5 NORTH UTC LIBRARY & NOBEL REC CENTER | 348,450 | 121 | \$52,501 | \$26,221 | \$26,280 | \$90,355 | \$1,735,200 |
| 6 CANYONSIDE REC CENTER | 237,030 | 369 | \$143,121 | \$71,027 | \$72,095 | \$170,213 | \$3,268,800 |
| 7 SOUTHEASTERN POLICE STATION | 246,768 | 52 | \$20,122 | \$9,575 | \$10,547 | \$46,451 | \$892,056 |
| 8 POLICE GARAGE, NORTHEASTERN | 247,746 | 50 | \$20,359 | \$9,596 | \$10,763 | \$46,674 | \$896,331 |
| 9 RIDGEHAVEN | 934,615 | 218 | \$94,629 | \$46,945 | \$47,684 | \$194,510 | \$3,735,400 |
| 10 MIDCITY PD | 341,402 | 72 | \$29,207 | \$13,958 | \$15,249 | \$65,655 | \$1,260,850 |

Cost-Optimal PV and Battery System Sizes (calculated by REopt)




Cost-Optimal System Sizes

(calculated by REopt)

| Facility Name | PV Size (kW) | Battery Size (kW) | Battery Size (kWh) | Energy Savings (\$) | Peak Demand Savings (\$) | Coincident Demand Savings (\$) | Total Annual Savings (\$) | Net Present Value (\$) | Savings (%) |
|---|--------------|-------------------|--------------------|---------------------|--------------------------|--------------------------------|---------------------------|------------------------|-------------|
| 1 ROSE CANYON OPERATIONS STATION | 155 | 44 | 230 | \$24,849 | \$10,794 | \$10,175 | \$45,818 | \$319,680 | 22% |
| 2 MIRAMAR OPERATIONS | 160 | 49 | 192 | \$24,698 | \$15,193 | \$11,580 | \$51,471 | \$445,070 | 22% |
| 3 COMMUNICATION BUILDING BLOCKHOUSE | 556 | 100 | 404 | \$88,275 | \$45,549 | \$45,570 | \$179,394 | \$1,924,640 | 29% |
| 4 ALLIED GARDENS & REC CENTER, BENJAMIN LIBRARY | 113 | 34 | 122 | \$19,318 | \$8,021 | \$6,604 | \$33,944 | \$281,200 | 19% |
| 5 NORTH UTC LIBRARY & NOBEL REC CENTER | 157 | 81 | 269 | \$26,246 | \$18,767 | \$17,728 | \$62,741 | \$537,920 | 31% |
| 6 CANYONSIDE REC CENTER | 112 | 304 | 720 | \$17,936 | \$58,511 | \$57,476 | \$133,923 | \$1,164,090 | 36% |
| 7 SOUTHEASTERN POLICE STATION | 66 | 10 | 45 | \$11,273 | \$2,442 | \$3,079 | \$16,794 | \$148,802 | 17% |
| 8 POLICE GARAGE, NORTHEASTERN | 65 | 10 | 44 | \$11,102 | \$2,415 | \$3,304 | \$16,821 | \$151,693 | 17% |
| 9 RIDGEHAVEN | 153 | 87 | 167 | \$28,919 | \$26,355 | \$15,919 | \$71,192 | \$788,820 | 21% |
| 10 MIDCITY PD | 99 | 16 | 86 | \$16,647 | \$4,805 | \$5,596 | \$27,048 | \$239,200 | 19% |


PV Generation and Battery Ratio

Annual Electricity Consumption vs. PV Generation




This chart shows the ratio of annual PV generation to annual electricity consumption for the REopt-calculated cost-optimal system sizes at each site. For reference, the dotted line indicates the points at which 50% of the load is served by PV generation. Dots below line indicate >50% of electricity from PV.

Battery Size kW vs. kWh



This chart shows the ratio of power to energy for the cost-optimal battery sizes, as calculated by REopt. The dotted lines represent the ratio of power to energy for batteries with a maximum discharge of two hours or four hours at rated power. Dots below the line indicate longer than the hour duration.

Rose Canyon Operations Station Dispatch Graph



Note: July 15th and July 16th represent weekend days.

This chart shows modeled dispatch of a combined PV and storage system at the Rose Canyon Operations Station for a representative week in July. The solar PV is meeting the load during the day, and excess generation is used to charge the battery. The battery is being dispatched in the late afternoon when the load is still high, but the solar generation is decreasing. Some PV generation is curtailed during the weekends

Rose Canyon Operations Station Sensitivity Analysis

| | 0. Base Case | 1. PV + Storage | 2. PV Only | 3. Storage Only | 4. City Owned | 5. ITC for Battery |
|---|--------------|------------------|------------------|-----------------|------------------|--------------------|
| PV Size (kW) | - | 155 | 96 | - | 144 | 208 |
| Battery Size (kW) | - | 44 | - | 12 | 48 | 66 |
| Battery Size (kWh) | - | 230 | - | 47 | 255 | 428 |
| Energy Cost (\$) | \$750,375 | \$273,167 | \$465,755 | \$744,713 | \$283,623 | \$147,278 |
| Peak Demand Charges (\$) | \$334,544 | \$127,260 | \$329,676 | \$285,014 | \$110,217 | \$51,019 |
| Non-Coincident Demand Charges (\$) | \$379,342 | \$183,935 | \$331,306 | \$336,737 | \$187,272 | \$153,148 |
| Lifecycle Cost of Electricity (\$) | \$1,464,260 | \$1,144,580 | \$1,294,120 | \$1,430,340 | \$1,142,850 | \$1,003,270 |
| Net Present Value (\$) | \$0 | \$319,680 | \$170,140 | \$33,920 | \$321,410 | \$460,990 |

This table shows sensitivity analyses for Rose Canyon Operations Station. Each net present value is relative to the base case.

Summary of Results

- PV and storage were assessed to be cost-effective at all buildings evaluated. While PV and storage are both cost-effective on their own, when implemented together, they provide more value.
- The cost-optimal system sizes could save a total of \$6 million in aggregate over the 20-year analysis period (26% reduction in electricity costs) for the 10 buildings.
- System sizes and ratios vary based on the load magnitude and shape at each building. The cost-optimal 1.6 MW of PV would generate 2,870,865 kWh annually, contributing 55% of the buildings' electricity consumption.
- All cost-optimal PV system sizes are smaller than the maximum system size that could fit on the ground, roof, and carport areas identified as suitable for PV.

Questions:

Emma Elgqvist

emma.elgqvist@nrel.gov

[**www.nrel.gov**](http://www.nrel.gov)



Estimate of Space for PV

1. ROSE CANYON OPERATIONS STATION


| ROSE CANYON OPERATIONS STATION | Sq. ft. |
|--------------------------------|---------|
| Carport 1 | 9,900 |
| Carport 2 | 9,500 |
| Carport 3 | 7,300 |
| Total | 26,700 |



2. MIRAMAR OPERATIONS

| MIRAMAR OPERATIONS | Sq. ft. |
|----------------------------|---------------|
| Carport 1 - New | 13,500 |
| Carport 2 - New | 13,500 |
| Carport 3 - Replacement | 3,400 |
| Carport 4 - Replacement | 3,400 |
| Total | 33,800 |
| | |
| New Roof (Retail Building) | 44,000 |
| Roof 1 | 32,800 |
| Total | 44,000 |

Note: Roof 1 not included



3. COMMUNICATION BUILDING BLOCKHOUSE

| COMMUNICATION BUILDING BLOCKHOUSE (Sq. ft.) | |
|---|----------------|
| Ground 1 - New | 68,900 |
| Ground 2 - New | 205,300 |
| Total | 274,200 |



4. ALLIED GARDENS & REC CENTER, BENJAMIN LIBRARY

ALLIED GARDENS POOL

ALLIED GARDENS RECREATION CENTER

BENJAMIN LIBRARY

| | Sq. ft. |
|------------------------|---------------|
| Carport 1 - Pool | 2,300 |
| Carport 2 - Pool | 3,200 |
| Carport 1 - Rec Center | 4,000 |
| Carport 2 - Rec Center | 6,800 |
| Carport 3 - Rec Center | 4,800 |
| Carport 1 - Library | 3,500 |
| Carport 2 - Library | 1,800 |
| Carport 3 - Library | 2,300 |
| Total | 28,700 |




5. NORTH UTC LIBRARY & NOBEL REC CENTER

NORTH UTC LIBRARY

NOBEL RECREATION CENTER


| | Sq. ft. |
|-------------------------|---------------|
| Carport 1 - Library | 2,200 |
| Carport 2 - Library | 3,800 |
| Carport 3 - Library | 3,400 |
| Carport 2 - Rec Center | 8,900 |
| Carport 3 - Rec Center | 8,200 |
| Carport 8 - Rec Center | 3,000 |
| Carport 9 - Rec Center | 5,100 |
| Carport 10 - Rec Center | 6,300 |
| Total | 40,900 |



6. CANYONSIDE REC CENTER

CANYONSIDE RECREATION CENTER


| | Sq. ft. |
|------------|---------|
| Carport 1 | 9,400 |
| Carport 2 | 6,900 |
| Carport 3 | 3,400 |
| Carport 4 | 2,300 |
| Carport 5 | 3,200 |
| Carport 6 | 3,200 |
| Carport 7 | 6,500 |
| Carport 8 | 4,400 |
| Carport 9 | 3,200 |
| Carport 10 | 4,600 |
| Carport 11 | 4,000 |
| Carport 12 | 3,800 |
| Carport 13 | 7,000 |
| Carport 14 | 6,900 |
| Total | 68,800 |



7. SOUTHEASTERN POLICE STATION

SOUTHEASTERN POLICE STATION


| | Sq. ft. |
|------------|---------|
| Carport 8 | 6,100 |
| Carport 9 | 6,400 |
| Carport 10 | 1,800 |
| Carport 11 | 2,700 |
| Total | 17,000 |



8. POLICE GARAGE, NORTHEASTERN


SOUTHEASTERN POLICE STATION

| | Sq. ft. |
|------------|---------|
| Carport 8 | 6,100 |
| Carport 9 | 6,400 |
| Carport 10 | 1,800 |
| Carport 11 | 2,700 |
| Total | 17,000 |



9. RIDGEHAVEN

| Ridgehaven | |
|-------------------------|---------------|
| | Sq. ft. |
| Carport 1 - Replacement | 500 |
| Carport 2 | 1,400 |
| Carport 3 | 2,000 |
| Carport 4 | 1,900 |
| Carport 5 | 3,000 |
| Carport 6 | 6,500 |
| Total | 15,300 |
| | |
| Roof 1 - Replacement | 2,600 |
| Roof 2 - Replacement | 900 |
| Roof 3 - Replacement | 500 |
| Roof 4 - Replacement | 2,300 |
| Total | 6,300 |



10. MIDCITY PD

| MID CITY POLICE STATION | | Sq. ft. |
|-------------------------|--|---------------|
| Carport 1 | | 4,440 |
| Carport 2 | | 4,440 |
| Carport 3 | | 4,440 |
| Total | | 13,320 |

