

A Power Hardware-in-the-Loop (PHIL) Test
Bed for Inverter Testing in Southern
California Edison (SCE)

6th International Workshop on Grid Simulator Testing of Wind Turbine Power Trains and Other Renewable Technologies

Arifujjaman, PhD
Grid Technology Innovation
Southern California Edison

November 9 - 10, 2022
Golden, CO

Energy for What's AheadSM



Outline

- ❑ Introduction
- ❑ Power Hardware-in-the-Loop (PHIL) Test Bed
- ❑ RSCAD Model and Scenarios
- ❑ Results
- ❑ Conclusions

Introduction

Energy for What's AheadSM



SCE Activities and Need

- ❑ The Distributed Energy Resource (DER) technologies are emerging as one of the most prominent solutions for Southern California Edison (SCE) to augment California's Green House Gas (GHG) reduction goals.
- ❑ The adoption of such technologies in the existing grid is also encouraged by the California Public Utilities Commission (CPUC) through numerous avenues. Such as the Electric Program Investment Charge (EPIC) program.
- ❑ Rule 21 compliant Smart Inverter (SI), which is a mandatory requirement for the interconnection of inverter-based DER technologies.
- ❑ The installed Legacy Inverters (LIs) are capable of performing certain functions, but in sharp contrast, SIs offer unique and advanced control capabilities when integrated with DER technology.

Aim of the Applied Research


- ❑ An organizational, vendor-agnostic PHIL test bed to enhance the ease of DER into the SCE grid. The testbed can enable SCE, stakeholders, national labs, vendors, and university researchers to evaluate existing and future use cases in a test set that provides a realistic combination of multiple utility management systems and field equipment
- ❑ Verify the Rule 21 advanced functions for smart inverters
- ❑ Analyze results and determine what could be the potential impact on the feeder protection system

Power Hardware-in-the-Loop (PHIL) Test Bed

Energy for What's AheadSM



PHIL Testbed Architecture



- ❑ The demonstration comprised of two smart and two legacy inverters, grid and PV simulator, RTDS, Sensor Circuits, protective relays, and an SCE feeder.
- ❑ The MPPT control has been performed locally

PHIL Testbed Pictures



Grid Simulator



Relay

PV Simulator

PHIL Testbed Pictures



RTDS



Sensor Circuits




Smart and Legacy Inverters

RSCAD Model and Scenarios

Energy for What's AheadSM



RSCAD Model for Feeder



Different Scenarios For Volt/VAR use case


Scenario NO.	Inverter (Hardware) in the loop	Simulated DER type	DER penetration level	Event
I	1 Smart	<ul style="list-style-type: none"> All PV inverters are legacy Sync and induction generation units are off 	60	Voltage variation
II	2 Smart	<ul style="list-style-type: none"> All PV inverters are legacy Sync and induction generation units are off 	60	Voltage variation
III	2 Smart	<ul style="list-style-type: none"> All PV inverters are smart Sync and induction generation units are off 	60	Voltage variation
IV	2 Smart	<ul style="list-style-type: none"> All PV inverters are smart Sync and induction generation units are off 	120	Voltage variation
V	2 Smart 2 Legacy	<ul style="list-style-type: none"> All PV inverters are legacy Sync and induction generation units are off 	60	Voltage variation
VI	2 Smart 2 Legacy	<ul style="list-style-type: none"> 66% smart inverters 34% legacy inverters Sync and induction generation units are off 	60	Voltage variation
VII	2 Smart 2 Legacy	<ul style="list-style-type: none"> 66% smart inverters 34% legacy inverters Sync and induction generation units are off 	120	Voltage variation
VIII	2 Smart 2 Legacy	<ul style="list-style-type: none"> 66% smart inverters 34% legacy inverters Sync and induction generation units are on 	60	Voltage variation
IX	2 Smart 2 Legacy	<ul style="list-style-type: none"> 66% smart inverters 34% legacy inverters Sync and induction generation units are on 	120	Voltage variation

Results

Energy for What's AheadSM




Volt/VAR Curve of Smart Inverters for IEEE 1547-2018



✓ Verify this curve for smart inverters in Scenario VII

Inverters DC Measurements for Operational Point #0 (+44,92)

- Running the RSCAD model and vary main source voltage to have **0.92 pu** voltage at PV.



Smart Inverter #1


Legacy Inverter #1

Legacy Inverter #2

Smart Inverter #2

Smart Inverter#1 Results for Operational Point #0 (+44,92)


- Running the RSCAD model and vary main source voltage to have **0.92 pu** voltage at PVHIL.



5/26/2022 07:29:45.134

— U1 rms AVG **110.33** V
 — U2 rms AVG **110.25** V

— I1 rms AVG **17.84** A
 — I2 rms AVG **17.85** A



5/26/2022 07:29:45.134


— P sum AVG **3.24** kW

— Q sum AVG **-2.23** kvar

$S_{\max} = 5050 \text{ KVA}$
 $-2.23 = 44.15\%$
 S_{\max}




Smart Inverter #1 Results for Operational Point #0 (+44,92)

- Running the RSCAD model and vary main source voltage to have **0.92 pu** voltage at PVHIL.



Legacy Inverter#1 Results for Operational Point #0 (+44,92)

- Running the RSCAD model and vary main source voltage to have **0.92 pu** voltage at PVHIL.



$V_{LL} \text{ rms} = 219.24 \text{ V}$
 $I_A \text{ rms} = 14.44 \text{ A}$
 $I_B \text{ rms} = 14.48 \text{ A}$
 $P = 3.16 \text{ kW}$


Inverter #2 and #3 Results for Operational Point #0 (+44,92)

- Running the RSCAD model and vary main source voltage to have **0.92 pu** voltage at PHIL.


Measurement Parameters	#2 (Smart)	#3 (Legacy)
V_A	110.3 V	110.3 V
V_B	110.2 V	110.2 V
I_A	17.75 A	14.41 A
I_B	18.04 A	14.45 A
S	3.94 KVA	3.16 KVA
P	3.28 kW	3.16 kW
Q	2.16 lead kVAR	0

$S_{\max} = 5000 \text{ KVA}$
 $2.16 = 43.3\% S_{\max}$


Volt/VAR Curve of Smart Inverter#1



Volt/VAR Curve of Smart Inverter#2




Inverters Verification for Operational Point #0 (+44,92)




RSCAD Results for Operational Point #0 (+44,92)

- Running the RSCAD model and vary main source voltage to have **0.92 pu** voltage at PVHIL.


GTAO Voltage/ Grid Simulator Input from RSCAD




GTAI Voltage/Current sensor output as input to RSCAD




GTAI Voltage/Voltage sensor output to RSCAD





GTAI Actual Current to RSCAD



P and Q set to PHIL Inverter in RSCAD at N37



Grid Simulator Results for Operational Point #0 (+44,92)




Phase A	Phase B
V rms	V rms
108.66	108.50
V dc	V dc
0.00	0.00
V THD	V THD
0.55 %	0.57 %
I rms	I rms
62.740	62.140
ICF	ICF
1.438	1.438
I THD	I THD
1.66 %	1.68 %
Power	Power
-6445.0	-6373.0
PF	PF
-0.945	-0.945

↓


$P_{\text{tot}} = 12.82$
 $Q_{\text{tot}} = 4.4363$
 kVAR

Relays Verification for Operational Point #0 (+44,92)




Relays Results for Operational Point #0 (+44,92)


Voltage in RSCAD



Current output in RSCAD



P and Q measurement in RSCAD



Instantaneous


Relay HMI

Date: 05/25/22 Time: 15:08:24.544


I MAG (A)	A	B	C	N	G	
	44.212	53.912	22.006	4.020	3.578	
I ANG (DEG)	A	B	C	S		
	-144.92	12.33	130.53	77.32	52.29	
V MAG (KV)	A	B	C	S		
	5.957	6.223	5.883	0.002		
V ANG (DEG)	A	B	C	S		
	0.00	-121.93	116.86	-88.19		
V MAG (KV)	AB	BC	CA			
	10.650	10.549	10.088			
V ANG (DEG)	AB	BC	CA			
	29.73	-93.44	148.65			
MW	A	B	C	3P		
	-0.216	-0.234	0.126	-0.324		
MVAR	A	B	C	3P		
	0.151	-0.240	-0.031	-0.119		
PF	A	B	C	3P		
	-0.818	-0.698	0.972	-0.938		
	LEAD	LAG	LEAD	LAG		
MAG	I1	3I2	3I0	V1	V2	3V0
	38.147	54.097	3.578	0.199	6.020	0.035
ANG (DEG)	I1	3I2	3I0	V1	V2	3V0
	-121.55	160.05	52.29	108.37	-1.69	-76.07
FREQ (Hz)	60.00					

Relays Results for Operational Point #0 (+44,92)


Voltage in RSCAD



Current in RSCAD



P and Q measurements in RSCAD



Relay HMI

Instantaneous


Date: 05/25/22 Time: 15:16:56.940

	A	B	C	N	G	
I MAG (A)	18.086	17.270	0.470	0.788	0.979	
I ANG (DEG)	-150.90	25.23	88.61	-158.66	-99.93	
	A	B	C	S		
V MAG (KV)	5.955	6.222	5.882	0.002		
V ANG (DEG)	0.00	-121.80	116.96	-75.62		
	AB	BC	CA			
V MAG (KV)	10.641	10.549	10.091			
V ANG (DEG)	29.80	-93.33	148.69			
	A	B	C	3P		
MW	-0.094	-0.090	0.002	-0.182		
MVAR	0.052	-0.058	0.001	-0.005		
PF	-0.874	-0.839	0.880	-1.000		
	LEAD	LAG	LAG	LAG		
	I1	3I2	3I0	V1	V2	3V0
MAG	10.539	29.600	0.979	0.195	6.018	0.045
ANG (DEG)	-123.94	178.44	-99.93	109.18	-1.61	-77.35
FREQ (Hz)	60.00					


Impact on Relays For Scenario VII

- ✓ During voltage variation event in which the voltage drops, breaker status is closed.
- ✓ No trips command for relays.


RMS Voltage Change During Voltage variation event




Status




RMS Voltage Change During Voltage variation event



Status




Front-Panel Display



After Voltage variation event




Front-Panel Display






Impact on Relays for Scenario I

✓ No trips command for relays.

Voltage Variation




Voltage variation








Impact on Relays for Scenario II

✓ No trips command for relays.

Voltage Variation




Voltage variation











Impact on Relays for Scenario III

✓ No trips command for relays.

Voltage Variation




Voltage variation




Impact on Relays for Scenario IV

✓ No trips command for relays.

Voltage Variation



Voltage variation



Front-Panel Display

Control Enabled	AC Supply	Battery Problem	Hot Line Tag	Trip	Fast Curve	High Current 81
Reset	Cycle	Lockout	A	B	C	G SEF

Control State FAULT TYPE

<input type="checkbox"/> GROUND ENABLED	<input type="checkbox"/> AUX 1
<input type="checkbox"/> RECLOSE ENABLED	<input type="checkbox"/> AUX 2

Front-Panel Display

Control Enabled	AC Supply	Battery Problem	Hot Line Tag	Trip	Fast Curve	High Current 81
Reset	Cycle	Lockout	A	B	C	G SEF

Control State FAULT TYPE

<input type="checkbox"/> GROUND ENABLED	<input type="checkbox"/> AUX 1
<input type="checkbox"/> RECLOSE ENABLED	<input type="checkbox"/> AUX 2

Front-Panel Display

Control Enabled	AC Supply	Battery Problem	Hot Line Tag	Trip	Fast Curve	High Current 81
Reset	Cycle	Lockout	A	B	C	G SEF

Control State FAULT TYPE

<input type="checkbox"/> GROUND ENABLED	<input type="checkbox"/> AUX 1
<input type="checkbox"/> RECLOSE ENABLED	<input type="checkbox"/> AUX 2

Front-Panel Display

Control Enabled	AC Supply	Battery Problem	Hot Line Tag	Trip	Fast Curve	High Current 81
Reset	Cycle	Lockout	A	B	C	G SEF


Control State FAULT TYPE

<input type="checkbox"/> GROUND ENABLED	<input type="checkbox"/> AUX 1
<input type="checkbox"/> RECLOSE ENABLED	<input type="checkbox"/> AUX 2










Impact on Relays for Scenario V

✓ No trips command for relays.

Voltage Variation




Voltage variation




Impact on Relays for Scenario VI

✓ No trips command for relays.


Voltage Variation




Voltage variation




Front-Panel Display








Front-Panel Display



Front-Panel Display




Front-Panel Display












Impact on Relays for Scenario VIII

✓ No trips command for relays.

Voltage variation




Voltage variation












Impact on Relays for Scenario IX

✓ No trips command for relays.

Voltage variation



Voltage variation



Conclusions

Energy for What's AheadSM



- ❑ The development of a Power Hardware-in-the-Loop (PHIL) testbed at Southern California Edison (SCE)'s Distributed Energy Resource (DER) Laboratory is described
- ❑ The volt/var use case results are verified by experimentation and found that there would be no impact on the feeder protection given the current protection setting.
- ❑ This testbed can benefit SCE to study the emerging technologies without the need to conduct in-field trials

Q & A